JAEA-Data/Code 2018-013 DOI:10.11484/jaea-data-code-2018-013



Mechanical Properties Database of Reactor Pressure Vessel Steels Related to Fracture Toughness Evaluation

Tohru TOBITA, Yutaka NISHIYAMA and Kunio ONIZAWA

Materials and Structural Integrity Research Division Nuclear Safety Research Center Sector of Nuclear Safety Research and Emergency Preparedness November 2018

Japan Atomic Energy Agency

日本原子力研究開発機構

本レポートは国立研究開発法人日本原子力研究開発機構が不定期に発行する成果報告書です。 本レポートの入手並びに著作権利用に関するお問い合わせは、下記あてにお問い合わせ下さい。 なお、本レポートの全文は日本原子力研究開発機構ホームページ(<u>http://www.jaea.go.jp</u>) より発信されています。

国立研究開発法人日本原子力研究開発機構 研究連携成果展開部 研究成果管理課 〒319-1195 茨城県那珂郡東海村大字白方 2 番地4 電話 029-282-6387, Fax 029-282-5920, E-mail:ird-support@jaea.go.jp

This report is issued irregularly by Japan Atomic Energy Agency. Inquiries about availability and/or copyright of this report should be addressed to Institutional Repository Section,

Intellectual Resources Management and R&D Collaboration Department, Japan Atomic Energy Agency.

2-4 Shirakata, Tokai-mura, Naka-gun, Ibaraki-ken 319-1195 Japan Tel +81-29-282-6387, Fax +81-29-282-5920, E-mail:ird-support@jaea.go.jp

© Japan Atomic Energy Agency, 2018

JAEA-Data/Code 2018-013

Mechanical Properties Database of Reactor Pressure Vessel Steels Related to Fracture Toughness Evaluation

Tohru TOBITA, Yutaka NISHIYAMA and Kunio ONIZAWA

Materials and Structural Integrity Research Division Nuclear Safety Research Center Sector of Nuclear Safety Research and Emergency Preparedness Japan Atomic Energy Agency Tokai-mura, Naka-gun, Ibaraki-ken

(Received August 28, 2018)

Mechanical properties of materials including fracture toughness are extremely important for evaluating the structural integrity of reactor pressure vessels (RPVs). In this report, the published data of mechanical properties of nuclear RPVs steels, including neutron irradiated materials, acquired by the Japan Atomic Energy Agency (JAEA), specifically tensile test data, Charpy impact test data, drop-weight test data, and fracture toughness test data, are summarized. There are five types of RPVs steels with different toughness levels equivalent to JIS SQV2A (ASTM A533B Class 1) containing impurities in the range corresponding to the early fission reactor plants to the latest plants. Neutron irradiation test was conducted at Japan Material Testing Reactor (JMTR). The data of the neutron fluence up to about 1×10^{20} n/cm² (E>1 MeV) at 290°C±5°C was evaluated. In addition to the base material of RPVs, the mechanical property data of the two types of stainless overlay cladding materials used as the lining of the RPV are summarized. These mechanical property data are summarized graphically for each material and listed also in tabular form to facilitate easy utilization of data.

Keywords: Reactor Pressure Vessel Steel, Stainless Overlay Cladding, Neutron Irradiation, and Mechanical Property

原子炉圧力容器鋼の破壊靱性評価に係る機械的特性データ集

日本原子力研究開発機構

安全研究・防災支援部門 安全研究センター 材料・構造安全研究ディビジョン

飛田 徹、西山 裕孝、鬼沢 邦雄

(2018年8月28日 受理)

原子炉圧力容器の健全性を判断する上で、破壊靱性を始めとする材料の機械的特性は重要な情報となる。本レポートは、日本原子力研究開発機構が取得した中性子照射材を含む原子炉圧力容器鋼材の機械的特性、具体的には引張試験、シャルピー 衝撃試験、落重試験及び破壊靱性試験の公開データをまとめたものである。対象とした材料は、国内の初期プラントから最新プラントに相当する範囲の不純物含有量及び靱性レベルで製造された5種類の原子炉圧力容器鋼である(JIS SQV2A(ASTM A533B Class1)相当)。中性子照射試験は Japan Material Testing Reactor (JMTR)にて実施された。照射量は最大で約1×10²⁰n/cm²(E>1 MeV)、照射温度は290°C±5°C である。また母材に加え、原子炉圧力容器の内張りとして用いられている2種類のステンレスオーバーレイクラッド材の機械的特性データについても掲載した。これらの機械的特性データは、材料ごとにグラフで整理するとともに、今後データを活用しやすいように表形式で整理した。

Contents

1. Introduction	1
2. Fabrication of material used	4
3. Tensile test	6
3.1 Test procedure	6
3.2 Results	6
4. Charpy impact test	16
4.1 Test procedure	16
4.2 Results	16
5. Drop-weight test	22
5.1 Test procedure	22
5.2 Results	22
6. Fracture toughness test	24
6.1 Master Curve method	24
6.2 Test procedure	25
6.3 Results	25
7. Summary	35
Acknowledgments	35
References	36
Appendix: Test data lists	38

目 次

1.	序論	1
2.	供試材の製作	4
3.	引張試験	6
	3.1 試験方法	6
	3.2 結果	6
4.	シャルピー衝撃試験	16
	4.1 試験方法	16
	4.2 結果	16
5.	落重試験	·22
	5.1 試験方法	22
	5.2 結果	22
6.	破壊靭性試験	·24
	6.1 マスターカーブ法について	24
	6.2 試験方法	25
	6.3 結果	25
7.	纏め	.35
謝	辛	35
参	考文献	36
付	录: 試験データリスト	38

List of Tables

Table 1 L	ist of materials and test data	3
Table 2 H	Ieat treatment of Steel A, Steel B, JRQ and Steel L	4
Table 3 C	Chemical composition (wt %) of materials	5
Table 4.1-1	Main specifications of 300J-Charpy impact testing machine	17
Table 5.2-1	Drop-weight test data	22
Table 6.3-1	Reference temperature (T _o) data	27
Table A T	ensile test data	39
Table B C	Charpy impact test data	42
Table C F	racture toughness test data	48

List of Figures

Fig. 3.1-1	Schematic images of tensile test specimens	7
Fig. 3.2-1	Stress-crosshead displacement curves	8
Fig. 3.2-2	Temperature dependence of tensile properties	11
Fig. 3.2-3	The difference between the measured σy and the calculated σy	15
Fig. 4.1-1	Schematic image of Charpy impact test specimen	17
Fig. 4.2-1	Charpy transition curves	18
Fig. 5.1-1	Schematic image of drop-weight test specimen	23
Fig. 6.2-1	Schematic images of fracture toughness test specimens	28
Fig. 6.3-1	1T-equivalent fracture toughness K _{Jc(1Teq)} and master curve	30
Fig. 6.3-2	Reference temperatures of all specimens for each material	34
Fig. 6.3-3	1T-equivalent fracture toughness, K _{Jc(1Teq)} normalized by T _{41J} obtained by Charpy impa	act test
	with 5% lower bound of master curve	34

This is a blank page.

1. Introduction

Since the reactor pressure vessels (RPV) are primary coolant boundary components, ensuring the structural integrity of RPVs is extremely important. In the transition temperature region, the fracture toughness of RPV steel depends on temperature, and fracture toughness decreases with decreasing temperature.

Because high pressure and low temperature are superimposed in RPV at the operating transients, such as startup/shutdown of nuclear reactor operations and pressurized thermal shock event, if there are defects such as cracks on the inner surface of the RPV, they may penetrate the vessel. By subjected to neutron irradiation from the core, the fracture toughness of RPV steel gradually decreases and the transition temperature is shifted to high temperatures. Therefore, as reactor operation duration is prolonged, these property changes can be seriously affected on the structural integrity of RPV. Thus, evaluating the fracture toughness of RPV steel under the operation service is very important.

Recently, the Master Curve (MC) method has been developed to evaluate the temperature dependence of fracture toughness by conducting a relatively small number (6~8 or more) of fracture toughness tests and tensile tests^{1-1, 1-2)}. In the MC method, the temperature dependence of the median value of fracture toughness distribution of a 1-inch-thickness compact tension-type (1T-C(T)) specimen is provided by a single exponential curve. This concept, developed by Wallin et al. ¹⁻³⁾, accounts successfully for size effects on fracture toughness by combining the weakest link size effect with micro-mechanical models of cleavage fracture, and provides a means to calculate statistical confidence bounds on cleavage fracture toughness data.

In Japan Atomic Energy Agency (JAEA), many tests including irradiation tests related to fracture toughness evaluation of RPV steels by the MC method have been performed, and their results were published. The present report summarizes the published data of mechanical property for unifying relevant data pertaining to fracture toughness evaluation of RPV steels, including the data acquired at the Japan Atomic Energy Research Institute from 1994^{1-4, 1-5, 1-6}). The materials are the RPV steels based on the JIS SQV 2 A (ASTM A 533 B Class 1) standard. We focused on impurities in the steels that are thought to influence irradiation embrittlement considerably and the chemical compositions adjusted the contents of phosphorus, sulfur, and copper, as well as the toughness level. With the progress of manufacturing technology of reactor pressure vessel, the content of copper, phosphorus and sulphur contents in RPV steel has been gradually decreased. In the surveillance data of the base materials of the PWR plants in Japan, the phosphorus and the copper contents are distributed in 0.014 to 0.003 % and 0.16 to 0.018 %, respectively¹⁻⁷).

In addition to the unirradiated material, we examined the materials that were subjected to high levels of neutron irradiation (up to about 10^{20} n / cm² (E>1 MeV)) at the Japan Materials Testing Reactor (JMTR). Fracture toughness data obtained from specimens of different dimensions were summarized. The specimen sizes ranged from large compact tension-type (4T-C(T)) with a thickness of 100 mm to small compact tension-type (Mini-C (T)) with a thickness of 4 mm that can be taken from a Charpy impact specimen. In addition, the data of tensile tests, drop-weight tests, and Charpy impact tests were collected and analyzed as mechanical properties related to fracture toughness evaluation. By contrast, stainless steel overlay cladding

of about 5 mm in thickness was welded to the inner surface of the RPV, and the mechanical properties of the cladding were considered in the structural integrity assessment¹⁻⁸⁾. Therefore, mechanical property data of the cladding were also described. These mechanical property data of each material are summarized and presented in graphical and tabular formats.

The data summarized in this research report will be useful to the structural integrity assessments of RPVs and evaluation of irradiation embrittlement of RPV steels. Material test data are listed in Table 1.

			$(\sigma_y: Yield strength; c_y = 0$	σ _u : Ultimate strengtl	h; T _{NDT} : Nil-duc Charby	tility transition t Drop-weight	emperatur	(e)		¢ *	
Mat	loire	Fluence* ¹	Tensil	e test	impact test	test		Fracture	toughnes	ss test ^{*2}	
		(10 ¹⁹ n/cm ²) E>1 MeV	Temperature dependence of σ_y and σ_u	Stress-crosshead displacement curve	Charpy transition curve	TNDT	Mini- C(T)	PCCv ^{*3}	0.4T -C(T)	1T -C(T)	4T -C(T)
		0	0	0	0	0	0	0		0	0
	Steel A	9-13	0		0			0			
		0	0	0	0	0	0	0		0	0
	Steel B	8-11	0		0			0			
RPV .		0			0		0	0	0	0	
steels	JRQ	2-11			0			0			
		0	0		0					0	
	Steel L	2.9-3.1	0		0						
	SJSP	0	0		0			0			
tainless		0	0	0	0						
steel	SAW CL	10-12	0	0	0						
overlay		0	0	0	0						
ladding	ESW CL	12-15	0	0	0						
These irrs	idiation test	s were conduct	ted in the IMTR								

Table 1 List of materials and test data

I liese illauialioli lesis wele colluucieu

^{*&}lt;sup>2</sup> Fracture toughness tests using Mini-C (T) specimens and other (PCCv, 0.4T-C(T), 1T-C(T)) specimens were conducted according to ASTM E 1921-12 and ASTM E 1921-97, Respectively.

^{*3} Pre-Cracked Charpy-v type specimen (PCCv).

2. Fabrication of material used

Five types of ASTM A533B Class 1 steel (Steel A, Steel B, JRQ, Steel L and JSPS) plates of thickness about 200 mm were fabricated according to JIS SQV 2 A and ASME SA533/SA533M (except Cu, P, and S contents) ²⁻¹). Here, JRQ is the International Atomic Energy Agency (IAEA) "reference" material used in several IAEA coordinated research programs²⁻²). JRQ is used for many IAEA projects dealing with the study of the behavior of RPV steels under neutron irradiation, which began in 1983. The use of JRQ material has since then been internationally recognized and explored by a number of Member States. JSPS is the material used in the round robin study organized by The Japan Society for Promoting of Science (JSPS) ²⁻³). This material was deliberately embrittled by increasing the concentration of Sulphur and Phosphorous in order to obtain a very low Upper Shelf Energy (USE \approx 70 J) in the unirradiated condition.

The heat treatment for these steels were carried out according to the standard. As an example, the heat treatment conditions of Steel A, Steel B, JRQ and Steel L are shown in Table 2.

Two types of weld overlay cladding materials were fabricated by means of submerged-arc welding (SAW CL) and electroslag welding (ESW CL) of base metals with stainless steel plates, respectively ²⁻⁴). The thickness of the both cladding was about 5 mm and heat treatment was carried out for 7 hours at 615 °C \pm 20 °C after welding. The dimensions of the base metal used for welding are 850 mm × 550 mm × 200 mm thickness.

Table 3 shows the chemical compositions of the materials taken from the 1/4 thickness position of the plates and cladding materials.

Material ID	Quenching	Tempering	Stress relief
Steel A	860 to 893 °C,	650 to 660 °C – 6 h,	610 to 623 °C – 42 h,
	Water quenched	Air cooled	Cooling rate <-35°C/h
Steel B	860 to 893 °C,	650 to 660 °C – 6 h,	610 to 623 °C – 42 h,
	Water quenched	Air cooled	Cooling rate <-35°C/h
JRQ	880 °C, Water quenched	665 °C – 12 h, Air cooled	620 °C – 40 h
Steel L	900 °C,	660 °C – 5 h,	600 °C - 25 h
	Water quenched	Air cooled	Cooling rate < -50 °C/h

Table 2 Heat treatment of Steel A, Steel B, JRQ and Steel L

		TUDIC		micodition i	ULL (WL /U) UL	CIBI 1010111				
Μ	aterial ID	С	Si	Mn	Р	S	Cu	Ni	Cr	Мо
Steel A		0.19	0.30	1.30	0.015	0.010	0.16	0.68	0.17	0.53
Steel B		0.19	0.19	1.43	0.004	0.001	0.04	0.65	0.13	0.50
JRQ		0.18	0.24	1.42	0.017	0.004	0.14	0.84	0.12	0.51
Steel L		0.17	0.24	1.36	0.003	0.003	0.02	0.61	0.07	0.47
JSPS		0.24	0.41	1.52	0.028	0.023	0.19	0.43	0.08	0.49
SAW CL	First layer: SUS309L	0.058	0.57	1.49	0.013	0.008		9.9	19.5	0.08
(Base: Steel A)	Last layer: SUS308L	0.030	0.84	1.56	0.009	0.009		10.4	19.6	0.01
ESW CL	First layer: SUS309L	0.013	0.62	1.28	0.02	0.002		10.7	19.5	0.02
(Base: Steel B)	Last layer: SUS308L	0.013	0.65	1.18	0.02	0.002		10.7	19.5	0.02

Table 3 Chemical composition (wt %) of materials

3. Tensile test

3.1 Test procedure

Tensile tests, in which two types of test specimens were examined, were conducted in the temperature range from -200 °C to 290 °C. The test temperature was measured with a K type thermocouple in contact with the specimen. The tensile test was carried out using Shimadzu or Instron's universal testing machine. In the tests, the crosshead speed was 0.1~0.5 mm/min at the constant. Schematic images of the specimens are shown in Fig. 3.1-1. Note that the SS - 3 type specimens tend to exhibit yield stress and tensile strength as high as several % and elongation as low as several %, as compared with round bar type specimens. The series of specimens were taken in the T direction from the 1/4 thickness position of the steel plate.

3.2 Results

Tensile tests were conducted using unirradiated materials (Steel A, Steel B, JRQ, Steel L, JSPS, SAW CL and ESW CL) and irradiated materials (Steel A, Steel B, Steel L, SAW CL and ESW CL). The stresscrosshead displacement curves obtained at the temperature examined are shown in Fig. 3.2-1, and the corresponding tensile test results (yield strength (σ_y), ultimate strength (σ_u), uniform elongation, fracture elongation, total elongation, and reduction of area) are summarized in Table A of Appendix. Figure 3.2-1 and Figure 3.2-2 shows the stress-crosshead displacement curves and the temperature dependence of tensile properties, respectively. Here, the graph of JRQ is a reprint of the one of IAEA report ³⁻¹.

The σ_y measured (σ_y (meas.)) in the present study was compared to the calculated temperature dependence of σ_y ($\sigma_{y(cal.)(T)}$), and the comparison result is shown in Fig. 3.2-3. The $\sigma_{y(cal.)(T)}$ was calculated using the following equation given in the Japan Welding Engineering Society Standards (WES1108-1195). This equation is also recommended as yield stress evaluation method of the Japanese Electric Association Code"Test Method for Determination of Reference Temperature, T_o, of Ferritic Steels," (JEAC 4216-2015).

$$\sigma_{y(cal.)(T)} = \sigma_{y(RT)} \exp\left\{ \left[481.4 - 66.5 \ln(\sigma_{y(RT)}) \right] \left[\frac{1}{T + 273} - \frac{1}{293} \right] \right\}$$
(3-1)

Here, $\sigma_{y(RT)}$ is the σ_y value at room temperature (in MPa), T is temperature (in K).

In Fig. 3.2-3, the evaluation results of the material JRQ using literature data ²⁻²⁾ of σ_y (meas.) are plotted as well. From Fig. 3.2-3, σ_y (cal.) is almost equal to σ_y (meas.) at temperatures above 0 °C, whereas σ_y (cal.) is smaller than σ_y (meas.) at temperatures below 0 °C.



(Round bar type: Steel A, Steel B, Steel L, JSPS, SAW CL and ESW CL)



(mm)

Fig. 3.1-1 Schematic images of tensile test specimens



Fig.3.2-1 Stress-crosshead displacement curves (1/3)





Fig.3.2-1 Stress-crosshead displacement curves (2/3)



Fig.3.2-1 Stress-crosshead displacement curves (3/3)



Fig. 3.2-2 Temperature dependence of tensile properties (1/4)



Fig. 3.2-2 Temperature dependence of tensile properties (2/4)



Fig. 3.2-2 Temperature dependence of tensile properties (3/4)



Fig. 3.2-2 Temperature dependence of tensile properties (4/4)



Fig. 3.2-3 The difference between the measured σ_y ($\sigma_{y(meas.)}$) and the calculated σ_y ($\sigma_{y(cal.)}$)

4. Charpy impact test

4.1 Test procedure

The Charpy impact test was performed using the 300-J Charpy impact testing machine with an International Organization for Standardization (ISO)-type hammer tup in the temperature range of -130 °C to 290 °C. The hammer speed at impact was ~5 m/s. The main specifications of the Charpy impact testing machine and schematic image of the test specimen are summarized and shown, respectively, in Table 4.1-1 and Fig. 4.1-1. All Charpy V-notch specimens were machined along the T-L orientation from the 1/4 thickness position of the steel plate.

The specimens were set in a temperature control bath for 15 min before testing. The media in the bath were alcohol for the low-temperature test and silicon oil for the high-temperature one. An automated specimen transfer system was used to maintain identical testing conditions for all specimens and to minimize the change in specimen temperature during transfer. The average time to impact of the specimens after removal from the temperature control bath was \sim 3.5 s.

4.2 Results

Charpy impact tests were conducted using all unirradiated materials, and the irradiated materials except JSPS. Charpy transition curves obtained in this study are shown in Fig. 4.2-1. As it can be seen in the figure, the materials exhibit ductile-brittle transition behavior with decreasing temperature because of the dominance of δ -ferrite phase. With neutron irradiation, a decrease in the upper-shelf energy (USE) and an increase in the Charpy 41 J temperature (T_{41J}) were observed. The results of the Charpy impact test are summarized in Table B of Appendix.

Hammer mass (kg)	26.6
Hammer edge	r =2mm (ISO type)
Centroid distance from rotation axis (m)	0.634
Gravitational acceleration (m/s ²)	9.8
Swing-up angle (degree)	144.5
Center of impact from rotation axis (m)	0.750
Capacity (J)	300
Blowing speed (m/s)	5.17
Resolution of impact force	12 bit
Sampling frequency	1 MHz

 Table 4.1-1
 Main specifications of 300J-Charpy impact testing machine





Fig. 4.1-1 Schematic image of Charpy impact test specimen



Fig. 4.2-1 Charpy transition curves (1/4)





Fig. 4.2-1 Charpy transition curves (2/4)



Fig. 4.2-1 Charpy transition curves (3/4)



Fig. 4.2-1 Charpy transition curves (4/4)

5. Drop-weight test

5.1 Test procedure

The drop-weight test was performed using drop-weight tester in accordance with the ASTM standerd for conducting drop-weight test to determine nil-ductility transition temperature of ferritic steels (ASTM E 208). P-3-type drop-weight test specimens shown in Fig. 5.1-1 with a single-pass crackstarter weld bead were used in this test. The nil-ductility transition temperature (T_{NDT}) is defined in ASTM E 208 to be the highest temperature at which a specimen breaks, provided two tests at a temperature 5°C higher show no-break performance.

5.2 Results

Drop-weight tests were conducted using unirradiated Steels A and B. The series of specimens were taken in the T direction from the 1/4 thickness position of the steel plate. The results of the drop-weight tests and the obtained T_{NDT} are shown in Table 5.2-1.



Table 5.2-1Drop-weight test data

* As a result of the Charpy impact test at T_{NDT} + 33 °C, all three specimens absorbed energy of 68 J or more and underwent lateral expansion of 0.9 mm or more. That is, T_{NDT} can be considered the reference temperature for nil-ductility transition (RT_{NDT}).



Fig. 5.1-1 Schematic image of drop-weight test specimen

6. Fracture toughness test

6.1 Master Curve method

Changes in the fracture toughness of RPV steels were evaluated from the initial fracture toughness and shifts in the Charpy energy transition curve due to neutron irradiation. To evaluate the structural integrity of RPVs, a lower-bound curve that enveloped the fracture toughness data was used. However, the lower-bound curve depended on the amount of data and scatter.

The MC method^{1-1,1-2)} is expected to be useful for direct evaluation of fracture toughness. This method allows for theoretical expression of the confidence limit considering the inherent statistical characteristics of fracture toughness. In the MC method, the relationship between temperature and median fracture toughness ($K_{Jc(med)}$) of a 1-inch-thick specimen is given as follows:

 $K_{Jc(med)} = 30 + 70 \exp[0.019(T - T_o)], MPa\sqrt{m},$ (6-1)

where

T: temperature (°C),

 T_o : reference temperature (°C).

 T_o is defined as the temperature at 100 MPa \sqrt{m} and is determined by at least six fracture toughness data points.

In the MC method, the fracture toughness value obtained from a small-sized specimen is adjusted to K_{Jc} value equivalent to a 1-inch-thick specimen ($K_{Jc(1Teq)}$) by the following equation:

 $K_{Jc(1Teq)} = K_{min} + (K_{Jc x} - K_{min})(B_x / B_{1T})^{1/4},$ (6-2)

where

$$\begin{split} &K_{Jc_x}: K_{Jc} \text{ for specimens of thickness } B_x, \\ &K_{min}: 20 \text{ MPa} \sqrt{m}, \\ &B_x: \text{ Thickness of specimen}, \\ &B_{1T}: \text{ Thickness of 1 inch thick specimen (=25.4mm).} \end{split}$$

Owing to the limited number of surveillance fracture toughness specimens in the surveillance capsule of Japanese early nuclear power plants, it was difficult to obtain sufficient data using the MC method in conjunction with the surveillance program for RPV steels. Therefore, many efforts have been made to create 4-mm-thick miniature compact tension (Mini-C (T)) specimens from broken surveillance Charpy specimens.

6.2 Test procedure

The fracture toughness tests using Mini-C (T), pre-cracked Charpy-V (PCCv), 0.4T-C (T), 1T-C (T) and 4T-C (T) specimens were performed using a 100 kN mechanical-servo type testing machine. Specimen preparation and testing were conducted according to the ASTM standard ^{1-1),6,2-1)} and according to studies in the literature ^{6,2-2)}. Due to the difference in the test period, fracture toughness tests using Mini-C (T) specimens and other (PCCv, 0.4T-C(T), 1T-C(T)) specimens were conducted according to ASTM E 1921-12 and ASTM E 1921-97, Respectively. Schematic images of the test specimens are shown in Fig. 6.2-1. The specimens were machined along the T-L orientation from the 1/4 thickness position of the steel plate. All specimens were side-grooved by 10% on each side after fatigue precracking. For the fatigue precracking, the maximum applied stress intensity factor was 20 MPa√m in the first precracking step and 15 MPa√m in the final step. A calibrated load cell and a clip gauge were used for measuring the applied load and load point displacement, respectively.

Before testing, the temperature of the test specimen and the fixture inside the testing chamber were maintained at the target temperature for 20 min. Cold nitrogen gas was injected into the chamber for low-temperature testing. The temperature distribution around the specimen was measured using calibrated thermocouples. One thermocouple was attached to the upper fixture. The other thermocouples were buried in the dummy specimens and located close to the test specimen. The temperatures of all thermocouples and, hence, that of the test specimen were then controlled to the target temperature within a variation of 1°C during testing.

6.3 Results

Fracture toughness tests were conducted using unirradiated materials (Steel A, Steel B, JRQ, Steel L and JSPS) and irradiated materials (Steel A, Steel B and JRQ). The K_{Jc} and K_{Jc(1Teq)} values obtained in the test are summarized in Table C of Appendix. The full cleavage fracture surface of all tested specimens was observed. Invalid K_{Jc} data exceeding K_{Jc(limit)} were omitted based on the K_{Jc(limit)} value according to ASTM E1921. The K_{Jc(1Teq)} values are plotted against the test temperature in Fig. 6.3-1 along with the MC. The T_o values were determined mainly by using the multi-temperature method according to ASTM E1921, and results are summarized in Table 6.3-1. The T_o values of JRQ are within the range of scatter of the IAEA round-robin test results^{6.3-1}).

The T_o values of all the specimens of the materials are shown in Fig. 6.3-2. The error bars in this figure represent the standard deviation (σ) in the estimation of T_o , which incorporates sample size and experimental uncertainties and is given by following equation;

$$\sigma = (\beta^2/r + (\sigma_{exp})^2)^{0.5}, \qquad (6-3)$$

where

 β : the sample size uncertainty factor determined based on 1T-equivalent K_{Jc(med)},

r: the total number of valid K_{Jc} data points,

 σ_{exp} : the contribution of experimental uncertainties.

The T_o values determined using the Mini-C (T) specimens as well as the 0.4T-C (T) specimens showed good agreement overall with those determined using the 1T-C (T) specimens. In case of the PCCv specimens, all T_o values were lower than those determined using the 1T-C (T) specimens. In this regard, a study ^{6.3-1} reported that the T_o of bending-type specimens is approximately 8 °C lower than that of the CT-type specimens, probably because of the difference in constraint near the crack tip.

With regard to evaluation of the fracture toughness of RPV steels based on the MC method, the 5% lowerbound of the MC was adopted as new fracture toughness curve for pressurerized thermal shock (PTS) evaluation in Japanese electric association codes^{6.3-2)} revised recent year. Yoshimoto et al. ^{6.3-3)} proposed T_{41J} based lower-bound curves of $K_{Jc(1Teq)}$ expressed by Eq. (6-4).

 $K_{Jc(0.xx)} = 20 + [ln\{1/(1 - 0.xx)\}]^{1/4} \{11 + 77exp[0.019(T - (T_{41J} + \Delta T_t))]\}, \quad (6-4)$

where

0.xx: cumulative probability level of xx%, T_{41J}: Charpy 41J transition temperature, ΔT_t : -15°C for plate and 14°C for weld materials.

The fracture toughness data of all the specimens normalized by $T_{41J} + \Delta T_t$ are shown in Fig. 6.3-3. The data of irradiated materials obtained using the PCCv specimens are plotted in the same figure as well. The solid line in the figure is the new fracture toughness curve for PTS evaluation, i.e. the 5% (xx = 05) lower bound of the MC. Most of the data, including those of the 4T-C (T) and the irradiated PCCv specimens, were enveloped by the proposed lower bound with a ratio of approximately 98%.

			Table 6.3-1	Reference terr	iperature (]	Γ₀) da	ta				
Material ID	Fluence $(10^{19} \text{ n})/(\text{cm}^2)$	Specimen type	Test temperature range (°C)	Loading rate dK/dt (MPa√m/s)	No. of to data	otal	No. of valid data	T ₀ (°	C)*1	Standard d estimate (eviation of of T _o (°C)
Steel A	0	Mini-C (T)	-100	0.1	6	29	9 27	-72	-67	7.4	5.4
			-90 to -100	0.5	10		8	-70		7.5	
			-100	1.8	10		10	-58		7.5	
		PCCV	-80 to -100	1.0	42		34	-7	6	4	9
		1T-C (T)	-30 to -80	0.8	32		32	9	6	5	1
	13	PCCv	50	1.0	8		8	7.	3	7	8
Steel B	0	Mini-C (T)	-120	0.1	10	30	10 29	-86	-91	7.2	5.3
			-120	0.5	10		9	-102		7.2	
			-120	1.8	10		10	-78		7.5	
		PCCV	-110 to -130	1.0	32		29	-1(60	5	2
		1T-C (T)	-60 to -110	0.8	32		32	6-	7	5	1
	11	PCCV	-50	1.0	7		7	-2	4	8	2
JRQ	0	Mini-C (T)	-100 to -110	0.5	12		11	×	0	9	9
		PCCV	-80	1.0	16		16	9	5	9	2
		0.4T-C (T)	-50 to -80	0.5	15		15	9	5	9	1
		1T-C (T)	-50 to -80	0.8	6		6	Ŷ	5	7	2
	11	PCCV	100	1.0	8		8	13	4	7	8
Steel L	0	PCCV	-100 to -130	1.0	22		15	-	14	9	1
		1T-C (T)	-100	0.8	9		9	-	17	8	4
	2.9	PCCV	-40	1.0	12		12	5	4	9	7
JSPS	0	PCCV	-25	1.0	8		8	(1		7	8
*1 Fracture toughne	ss tests using Min	i-C (T) specimens an	nd other (PCCv, 0.4T-C	(T), 1T-C(T)) specir	nens were con	nducted	according to AST	ME 1921-	2 and AS	TM E 1921-97,	Respectively.

- 27 -



Fig. 6.2-1 Schematic images of fracture toughness test specimens (1/2)



Fig. 6.2-1 Schematic images of fracture toughness test specimens (2/2)



Fig. 6.3-1 1T-equivalent fracture toughness $K_{Jc(1Teq)}$ and master curve (1/4)



Fig. 6.3-1 1T-equivalent fracture toughness K_{Jc(1Teq)} and master curve (2/4)



Fig. 6.3-1 1T-equivalent fracture toughness $K_{Jc(1Teq)}$ and master curve (3/4)



Fig. 6.3-1 1T-equivalent fracture toughness K_{Jc(1Teq)} and master curve (4/4)



Fig. 6.3-2 Reference temperatures of all specimens for each material



Fig. 6.3-3 1T-equivalent fracture toughness, K_{Jc(1Teq)} normalized by T_{41J} obtained by Charpy impact test with 5% lower bound of master curve

7. Summary

Many tests including irradiation tests related to structural integlity assessment of RPV have been performed. Material tests such as tensile, drop-weight, Charpy impact, and fracture toughness tests of RPV steels were carried out using five types of ASTM A533B Class1 steels with different impurity contents and fracture toughness levels, and the test results arewere summarized in this research report. Especially in the fracture toughness test, a large number of tests using specimens with different sizes and shapes were conducted, and the applicability of the master curve method which introduced in Japanese electric association codes in recent years was also confirmed.

The data summarized in this research report will be useful to the structural integrity assessments of RPVs and evaluation of irradiation embrittlement of RPV steels.

Acknowledgments

This work includes the experimental results under a contract with the former Science and Technology Agency (STA) of Japan. The authors wish to thank Drs. Satoshi HANAWA and Jin OHGIYANAGI of Japan Atomic Energy Agency for their useful comments to improve the manuscript.

References

- 1-1) ASTM international, "Standard Test Method for Determination of Reference Temperature, To, for Ferritic Steels in the Transition Range", ASTM E1921-12 (2012).
- 1-2) Japan Electric Association, "Test Method for Determination of Reference Temperature, T_o, of Ferritic Steels", JEAC 4216-2015(2015) (in Japanese).
- 1-3) Wallin, K., "The Scatter in K_{Ic}-results", Engineering Fracture Mechanics, vol.19, no. 6, pp. 1085-1093 (1984).
- 1-4) Onizawa K., Tobita T. and Suzuki M., "Investigation on the evaluation of cleavage fracture toughness using PCCv specimens in the ductile-brittle transition range of reactor pressure vessel steels (contract research)", JAERI-Research 97-081, 36p. (1997).
- 1-5) Onizawa, K., Tobita, T., and Suzuki, M., "Effect of Irradiation on Fracture Toughness in the Transition Range of RPV steels", Effects of Radiation on Materials: 19th International Symposium, ASTM international, pp.204-219 (2000).
- 1-6) Onizawa K. and Suzuki M., "Correlation Between Cleavage Fracture Toughness and Charpy Impact Properties in the Transition Temperature Range of Reactor Pressure Vessel Steels", JSME International Journal Series A, vol. 47, no.3, pp. 479-485 (2004).
- 1-7) Soneda N. ed., "Irradiation Embrittlement of Reactor Pressure Vessels (RPVs) in Nuclear Power Plants", Woodhead Publishing Series in Energy; number 26, Elsevier (2015).
- 1-8) Japan Electric Association, "Method of Verification Tests of the Fracture Toughness for Nuclear Power Plant Components", JEAC 4206-2016(2016) (in Japanese).
- 2-1) ASTM international, "Standard Specification for Pressure Vessel Plates, Alloy Steel, Quenched and Tempered 8 and 9 Percent Nickel", ASTM A553 / A553M 95(2000).
- 2-2) International Atomic Energy Agency, "Reference manual on the IAEA JRQ correlation monitor steel for irradiation damage studies", IAEA-TECDOC-1230 (2001).
- 2-3) Japan Society for the Promotion of Science, "Standard Test Method for Fracture Toughness within Ductile-Brittle Transition Range", Standard of the 129th Committee (1995) (in Japanese).
- 2-4) Tobita T., Udagawa M., Chimi Y., Nishiyama Y. and Onizawa K., "Effect of neutron irradiation on the mechanical properties of weld overlay cladding for reactor pressure vessel", J. Nucl. Mat., vol. 452, no. 1-3, pp. 61-68 (2014).
- 3-1) International Atomic Energy Agency, "Reference manual on the IAEA JRQ correlation monitor steel for irradiation damage studies", IAEA-TECDOC-1230 (2001).
- 6.2-1) ASTM international, "Standard Test Method for Determination of Reference Temperature, T_o, for Ferritic Steels in the Transition Range", ASTM E1921-97 (1997).
- 6.2-2) Tobita T., Nishiyama Y., Ohtsu T., Udagawa M., Katsuyama J.and Onizawa K., "Fracture Toughness Evaluation of Reactor Pressure Vessel Steels by Master Curve Method Using Miniature Compact Tension Specimens", Journal of Pressure Vessel Technology, vol.137, no.5, pp.051405_1-051405_8 (2015).

- 6.3-1) International Atomic Energy Agency, "Application of Surveillance Programme Results to Reactor Pressure Vessel Integrity Assessment", IAEA-TECDOC-1435 (2005).
- 6.3-2) Japan Electric Association, "Method of Verification Tests of the Fracture Toughness for Nuclear Power Plant Components", JEAC 4206-2016(2016) (in Japanese).
- 6.3-3) Yoshimoto K., Hirota T. and Sakamoto H., "Fracture Toughness Curves of Japanese Reactor Pressure Vessel Steels considering Neutron Irradiation Embrittlement", E-Journal of Advanced Maintenance, vol.7, no.2, pp. 166-171 (2015).

Appendix: Test data lists

Test data lists consist of the following Tables.

Table A Tensile test data

Table B Charpy impact test data

Table C Fracture toughness test data

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Test temp. (°C)	σ _y (MPa)	σ _u (MPa)	UE (%)	TE (%)	RA (%)
Steel A	0	-195	905	990	17.0	27.8	51.6
		-173	739	866	14.7	29.6	58.9
		-142	720	853	15.1	29.8	59.4
		-112	621	779	15.3	29.0	64.7
		-82	532	708	15.4	27.1	68.2
		-52	504	672	12.4	26.4	67.9
		-31	498	653	12.5	27.7	68.6
		26	469	612	10.5	26.4	70.6
		148	435	566	8.8	21.5	69.7
		292	416	582	9.9	22.4	67.2
	8.9	-50	766	866	10	18.7	
	@290°C	27	672	767	9.5	20.0	
		29	701	793	8.8	17.2	
		50	678	770	9.7	19.3	
		50	691	783	9.1	18.7	
		150	630	746	9.6	17.8	
		290	594	723	8.8	17.1	
Steel B	0	-195	918	991	14.3	26.7	55.0
		-173	784	874	14.5	28.1	65.2
		-142	729	849	14.8	27.2	64.1
		-112	632	770	13.6	28.9	70.6
		-82	539	700	14.0	29.2	71.8
		-52	496	656	12.9	28.0	74.1
		-31	492	641	11.0	26.9	72.6
		26	462	597	10.3	24.9	75.7
		148	416	542	8.0	21.0	73.7
		292	407	565	8.9	23.7	73.0
	8.1	-50	585	703	10.4	21.5	
	@290°C	-50	612	733	11.6	24.8	
		-20	585	703	10.4	21.5	
		-20	596	707	11.1	23.6	
		27	562	667	10.0	21.6	

Table ATensile test data (1/3)

(UE: Uniform elongation; TE: Total elongation; RA: Reduction of area)

Material ID	Fluence (10^{19} n/cm^2) E>1 MeV	Test temp. (°C)	σ _y (MPa)	σ _u (MPa)	UE (%)	TE (%)	RA (%)
Steel B	8.1	27	565	666	10.0	22.6	
	@290°C	150	500	630	11.3	22.0	
		290	484	620	11.3	24.1	
Steel L	0	25	471	613		24.7	73.5
		25	468	609		26.2	73.5
		25	469	612		24.6	72.2
		20	465	607	11.8	24.1	72.8
		20	456	599	11.3	25.5	74
		290	412	608	12	24.3	73.7
	3.1	-40	564	699	11.7	22.5	
	@290°C	-40	558	692	11.3	22.8	
		15	527	651	9.59	19.59	
		15	527	651	10.05	21.41	
		100	491	613	9.14	18.05	
		150	472	616	10.41	19.82	
		290	450	621	9.73	20.09	
JSPS	0	-75	515	732	16.7	24.3	
		-50	497	698	15.3	24.1	
		-25	483	685	12.1	18.3	58.0
		-25	486	681	13.8	21.0	52.1
		0	468	659	11.6	18.3	61.9
		0	468	658	14.1	21.6	54.0
		25	459	636	11.0	17.1	61.3
		25	463	641	11.1	18.6	57.9
		25	462	640	13.1	19.8	57.8
		100	431	600	11.8	17.1	
		200	422	619	12.6	17.0	
		290	415	648	13.0	18.7	
SAW CL	0	-150	279	1039		40	
		25	283	516		59	
		25	281	501		60	
		150	257	399		34	

Table ATensile test data (2/3)(UE: Uniform elongation; TE: Total elongation; RA: Reduction of area)

Material ID	Fluence (10^{19} n/cm^2) E>1 MeV	Test temp. (°C)	σ _y (MPa)	σ _u (MPa)	UE (%)	TE (%)	RA (%)
SAW CL	0	290	228	341		35	
	10.0	25	395	564		40	
	@290°C	25	377	565		43	
		100	326	473		29	
		150	321	444		29	
		150	315	439		34	
		200	300	418		29	
		290	274	389		27	
		290	280	382		23	
ESW CL	0	-150	227	991		40	
		25	285	487		58	
		25	279	484		58	
		150	243	376		34	
		290	212	339		30	
	12.0	25	407	555		50	
	@290°C	25	342	539		60	
		100	310	436		24	
		150	319	439		33	
		150	306	438		33	
		200	285	400		24	
		290	263	380		31	
		290	267	368		21	

Table ATensile test data (3/3)

(UE: Uniform elongation; TE: Total elongation; RA: Reduction of area)

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Test temp. (°C)	Absorbed energy (J)Shear fractureLateral Expansion (%)		Lateral Expansion (mm)	T _{41J} (°C)	USE (J)
Steel A	0	-100	6.9	0	0.010		
		-80	15.9	0	0.067		
		-80	6.5	0	0.036		
		-60	19.2	5	0.129		
		-60	28.2	5	0.202		
		-50	29.3	5	0.284		
		-50	40.3	10	0.456		
		-40	40.3	10	0.715	10	1.51
		-40	42.7	10	0.708	-42	151
		-20	74.9	25	1.233		
		-20	70.9	25	1.220		
		11	118.4	80	1.657		
		11	104.4	65	1.677		
		40	148.4	100	2.248		
		40	152.2	100	2.193		
		60	151.6	100	2.187		
	13	50	14.0	7	0.195		
	@290°C	70	18.1	11	0.494		
		90	16.0	22	0.419		
		110	32.0	24	0.584		
		120	34.8	37	0.656	112	97
		125	64.2	71	1.213	113	86
		130	69.7	82	1.426		
		150	77.3	82	1.445		
		180	82.1	100	1.468		
		180	90.1	100	1.711		
Steel B	0	-100	8.0	0	0.027		
		-100	5.6	0	0.016		
		-80	11.2	0	0.022	(1	207
		-80	10.6	0	0.040	-01	207
		-70	25.7	5	0.233		
		-70	34.2	5	0.224		

Table BCharpy impact test data (1/6)(T41J: Charpy 41 J temperature, USE: Upper-shelf energy)

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Test temp. (°C)	Absorbed energy (J)Shear fractureLateral Expansion (%)		Lateral Expansion (mm)	T _{41J} (°C)	USE (J)
Steel B	0	-60	59.9	10	0.697		
		-60	23.4	5	0.152		
		-50	52.5	15	0.623		
		-50	75.2	20	0.985		
		-40	97.9	30	1.343		
		-40	114.9	40	1.778	(1	207
		-20	153.0	70	2.059	-61	207
		-20	159.0	75	2.165		
		11	220.9	100	2.625		
		12	198.8	100	2.421		
		40	202.5	100	2.437		
		60	205.6	100	2.568		
	11	-40	5.3	2	0.091		
	@290°C	-20	25.9	7	0.431		
		0	22.9	18	0.437		
		10	16.0	14	0.347		
		15	48.7	31	0.825	10	177
		28	108.9	54	1.590	10	166
		50	116.2	67	1.779		
		70	152.3	84	2.195		
		100	163.2	100	2.285		
		120	168.7	100	2.342		
JRQ	0	-80	5.2	0	0.023		
		-60	8.3	0	0.059		
		-40	13.1	0	0.06		
		-40	29.5	5	0.279		
		-20	20.2	5	0.142	25	104
		-20	25.1	5	0.254	-25	194
		-10	84.8	20	1.376		
		-10	92.8	25	1.19		
		-5	29.3	5	0.389		
		-5	125.0	55	1.89		

Table BCharpy impact test data (2/6)(T41J: Charpy 41 J temperature, USE: Upper-shelf energy)

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Test temp. (°C)	Absorbed energy (J)Shear fractureLateral Expansion (%)		Lateral Expansion (mm)	T _{41J} (°C)	USE (J)
JRQ	0	12	78.7	20	1.267		
		12	103.5	30	1.434		
		40	138.6	50	2.063		
		40	147.3	80	2.005	25	104
		60	162.2	90	2.21	-25	194
		100	179.4	100	2.431		
		100	201.4	100	2.577		
		120	199.8	100	2.395		
	2.4	-20	7.2	0	0.214		
	@290°C	19	13.2	7	0.276		
		40	8.5	9	0.220		
		40	7.9	10	0.260		
		50	51.5	26	0.898		
		50	44.2	25	0.797	55	120
		60	57.9	27	1.013	33	130
		80	80.0	45	1.283		
		100	77.1	56	1.501		
		140	131.6	100	2.052		
		160	141.0	100	2.146		
		160	117.3	100	1.857		
	10	20	5.4	0	0.120		
	@290°C	20	3.2	0	0.097		
		20	17.0	7	0.047		
		90	2.2	10	0.264		
		90	2.2	42	0.827		
		90	2.2	50	0.799	171	111
		175	67.4	70	1.283	101	111
		200	67.7	86	1.108		
		200	74.3	89	1.322		
		230	109.3	100	1.732		
		230	111.1	100	1.862		
		230	113.4	100	2.028		

Table BCharpy impact test data (3/6)(T41J: Charpy 41 J temperature, USE: Upper-shelf energy)

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Test temp. (°C)	Absorbed energy (J)	Shear fracture (%)	Lateral Expansion (mm)	T _{41J} (°C)	USE (J)
Steel L	0	-80	6	0	0.03		
		-80	11	0	0.02		
		-80	12.9	0	0.072		
		-80	21	0	0.16		
		-70	15	10	0.4		
		-70	42	15	0.5		
		-70	56	20	0.71		
		-65	39	10	0.47		
		-60	15	10	0.12		
		-60	40.6	5	0.445		
		-60	46	15	0.53		
		-60	54	30	0.69		
		-60	59	20	0.78		
		-60	84	30	1.11		
		-55	54	15	0.69	(9	190
		-50	79	30	1.03	-08	189
		-50	90	30	1.21		
		-50	103	35	1.39		
		-40	94.5	45	1.446		
		-40	103	35	1.41		
		-40	137	45	1.79		
		-20	112	50	1.48		
		-20	131	55	1.68		
		-20	133.1	50	1.899		
		0	134	60	1.84		
		0	148	70	1.87		
		11.6	161	80	2.181		
		20	191	100	2.17		
		20	196	100	2.35		
		40	178.8	100	2.219		

Table BCharpy impact test data (4/6)(T41J: Charpy 41 J temperature, USE: Upper-shelf energy)

Material ID	Fluence (10^{19} n/cm ²) E>1 MeV	Test temp. (°C)	Absorbed energy (J)	Shear fracture (%)	Lateral Expansion (mm)	T _{41J} (°C)	USE (J)
Steel L	2.9	-40	12.5	9	0.321		
	@290°C	-20	13.2	12	0.322		
		0	39.7	23	0.711		
		15	45.8	31	0.923	10	1.5.1
		28.3	54.7	38	0.951	12	151
		50	95.8	56	1.684		
		70	143.3	100	2.257		
		100	158.1	100	2.340		
JSPS	0	-50	5.4	0			
		-20	11				
		0	16.5				
		20.5	27.9	20			
		23.7	27.7	20			- 4
		40	37.3	50		39	/4
		50	45.4				
		60	58.1	80			
		80	70.1	100			
		100	78.5	100			

Table BCharpy impact test data (5/6)(T41J: Charpy 41 J temperature, USE: Upper-shelf energy)

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Test temp. (°C)	Absorbed energy (J)	Shear fracture (%)	Lateral Expansion (mm)	T _{41J} (°C)	USE (J)
SAW CL	0	-130	22.9				
		-100	34.5				
		-50	38.9				
		-20	52.8			()	74
		13	69.9			-63	/6
		50	71.5				
		100	76.8				
		150	76.0				
	12	-100	14.7				
	@290°C	-50	32.3				
		-20	44.1			-27	59
		21	51.0				
		100	58.8				
ESW CL	0	-130	37.0				
		-100	50.0				
		-50	61.5				
		-20	91.1			110	120
		13	118.1			-110	128
		50	116.4				
		100	128.2				
		150	126.8				
ESW CL	15	-100	16.7				
	@290°C	-50	46.1				
		-20	60.8			-55	95
		21	77.4				
		100	95.1				

Table B	Charpy impact test data (6/6)
---------	-------------------------------

(T_{41J}: Charpy 41 J temperature, USE: Upper-shelf energy)

Table C Fracture toughness test data (1/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was	calcrated from K _{Jc(limit)} as	a censored K _{Jc} according to	OASTM E1921.
-------------------------------	--	---	--------------

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
Steel A	0	Mini-C	4.05	4.09	8.01	-90	0.5	66.7	49.5
		(T)	4.06	4.20	8.02	-100	1.8	69.8	51.5
			4.05	4.11	8.01	-90	0.5	70.8	52.1
			4.08	4.03	8.01	-100	0.1	72.0	52.9
			4.06	4.04	8.00	-100	1.8	72.3	53.1
			4.08	4.09	8.01	-100	0.1	75.4	55.1
			4.08	4.04	8.01	-100	0.5	79.0	57.3
			4.08	4.00	8.01	-100	0.5	83.0	59.9
			4.08	4.02	8.01	-100	0.1	84.0	60.5
			4.06	4.12	8.00	-100	1.8	86.2	61.8
			4.06	4.06	8.01	-100	1.8	92.0	65.5
			4.06	4.12	8.00	-100	1.8	92.5	65.8
			4.06	4.05	8.00	-100	1.8	92.7	66.0
			4.06	4.09	8.00	-100	1.8	93.6	66.5
			4.08	4.03	8.01	-100	0.1	95.2	67.6
			4.06	4.11	8.00	-100	1.8	95.9	68.0
			4.08	4.04	8.01	-100	0.1	96.7	68.5
			4.05	4.07	8.01	-90	0.5	96.9	68.6
			4.06	4.15	8.00	-100	1.8	97.3	68.9
			4.05	4.04	8.01	-90	0.5	100.4	70.8
			4.06	4.13	8.00	-100	1.8	104.5	73.4
			4.05	4.15	8.01	-90	0.5	109.7	76.7
			4.08	4.06	8.01	-100	0.1	118.6	82.5
			4.08	4.08	8.01	-100	0.1	120.7	83.7
			4.08	4.15	8.01	-100	0.1	125.9	87.0
			4.08	4.08	8.01	-100	0.1	126.4	87.4
			4.08	4.05	8.00	-100	0.5	126.7	87.6
			4.05	4.11	8.01	-90	0.5	137.5 [132.4]	91.0* ¹⁾
			4.05	4.12	8.02	-90	0.5	184.6 [132.4]	91.0*1)

Table C Fracture toughness test data (2/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was	calcrated from K _{Jc(limit)} as	a censored K _{Jc} according to	OASTM E1921.
-------------------------------	--	---	--------------

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
Steel A	0	PCCv	10.00	5.11	10.03	-100	1.0	57.9	50.1
			10.00	4.99	10.05	-90	1.0	60.8	52.4
			10.00	4.67	10.05	-90	1.0	64.7	55.6
			10.00	5.05	10.02	-100	1.0	66.7	57.2
			10.00	4.98	10.02	-100	1.0	72.7	61.9
			10.00	5.15	10.03	-100	1.0	75.6	64.3
			10.00	5.05	10.03	-100	1.0	76.2	64.7
			10.01	5.09	10.01	-80	1.0	78.3	66.4
			10.00	4.96	10.01	-80	1.0	78.5	66.5
			10.00	4.98	10.02	-100	1.0	82.4	69.7
			10.01	5.02	10.01	-80	1.0	85.0	71.7
			10.00	5.33	10.03	-100	1.0	86.5	72.9
			10.00	5.01	10.03	-90	1.0	86.5	73.0
			10.00	4.80	10.05	-90	1.0	89.0	74.9
			10.00	5.00	10.03	-100	1.0	91.9	77.2
			10.00	4.76	10.08	-90	1.0	93.1	78.1
			10.00	4.86	10.07	-90	1.0	94.6	79.4
			10.01	5.12	10.01	-80	1.0	96.6	81.0
			10.02	5.10	10.01	-80	1.0	99.5	83.3
			10.00	4.91	10.03	-90	1.0	100.8	84.3
			9.99	5.07	9.99	-80	1.0	103.5	86.4
			10.00	5.09	10.02	-100	1.0	104.9	87.5
			10.00	5.02	10.02	-100	1.0	107.5	89.6
			10.00	4.91	10.00	-90	1.0	109.8	91.4
			10.00	5.00	10.00	-80	1.0	110.8	92.3
			10.00	4.98	10.02	-80	1.0	111.9	93.1
			10.01	5.18	10.01	-80	1.0	112.0	93.2
			10.00	4.94	10.08	-90	1.0	113.1	94.1
			10.00	5.02	10.03	-80	1.0	113.3	94.2
			10.00	5.01	10.06	-90	1.0	115.0	95.6

Table C Fracture toughness test data (3/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was c	calcrated from K _{Jc(limit)} as a	censored K _{Jc} according to	OASTM E1921.
---------------------------------	--	---------------------------------------	--------------

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
Steel A	0	PCCv	10.00	5.07	10.03	-80	1.0	118.8	98.7
			10.01	5.08	10.02	-80	1.0	122.6	101.7
			10.00	5.04	10.03	-80	1.0	125.3	103.8
			10.01	5.21	10.01	-80	1.0	127.7	105.7
			10.00	5.16	10.02	-80	1.0	139.6 [135.6]	111.9* ¹⁾
			10.02	5.15	10.02	-80	1.0	139.6 [135.5]	112.0*1)
			10.00	5.13	10.03	-80	1.0	145.3 [136.1]	112.4*1)
			10.00	5.16	10.01	-80	1.0	148.1 [135.3]	111.8* ¹⁾
			10.01	5.25	10.01	-80	1.0	156.9 [134.0]	110.7*1)
			10.00	5.01	10.01	-80	1.0	173.1 [137.4]	113.4*1)
			10.01	5.13	10.01	-80	1.0	174.7 [135.7]	112.1*1)
			10.01	5.14	10.01	-80	1.0	202.3 [135.6]	111.9* ¹⁾
		1T-C (T)	25.02	29.64	50.04	-80	0.8	64.2	64.0
			25.00	28.59	49.99	-80	0.8	69.9	69.7
			25.00	28.57	50.01	-80	0.8	72.6	72.4
			24.99	28.73	50.00	-80	0.8	73.5	73.2
			25.00	28.55	50.00	-80	0.8	79.6	79.4
			25.00	28.77	50.00	-80	0.8	85.2	84.9
			25.02	29.08	50.00	-80	0.8	87.5	87.2
			25.00	29.30	50.02	-50	0.8	94.4	94.1
			25.02	29.24	50.02	-80	0.8	97.0	96.7
			25.02	29.05	50.02	-80	0.8	99.3	99.0
			24.99	28.55	50.00	-80	0.8	102.2	101.9
			25.00	29.32	50.02	-80	0.8	109.6	109.3
			25.02	29.21	50.02	-50	0.8	88.5	88.3

Table C Fracture toughness test data (4/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

^{*1)} K _{Jc(1Teq)} was calcrate	d from K _{Jc(limit)} as a censored	K _{Jc} according to ASTM E1921.
---	---	--

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K_{Jc} [K _{Jc(limit)}] (MPa \sqrt{m})	K _{Jc(1Teq)} (MPa√m)
Steel A	0	1T-C (T)	25.02	29.54	50.02	-50	0.8	106.3	106.0
			25.00	28.59	49.99	-50	0.8	111.0	110.6
			25.00	29.06	50.02	-50	0.8	116.0	115.7
			25.02	29.22	50.00	-50	0.8	120.3	119.9
			25.00	29.37	50.02	-50	0.8	130.6	130.2
			25.02	29.01	50.04	-50	0.8	133.2	132.8
			25.00	28.54	49.99	-50	0.8	138.4	137.9
			25.00	29.10	49.97	-50	0.8	142.8	142.3
			25.00	28.46	50.00	-50	0.8	147.4	146.9
			24.99	28.71	50.00	-50	0.8	154.5	154.0
			25.00	28.64	50.05	-50	0.8	170.9	170.3
			24.99	28.83	49.97	-30	0.8	138.7	138.2
			25.00	29.16	50.05	-30	0.8	151.1	150.6
			25.00	28.90	49.98	-30	0.8	153.9	153.4
			25.00	29.03	49.98	-30	0.8	162.2	161.6
			24.99	28.78	50.02	-30	0.8	178.0	177.3
			25.00	28.92	50.04	-30	0.8	187.6	187.0
			25.00	29.02	50.07	-30	0.8	188.6	187.9
			25.00	28.90	50.00	-30	0.8	223.1	222.3
		4T-C (T)	101.2	106.15	200.3	-80	0.1	75.8	99.1
			100.0	105.64	200.5	-50	0.1	96.7	128.4
			101.4	106.63	200.4	-50	0.1	102.8	137.5

Table C Fracture toughness test data (5/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was calcrated from K _{Jc(limit)} as a	censored K _{Jc} according to ASTM E1921.
--	---

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
Steel A	13	PCCv	9.98	5.21	9.99	50	1.0	52.1	45.5
	@290°C		9.99	5.12	9.99	50	1.0	57.4	49.7
			9.99	5.05	9.99	50	1.0	60.2	52.0
			9.99	5.07	9.99	50	1.0	62.5	53.8
			9.99	5.02	9.99	50	1.0	68.5	58.6
			9.98	5.11	9.98	50	1.0	71.7	61.1
			9.99	5.09	9.99	50	1.0	90.9	76.3
			9.99	5.12	9.99	50	1.0	143.8	118.4
Steel B	0	Mini-C	4.08	4.05	8.01	-120	1.8	48.4	38.0
		(T)	4.05	4.05	8.02	-120	0.5	61.2	46.0
			4.07	4.04	8.00	-120	1.8	67.5	50.1
			4.05	4.13	8.01	-120	0.1	70.2	51.7
			4.08	4.06	8.01	-120	1.8	77.7	56.5
			4.05	4.07	8.00	-120	0.5	78.6	57.0
			4.05	4.14	8.01	-120	0.1	78.9	57.2
			4.05	4.13	8.01	-120	0.1	82.8	59.7
			4.05	4.11	8.01	-120	0.1	83.1	59.9
			4.08	4.04	8.01	-120	1.8	83.2	60.0
			4.04	4.11	8.01	-120	0.1	86.4	61.9
			4.08	4.07	8.01	-120	1.8	88.3	63.2
			4.05	4.09	8.01	-120	0.5	89.5	63.9
			4.05	4.18	8.01	-120	0.1	89.5	63.9
			4.08	4.11	8.00	-120	1.8	91.0	64.9
			4.05	4.10	8.01	-120	0.1	91.8	65.4
			4.08	4.07	8.00	-120	1.8	91.8	65.4
			4.08	4.08	8.01	-120	1.8	93.8	66.7
			4.08	4.05	8.01	-120	1.8	93.8	66.7
			4.05	4.11	8.01	-120	0.5	96.7	68.5
			4.06	4.00	8.01	-120	0.5	103.3	72.7
			4.04	4.10	8.01	-120	0.1	110.6	77.2

Table C Fracture toughness test data (6/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was calcrated f	from K _{Jc(limit)} as a censored	K _{Jc} according to ASTM E1921.
---	---	--

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	$\begin{array}{c} K_{Jc(1Teq)} \\ (MPa\sqrt{m}) \end{array}$
Steel B	0	Mini-C	4.08	4.10	8.01	-120	1.8	115.3	80.3
		(T)	4.05	4.18	8.01	-120	0.1	115.6	80.4
			4.05	4.07	8.01	-120	0.5	128.0	88.3
			4.06	4.08	8.01	-120	0.5	129.8	89.4
			4.05	4.12	8.00	-120	0.1	131.9	90.7
			4.06	4.05	8.00	-120	0.5	132.6	91.2
			4.06	4.13	8.01	-120	0.5	134.9	92.7
			4.06	4.09	8.01	-120	0.5	162.4 [142.2]	97.2* ¹⁾
		PCCv	10.00	4.80	10.00	-130	1.0	47.5	41.9
			10.02	4.85	10.00	-110	1.0	63.2	54.4
			10.00	5.04	10.00	-120	1.0	64.1	54.9
			10.02	5.01	10.01	-110	1.0	73.2	62.3
			10.00	4.93	10.03	-130	1.0	59.5	51.4
			10.00	5.01	10.03	-130	1.0	61.5	53.0
			10.00	4.98	10.00	-120	1.0	69.0	58.7
			10.01	5.07	10.00	-120	1.0	73.8	62.5
			10.01	4.80	10.05	-120	1.0	74.7	63.2
			9.99	4.85	10.00	-120	1.0	79.4	66.8
			10.01	4.87	10.00	-130	1.0	72.8	62.0
			10.01	4.81	10.05	-110	1.0	92.7	77.9
			10.01	4.85	10.00	-110	1.0	93.1	78.2
			10.00	4.97	10.00	-130	1.0	74.0	62.9
			10.01	4.84	10.04	-130	1.0	74.0	62.9
			10.01	4.81	10.00	-110	1.0	94.2	79.1
			10.00	4.88	10.03	-120	1.0	84.1	70.5
			10.00	5.01	10.04	-120	1.0	84.2	70.5
			10.00	4.87	10.00	-130	1.0	75.0	63.7
			10.01	5.12	10.02	-130	1.0	76.5	64.9
			10.01	5.15	10.01	-130	1.0	83.5	70.5
			10.01	5.23	10.02	-130	1.0	84.2	71.1

Table C Fracture toughness test data (7/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was calcrated from K _{Jc(limit)} as a	censored K _{Jc} according to ASTM E1921.
--	---

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K_{Jc} $[K_{Jc(limit)}]$ $(MPa\sqrt{m})$	K _{Jc(1Teq)} (MPa√m)
Steel B	0	PCCv	10.02	4.92	10.03	-120	1.0	97.9	81.2
			10.03	4.79	10.01	-120	1.0	102.6	84.8
			10.00	4.74	10.02	-110	1.0	119.9	99.5
			10.02	5.13	10.02	-110	1.0	122.6	101.6
			10.02	5.18	10.01	-120	1.0	112.0	92.1
			10.00	4.96	10.01	-110	1.0	134.2	110.8
			10.01	5.07	10.01	-110	1.0	140.8	116.1
			10.02	5.08	10.01	-110	1.0	149.4 [116.9]	119.3*1)
			10.01	5.25	10.02	-110	1.0	152.0 [116.9]	117.4* ¹⁾
			10.02	5.30	10.02	-110	1.0	228.3 [116.9]	116.9* ¹⁾
		1T-C (T)	25.00	28.59	50.02	-110	0.8	65.2	65.0
			25.04	28.67	50.02	-110	0.8	71.0	70.9
			25.00	29.12	50.02	-110	0.8	71.1	70.9
			25.02	29.17	50.02	-110	0.8	78.1	77.9
			25.02	29.73	50.02	-110	0.8	79.6	79.4
			25.02	28.96	50.00	-110	0.8	87.6	87.4
			25.00	28.63	50.01	-110	0.8	97.7	97.4
			25.04	28.98	50.00	-110	0.8	99.3	99.0
			24.99	29.38	50.00	-110	0.8	104.3	104.0
			25.02	29.31	50.02	-110	0.8	108.0	107.7
			25.00	29.27	50.04	-110	0.8	110.5	110.1
			25.00	28.79	50.03	-110	0.8	120.8	120.4
			25.02	29.06	50.02	-80	0.8	72.3	72.1
			25.00	28.81	50.01	-80	0.8	88.4	88.1
			25.02	29.22	50.02	-80	0.8	94.2	93.9
			25.00	29.22	50.01	-80	0.8	105.4	105.1
			25.02	29.35	50.00	-80	0.8	122.8	122.5
			25.00	28.54	50.00	-80	0.8	124.6	124.2
			24.99	28.74	50.02	-80	0.8	132.8	132.3

Table C Fracture toughness test data (8/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was calcrated	from K _{Jc(limit)} as a	censored K _{Jc}	according to A	STM E1921.
---	----------------------------------	--------------------------	----------------	------------

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
Steel B	0	1T-C(T)	25.02	29.48	50.00	-80	0.8	134.1	133.7
			25.02	29.08	50.02	-80	0.8	135.2	134.8
			25.04	28.88	50.02	-80	0.8	136.4	136.0
			25.00	29.40	50.02	-80	0.8	136.9	136.4
			25.00	28.43	50.00	-80	0.8	158.6	158.0
			25.00	28.80	50.00	-60	0.8	122.8	122.3
			25.00	29.18	50.06	-60	0.8	123.4	123.0
			25.00	29.27	50.06	-60	0.8	155.0	154.4
			25.00	28.89	50.02	-60	0.8	157.4	156.8
			25.00	29.15	50.06	-60	0.8	184.7	184.1
			25.00	29.06	50.07	-60	0.8	210.6	209.8
			25.00	29.19	50.02	-60	0.8	211.0	210.2
			25.00	29.17	50.02	-60	0.8	226.8	226.0
		4T-C (T)	101.5	106.39	200.4	-110	0.1	55.9	71.0
			101.5	108.93	200.2	-80	0.1	69.6	90.5
			101.3	106.99	200.2	-80	0.1	102.6	137.2
Steel B	11	PCCv	9.99	5.04	10.00	-50	1.0	44.8	39.7
	@290°C		9.98	4.96	9.98	-50	1.0	55.2	48.0
			9.99	4.91	9.99	-50	1.0	61.9	53.3
			9.98	5.10	9.98	-50	1.0	92.8	77.9
			9.99	5.10	9.99	-50	1.0	94.6	79.3
			9.98	5.06	9.98	-50	1.0	108.7	90.5
			10.00	5.04	10.01	-50	1.0	112.2	93.3

Table C Fracture toughness test data (9/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was calc	rated from K _{Jc(limit)} as a c	ensored K _{Jc} according to	ASTM E1921.
------------------------------------	--	--------------------------------------	-------------

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
JRQ	0	Mini-C	4.08	3.98	8.00	-100	0.5	116.2	80.9
		(T)	4.08	3.98	8.00	-100	0.5	76.7	55.9
			4.08	4.03	8.01	-100	0.5	102.6	72.3
			4.08	4.09	8.01	-100	0.5	100.8	71.2
			4.08	4.05	8.01	-100	0.5	65.2	48.6
			4.08	4.00	8.01	-100	0.5	153.6 [139.6]	95.7* ¹⁾
			4.08	4.07	8.00	-110	0.5	67.1	49.8
			4.08	4.04	8.01	-110	0.5	140.3	96.2
			4.08	4.06	8.02	-110	0.5	121.6	84.3
			4.08	4.05	8.02	-110	0.5	82.9	59.8
			4.08	4.03	8.01	-110	0.5	99.7	70.5
			4.07	4.06	8.01	-110	0.5	59.0	44.7
		PCCv	10.00	5.06	10.00	-80	1.0	39.9	35.8
			10.00	4.97	10.02	-80	1.0	72.6	61.8
			10.00	5.60	10.00	-80	1.0	86.0	72.5
			10.00	5.58	10.00	-80	1.0	86.2	72.6
			10.00	5.60	10.00	-80	1.0	89.7	75.4
			10.00	4.90	10.01	-80	1.0	92.6	77.7
			10.00	5.64	10.00	-80	1.0	92.9	78.0
			10.00	5.61	10.00	-80	1.0	93.0	78.1
			10.00	4.93	10.00	-80	1.0	99.0	82.8
			10.00	4.95	10.00	-80	1.0	110.0	91.5
			10.00	5.07	10.00	-80	1.0	115.7	96.1
			10.00	5.78	10.00	-80	1.0	119.9	99.4
			10.00	4.96	10.00	-80	1.0	120.3	99.7
			10.00	5.54	10.00	-80	1.0	121.3	100.6
			10.00	5.01	10.00	-80	1.0	125.6	104.0
			10.00	5.64	10.00	-80	1.0	127.3	105.3

Table C Fracture toughness test data (10/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was calcrated	from K _{Jc(limit)} as a	censored K _{Jc} ad	ccording to AS	STM E1921
---	----------------------------------	-----------------------------	----------------	-----------

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
JRQ	0	0.4T-C	10.03	10.97	20.00	-80	0.5	109.7	91.1
		(T)	10.03	11.11	20.01	-80	0.5	79.4	67.1
			10.03	11.02	20.01	-80	0.5	101.8	84.8
			10.03	11.08	20.01	-80	0.5	94.5	79.0
			10.03	10.97	20.01	-80	0.5	116.2	96.3
			10.03	11.03	20.00	-80	0.5	126.6	104.5
			10.03	11.03	20.00	-80	0.5	111.2	92.3
			10.03	11.12	20.00	-80	0.5	129.1	106.5
			10.03	11.08	20.01	-50	0.5	128.1	105.7
			10.03	11.05	20.00	-50	0.5	161.6	132.3
			10.03	11.08	20.00	-50	0.5	171.4	140.0
			10.03	11.06	20.00	-50	0.5	171.6	140.2
			10.03	11.07	20.01	-50	0.5	136.8	112.6
			10.03	11.09	20.01	-50	0.5	138.1	113.6
			10.03	11.17	20.01	-50	0.5	81.2	68.5
		1T-C (T)	25.0	25.64	50.00	-80	0.8	50.2	50.1
			25.0	25.63	50.00	-80	0.8	61.6	61.5
			25.0	25.67	50.00	-80	0.8	65.5	65.3
			25.0	25.42	50.00	-80	0.8	76.3	76.1
			25.0	25.59	50.00	-80	0.8	80.4	80.1
			25.0	25.57	50.00	-80	0.8	122.0	121.6
			25.0	25.58	50.00	-50	0.8	136.1	135.6
			25.0	25.47	50.00	-50	0.8	100.4	100.1
			25.0	25.31	50.00	-50	0.8	144.8	144.3

Table C Fracture toughness test data (11/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

*1) K _{Jc(1Teq)} was calcrated	from K _{Jc(limit)} as a censored	K _{Jc} according to ASTM E1921.
---	---	--

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
JRQ	11	PCCv	10.02	5.23	10.03	100	1.0	57.0	49.4
	@290°C		10.01	5.26	10.03	100	1.0	64.0	55.0
			10.02	5.11	10.03	100	1.0	64.7	55.6
			10.02	5.13	10.03	100	1.0	68.1	58.3
			10.02	5.02	10.03	100	1.0	74.0	63.0
			10.02	5.08	10.02	100	1.0	80.9	68.4
			10.02	5.12	10.03	100	1.0	100.0	83.7
			10.02	5.18	10.03	100	1.0	109.6	91.3

Table C Fracture toughness test data (12/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

^{*1)} K _{Jc(1Teq)} was calcrated	from $K_{Jc(limit)}$ as a censored	K _{Jc} according to ASTM E1921.
--	------------------------------------	--

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
Steel L	0	PCCv	10.01	5.11	10.02	-130	1.0	67.5	57.8
			10.00	4.93	10.02	-130	1.0	73.3	62.4
			10.02	4.97	10.04	-130	1.0	82.4	69.6
			10.03	5.03	10.03	-130	1.0	91.3	76.7
			10.02	4.99	10.03	-130	1.0	94.6	79.4
			10.03	5.03	10.01	-130	1.0	100.3	83.9
			10.00	5.05	10.01	-130	1.0	101.6	84.9
			10.02	5.10	10.01	-130	1.0	113.3	94.2
			10.01	5.14	10.03	-130	1.0	114.2	94.9
			10.01	5.05	10.01	-130	1.0	127.4	105.4
			10.01	4.91	10.01	-100	1.0	117.2	97.3
			10.00	5.03	10.01	-100	1.0	120.3	99.8
			10.01	5.13	10.01	-100	1.0	128.8	106.6
			10.02	5.11	10.02	-100	1.0	135.5	111.9
			10.01	5.00	10.02	-100	1.0	140.4	115.8
			10.01	4.92	10.01	-100	1.0	158.5 [142.5]	117.4* ¹⁾
			10.01	5.10	10.02	-100	1.0	170.4 [140.2]	115.6* ¹⁾
			10.01	5.09	10.01	-100	1.0	192.0 [140.2]	115.6*1)
			10.02	4.87	10.01	-100	1.0	198.8 [143.2]	118.0*1)
			10.00	5.10	10.02	-100	1.0	199.8 [140.2]	115.6*1)
			10.01	4.88	10.01	-100	1.0	213.3 [143.2]	118.0*1)
			10.00	5.03	10.01	-100	1.0	213.5 [141.0]	116.2*1)

Table C Fracture toughness test data (13/13)

(B: Specimen thickness; a0: Crack length; W: Specimen width)

^{*1)} K _{Jc(1Teq)} was calcrated	from K _{Jc(limit)} as a censore	ed K _{Jc} according to ASTM E1921.
--	--	---

Material ID	Fluence (10 ¹⁹ n/cm ²) E>1 MeV	Specimen type	B (mm)	ao (mm)	W (mm)	Test temp. (°C)	dK/dt (MPa√m/s)	K _{Jc} [K _{Jc(limit)}] (MPa√m)	K _{Jc(1Teq)} (MPa√m)
Steel L	0	1T-C (T)	24.99	25.68	49.99	-100	0.8	61.8	61.6
			24.99	25.59	49.96	-100	0.8	105.7	105.3
			24.99	25.93	49.99	-100	0.8	115.3	114.9
			24.98	25.71	49.92	-100	0.8	141.2	140.7
			24.99	25.72	50.05	-100	0.8	150.4	149.8
			24.99	25.83	49.96	-100	0.8	170.8	170.2
	2.9	PCCv	10.01	5.25	10.00	-40	1.0	78.2	66.3
	@290°C		10.02	5.61	10.00	-40	1.0	78.6	66.6
			10.02	5.36	10.00	-40	1.0	81.7	69.1
			10.02	5.29	10.00	-40	1.0	92.7	77.9
			10.02	5.34	10.00	-40	1.0	95.4	80.0
			10.01	5.37	10.00	-40	1.0	103.2	86.2
			10.02	5.63	10.00	-40	1.0	104.6	87.3
			10.02	5.40	10.00	-40	1.0	105.8	88.3
			10.02	5.49	10.00	-40	1.0	106.5	88.8
			10.02	5.37	10.00	-40	1.0	108.9	90.7
			10.02	5.29	10.00	-40	1.0	125.7	104.1
			10.02	5.25	10.00	-40	1.0	131.5	108.7
JSPS	0	PCCv	10.01	4.84	10.00	-25	1.0	63.9	54.8
			10.00	4.95	10.00	-25	1.0	75.3	63.8
			10.01	4.91	10.00	-25	1.0	79.2	66.9
			10.00	5.29	9.99	-25	1.0	82.1	69.2
			10.01	4.93	10.01	-25	1.0	83.4	70.3
			10.01	4.99	10.00	-25	1.0	89.0	74.7
			10.01	4.85	10.01	-25	1.0	109.6	91.0
			10.01	4.85	10.01	-25	1.0	114.5	94.9

表 1. SI 基本単位							
甘大昌	SI 基本ì	単位					
盔半里	名称	記号					
長さ	メートル	m					
質 量	キログラム	kg					
時 間	秒	s					
電 流	アンペア	А					
熱力学温度	ケルビン	Κ					
物質量	モル	mol					
光度	カンデラ	cd					

表2. 基本単位を用いて表されるSI組立	「単位の例				
_{知立} SI 組立単位	SI 組立単位				
和立里 名称	記号				
面 積 平方メートル	m ²				
体 積 立方メートル	m ³				
速 さ , 速 度 メートル毎秒	m/s				
加速 度メートル毎秒毎秒	m/s^2				
波 数 毎メートル	m ⁻¹				
密度, 質量密度 キログラム毎立方メート	ル kg/m ³				
面 積 密 度 キログラム毎平方メート	ν kg/m ²				
比体積 立方メートル毎キログラ	ム m ³ /kg				
電 流 密 度 アンペア毎平方メート	\mathcal{N} A/m ²				
磁 界 の 強 さアンペア毎メートル	A/m				
量 濃 度 ^(a) , 濃 度 モル毎立方メートル	mol/m ⁸				
質量濃度 キログラム毎立方メート	ル kg/m ³				
輝 度 カンデラ毎平方メート	ν cd/m ²				
屈 折 率 ^(b) (数字の) 1	1				
比 透 磁 率 (b) (数字の) 1	1				
(a) 量濃度 (amount concentration) は臨床化学の分野	では物質濃度				

(substance concentration)ともよばれる。
 (b) これらは無次元量あるいは次元1をもつ量であるが、そのことを表す単位記号である数字の1は通常は表記しない。

表3. 固有の名称と記号で表されるSI組立単位

			SI 組立単位	
組立量	名称	記号	他のSI単位による	SI基本単位による
		10.0	表し方	表し方
平 面 角	ラジアン ^(b)	rad	1 ^(b)	m/m
立 体 角	ステラジアン ^(b)	$sr^{(c)}$	1 ^(b)	m^2/m^2
周 波 数	ヘルツ ^(d)	Hz		s ⁻¹
力	ニュートン	Ν		m kg s ⁻²
E 力 , 応 力	パスカル	Pa	N/m ²	$m^{-1} kg s^{-2}$
エネルギー,仕事,熱量	ジュール	J	N m	$m^2 kg s^2$
仕事率, 工率, 放射束	ワット	W	J/s	m ² kg s ⁻³
電荷,電気量	クーロン	С		s A
電位差(電圧),起電力	ボルト	V	W/A	$m^2 kg s^{-3} A^{-1}$
静電容量	ファラド	F	C/V	$m^{-2} kg^{-1} s^4 A^2$
電気抵抗	オーム	Ω	V/A	$m^2 kg s^{-3} A^{-2}$
コンダクタンス	ジーメンス	s	A/V	$m^{-2} kg^{-1} s^3 A^2$
磁東	ウエーバ	Wb	Vs	$m^2 kg s^2 A^{-1}$
磁 束 密 度	テスラ	Т	Wb/m ²	$kg s^{-2} A^{-1}$
インダクタンス	ヘンリー	Η	Wb/A	$m^2 kg s^{-2} A^{-2}$
セルシウス温度	セルシウス度 ^(e)	°C		K
光東	ルーメン	lm	cd sr ^(c)	cd
照度	ルクス	lx	lm/m ²	m ⁻² cd
放射性核種の放射能 ^(f)	ベクレル ^(d)	Bq		s ⁻¹
吸収線量,比エネルギー分与,	ガレイ	Gy	J/kg	m ² e ⁻²
カーマ	, , , , , , , , , , , , , , , , , , ,	Gy	ong	
線量当量,周辺線量当量,	2 ((g)	Su	I/lrg	2 -2
方向性線量当量,個人線量当量		30	o/kg	III S
酸素活性	カタール	kat		s ⁻¹ mol

酸素活性(カタール) kat [s¹ mol
 (a)SI接頭語は固有の名称と記号を持つ組立単位と組み合わせても使用できる。しかし接頭語を付した単位はもはや ュヒーレントではない。
 (b)ラジアンとステラジアンは数字の1に対する単位の特別な名称で、量についての情報をつたえるために使われる。 実際には、使用する時には記号rad及びsrが用いられるが、習慣として組立単位としての記号である数字の1は明 示されない。
 (c)測光学ではステラジアンという名称と記号srを単位の表し方の中に、そのまま維持している。
 (d)へルツは周頻現象についてのみ、ペラレルは放射性核種の統計的過程についてのみ使用される。
 (e)センシウス度はケルビンの特別な名称で、セルシウス温度を表すために使用される。やレシウス度とケルビンの
 (d)ペルジは周頻現象についてのみ、ペラレルは放射性核種の統計的過程についてのみ使用される。
 (e)センシウス度はケルビンの特別な名称で、1、組定差で建度問題を表す数値はどもらの単位で表しても同じである。
 (f)放射性核種の放射能(activity referred to a radionuclide)は、しばしば誤った用語で"radioactivity"と記される。
 (g)単位シーベルト(PV,2002,70,205)についてはCIPM勧告2(CI-2002)を参照。

表4.単位の中に固有の名称と記号を含むSI組立単位の例

	SI 組立単位			
組立量	名称	記号	SI 基本単位による 表し方	
粘度	パスカル秒	Pa s	m ⁻¹ kg s ⁻¹	
カのモーメント	ニュートンメートル	N m	m ² kg s ⁻²	
表 面 張 九	コニュートン毎メートル	N/m	kg s ⁻²	
角 速 度	ラジアン毎秒	rad/s	m m ⁻¹ s ⁻¹ =s ⁻¹	
角 加 速 度	ラジアン毎秒毎秒	rad/s^2	$m m^{-1} s^{-2} = s^{-2}$	
熱流密度,放射照度	ワット毎平方メートル	W/m^2	kg s ⁻³	
熱容量、エントロピー	ジュール毎ケルビン	J/K	$m^2 kg s^2 K^1$	
比熱容量, 比エントロピー	ジュール毎キログラム毎ケルビン	J/(kg K)	$m^2 s^{-2} K^{-1}$	
比エネルギー	ジュール毎キログラム	J/kg	$m^2 s^{-2}$	
熱 伝 導 率	ワット毎メートル毎ケルビン	W/(m K)	m kg s ⁻³ K ⁻¹	
体積エネルギー	ジュール毎立方メートル	J/m ³	$m^{-1} kg s^{-2}$	
電界の強さ	ボルト毎メートル	V/m	m kg s ⁻³ A ⁻¹	
電 荷 密 度	クーロン毎立方メートル	C/m ³	m ⁻³ s A	
表 面 電 荷	「クーロン毎平方メートル	C/m ²	m ² s A	
電 束 密 度 , 電 気 変 位	クーロン毎平方メートル	C/m ²	$m^2 s A$	
誘 電 卒	コァラド毎メートル	F/m	$m^{-3} kg^{-1} s^4 A^2$	
透 磁 率	ペンリー毎メートル	H/m	m kg s ⁻² A ⁻²	
モルエネルギー	ジュール毎モル	J/mol	$m^2 kg s^2 mol^1$	
モルエントロピー, モル熱容量	ジュール毎モル毎ケルビン	J/(mol K)	$m^2 kg s^{-2} K^{-1} mol^{-1}$	
照射線量(X線及びγ線)	クーロン毎キログラム	C/kg	kg ⁻¹ s A	
吸収線量率	グレイ毎秒	Gy/s	$m^{2} s^{-3}$	
放 射 強 度	ワット毎ステラジアン	W/sr	$m^4 m^{-2} kg s^{-3} = m^2 kg s^{-3}$	
放射輝度	ワット毎平方メートル毎ステラジアン	$W/(m^2 sr)$	m ² m ⁻² kg s ⁻³ =kg s ⁻³	
酵素活性濃度	カタール毎立方メートル	kat/m ³	$m^{-3} s^{-1} mol$	

表 5. SI 接頭語						
乗数	名称	名称 記号 乗数		名称	記号	
10^{24}	э 9	Y	10 ⁻¹	デシ	d	
10^{21}	ゼタ	Z	10 ⁻²	センチ	с	
10^{18}	エクサ	Е	10-3	ミリ	m	
10^{15}	ペタ	Р	10^{-6}	マイクロ	μ	
10^{12}	テラ	Т	10 ⁻⁹	ナノ	n	
10^{9}	ギガ	G	10^{-12}	ピコ	р	
10^{6}	メガ	М	10^{-15}	フェムト	f	
10^{3}	+ 1	k	10^{-18}	アト	а	
10^{2}	ヘクト	h	10^{-21}	ゼプト	z	
10^{1}	デカ	da	10^{-24}	ヨクト	v	

表6.SIに属さないが、SIと併用される単位				
名称	記号	SI 単位による値		
分	min	1 min=60 s		
時	h	1 h =60 min=3600 s		
日	d	1 d=24 h=86 400 s		
度	•	1°=(π/180) rad		
分	,	1'=(1/60)°=(π/10 800) rad		
秒	"	1"=(1/60)'=(π/648 000) rad		
ヘクタール	ha	1 ha=1 hm ² =10 ⁴ m ²		
リットル	L, 1	1 L=1 l=1 dm ³ =10 ³ cm ³ =10 ⁻³ m ³		
トン	t	$1 t=10^3 kg$		

表7. SIに属さないが、SIと併用される単位で、SI単位で

名称 記		SI 単位で表される数値	
電子ボルト	eV	1 eV=1.602 176 53(14)×10 ⁻¹⁹ J	
ダルトン	Da	1 Da=1.660 538 86(28)×10 ^{·27} kg	
統一原子質量単位	u	1 u=1 Da	
天 文 単 位	ua	1 ua=1.495 978 706 91(6)×10 ¹¹ m	

表8. SIに属さないが、SIと併用されるその他の単位

名称	記号	SI 単位で表される数値
バール	bar	1 bar=0.1MPa=100 kPa=10 ⁵ Pa
水銀柱ミリメートル	mmHg	1 mmHg≈133.322Pa
オングストローム	Å	1 Å=0.1nm=100pm=10 ⁻¹⁰ m
海 里	М	1 M=1852m
バーン	b	$1 \text{ b}=100 \text{ fm}^2=(10^{\cdot 12} \text{ cm})^2=10^{\cdot 28} \text{m}^2$
ノット	kn	1 kn=(1852/3600)m/s
ネーパ	Np	の単位しの教徒的な問題は
ベル	В	31単位との数値的な関係は、 対数量の定義に依存。
デシベル	dB -	

表9. 固有の名称をもつCGS組立単位

名称	記号	SI 単位で表される数値		
エルグ	erg	1 erg=10 ⁻⁷ J		
ダイン	dyn	1 dyn=10 ⁻⁵ N		
ポアズ	Р	1 P=1 dyn s cm ⁻² =0.1Pa s		
ストークス	St	$1 \text{ St} = 1 \text{ cm}^2 \text{ s}^{-1} = 10^{-4} \text{ m}^2 \text{ s}^{-1}$		
スチルブ	$^{\mathrm{sb}}$	$1 \text{ sb} = 1 \text{ cd cm}^{-2} = 10^4 \text{ cd m}^{-2}$		
フォト	ph	1 ph=1cd sr cm ⁻² =10 ⁴ lx		
ガ ル	Gal	1 Gal =1cm s ⁻² =10 ⁻² ms ⁻²		
マクスウエル	Mx	$1 \text{ Mx} = 1 \text{ G cm}^2 = 10^{-8} \text{Wb}$		
ガウス	G	$1 \text{ G} = 1 \text{Mx cm}^{-2} = 10^{-4} \text{T}$		
エルステッド ^(a)	Oe	1 Oe ≙ (10 ³ /4 π)A m ⁻¹		
(a) 3元系のCGS単位系とSIでは直接比較できないため、等号「 ▲ 」				

は対応関係を示すものである。

表10. SIに属さないその他の単位の例						
名称 記号		記号	SI 単位で表される数値			
キ	ユ		IJ	-	Ci	1 Ci=3.7×10 ¹⁰ Bq
$\scriptstyle u$	\sim	ŀ	ゲ	\sim	R	$1 \text{ R} = 2.58 \times 10^{-4} \text{C/kg}$
ラ				ĸ	rad	1 rad=1cGy=10 ⁻² Gy
$\scriptstyle u$				ム	rem	1 rem=1 cSv=10 ⁻² Sv
ガ		$\boldsymbol{\mathcal{V}}$		7	γ	$1 \gamma = 1 \text{ nT} = 10^{-9} \text{T}$
フ	T.		N	Ξ		1フェルミ=1 fm=10 ⁻¹⁵ m
メー	ートル	/系	カラゞ	ット		1 メートル系カラット= 0.2 g = 2×10 ⁻⁴ kg
ŀ				N	Torr	1 Torr = (101 325/760) Pa
標	準	大	気	圧	atm	1 atm = 101 325 Pa
力			IJ	-	cal	1 cal=4.1858J(「15℃」カロリー), 4.1868J (「IT」カロリー), 4.184J(「熱化学」カロリー)
3	ク			~	ц	$1 \mu = 1 \mu m = 10^{-6} m$