

JAERI-M

8 2 8 7

ROSA - II試験データの公開テープ  
処理について

(公開テープの利用マニュアル)

1979年6月

鈴木 光弘・大崎 秀機・関口 修一\*

この報告書は、日本原子力研究所が JAERI-M レポートとして、不定期に刊行している研究報告書です。入手、複製などのお問い合わせは、日本原子力研究所技術情報部（茨城県那珂郡東海村）あて、お申しこしてください。

JAERI-M reports, issued irregularly, describe the results of research works carried out in JAERI. Inquiries about the availability of reports and their reproduction should be addressed to Division of Technical Information, Japan Atomic Energy Research Institute, Tokai-mura, Naka-gun, Ibaraki-ken, Japan.

ROSA-II 試験データの公開テープ処理について  
(公開テープの利用マニュアル)

日本原子力研究所東海研究所安全工学部

鈴木光弘・大崎秀機・関口修一\*

(1979年5月25日受理)

加圧水型原子炉の想定冷却材喪失事故と、その時に機能すべき非常用炉心冷却系とを模擬した試験が、ROSA-II 試験装置を用いて行なわれた。その試験データは既にデータ報告書 (No. 1 ~ 13 および UHI 試験 2 冊) として刊行、公開されている。今回、ROSA-II 試験データの一般利用に供するために、原研の計算センターに試験データを収録した公開データテープを設け、同センターにおいて本報に示す手順で試験データの作図および数値リストを出力できるようにした。なお、同センター以外の計算機で処理する場合は、公開テープを複写し、計算プログラムをその計算機に合うように変換した上で行なう必要がある。また、試験データの正確な処理を行ない、かつ、公開テープの消去、損傷を防止するために、本報に示す利用マニュアルに依拠する必要がある。この公開テープは、計算センター所管のテープを著者の1人が借用して作成したものであり、一定期間の後にはテープの返還と消去を要するものである。その際には、安工一研究室所管の同種テープを利用することができる。

---

\*原子力エンジニアリング株式会社

Open Data Tapes of ROSA-II Tests:  
Users' Manual on the Tapes

Mitsuhiro SUZUKI, Hideki OSAKI and Shuichi SEKIGUCHI\*

Division of Reactor Safety  
Tokai Research Establishment, JAERI

(Received May 25, 1979)

Tests simulating a postulated loss-of-coolant accident and performance of ECCS in a PWR were carried out with the ROSA-II test facility. The test data were already published as data reports (No.1 ~ 13 and 2 for UHI tests).

For the purpose of general use of the ROSA-II test data, open data tapes recording the data are made available in the calculation center of JAERI. Following the procedures in the present manual, anyone who utilizes the calculation center can obtain the test data as figures and numerical tables. On the other hand, anyone who wishes to process the open data tapes with other computer system than that in the calculation center may apply to Reactor Safety Laboratory 1, JAERI, for reproduction of the tapes and can obtain the same after suitable conversion of the calculation program for that computer system.

The present manual should be followed in order to obtain the data properly and to avoid elimination and damage of the open tapes. By arrangements with the calculation center, test data on the open tapes will be eliminated in future; when, however, the same data tapes in Reactor Safety Laboratory 1 will be made available for general use.

Keywords: PWR, LOCA, ECCS, Simulation Tests, ROSA-II Facility, Users' Manual, Open Data Tapes, Data Processing, Plotter, Digital Tables

---

\*) Nuclear Engineering

## 目 次

1. はじめに .....	1
2. 収録試験データと公開テープ .....	1
3. データ出力の方法 .....	2
3.1 公開テープ利用の手続 .....	2
3.2 データ出力用制御文とインプットデータ .....	3
3.3 原研以外の計算機を使用する場合 .....	3
参考文献 .....	4

Contents

1. Introduction .....	1
2. Recorded experimental data and opened tapes .....	1
3. Procedure for output of data .....	2
3.1 A procedure of opened tapes for user .....	2
3.2 Control cards and input data for data editing .....	3
3.3 In the case of data process using another computer system .....	3
References .....	4

## List of Tables and Figures

Table 1	Test Parameters of ROSA-II .....	5
Table 2	Opened Tape Numbers and Abstracts of Runs Recorded in the Tapes .....	6
Table 3	Measurement List (For No.1 & No.2 Assembly) .....	8
Table 4	" (For No.3 Assembly) .....	9
Table 5	" (For No.3A Assembly) .....	10
Table 6	" (For No.4 Assembly) .....	12
Table 7	" (For No.40 Assembly) .....	14
Table 8	" (For No.5 Assembly) .....	16
Table 9	" (For UHI Assembly) .....	18
Table 10	Standard Set of Output for Test Data Using No.1 and No.2 Assembly .....	20
Table 11	Standard Set of Output for Test Data Using No.3 and No.4 Assembly .....	21
Table 12	Standard Set of Output for Test Data Using No.3A Assembly .....	22
Table 13	Standard Set for Output of Test Data Using No.40 Assembly .....	23
Table 14	Standard Set for Output of Test Data Using No.5 Assembly .....	24
Table 15	Standard Set for Output of Test Data Using UHI Assembly.	25
Table 16	Elimination Channel Number for Output in the Test Data of No.1 Assembly .....	26
Table 17	Elimination Channel Number for Output in the Test Data of No.2 Assembly .....	27
Table 18	Elimination Channel Number for Output in the Test Data of No.3 Assembly .....	27
Table 19	Elimination Channel Number for Output in the Test Data of No.3A Assembly .....	28
Table 20	Elimination Channel Number for Output in the Test Data of No.4 Assembly .....	29
Table 21	Elimination Channel Number for Output in the Test Data of No.40 Assembly .....	28
Table 22	Elimination Channel Number for Output in the Test Data of No.5 Assembly .....	30

Table 23	Elimination Channel Number for Output in the Test Data of UHI Assembly .....	31
Table 24	Input Data List for Data Processing (RSTEP-1) .....	32
Table 25	Input Manual for Data Processing of Opened Data Tapes (RSTEP-3, 3C) .....	34
Table 26	Control Cards for the Output of Plotter and Digital Tables .....	36
Table 27	Control Cards for the Output of COM and Digital Tables .....	37
Table 28	Sample Input Data for Run 419 (RSTEP-3, 3C) .....	38
Table 29	Program for the Duplication of Opened SLTAPE to NLTAPE .	39
Table 30	List of ROSA-II Test Runs .....	41
Table 31	Program List of RSTEP-3 .....	45
Fig. 1	Application Paper for the Use of Computer System of the Calculation Center of JAERI (System B) .....	55



## 1. はじめに

ROSA-II試験は、加圧水型原子炉（PWR）の設計基準事故として想定されている冷却材喪失事故（LOCA）とその時に作動すべき非常用炉心冷却系（ECCS）の性能を模擬したシステム総合実験であり、冷却材の流出過程における一次系内の冷却材挙動や炉心の冷却状態、およびECCS水の炉心冷却に寄与する効果を調べることを目的として、1974年2月から実験を開始し、1977年7月までにミスランを除き60回の実験を行なった。これらの実験は、Table 1に示すような7つの実験パラメータのうちから選んだいくつかのパラメータの効果を調べるために、合計15冊のデータ報告書の中にまとめて収録されている。ROSA-II試験の研究計画<sup>(1)</sup>や試験装置の概要<sup>(2)</sup>、および上記15冊のデータ報告書<sup>(3)~(17)</sup>はそれぞれ刊行・公開されており、それらの試験結果の要点については原子力学会誌上の論文<sup>(18)~(21)</sup>や口頭発表で公表されている。

ROSA-II試験では、炉心等一次系内の流量や流体密度が得られていないという弱点はあるが、LOCA/ECCSの全過程を対象とした圧力、差圧、流体及び金属面温度、流出及び注入流量等が測定されており、冷却材挙動を理解する上で重要な物理量が得られているといえる。特に、世界的にもPWRのLOCA現象についてシステム効果を考慮した模擬総合実験は数少なく、国内においてはこのROSA-II試験のみであり、ブローダウン過程から再冠水過程まで一貫した物理現象を対象としてLOCA解析コードを評価する上で有用な実験データを有していることを考え、今回、ROSA-II試験結果を利用しやすくするために公開データテープを作成した。本報は、原研の計算センターに保管されている上記ROSA-II公開データテープを使用し、データの数値リストと作図を得る上で必要な計算プログラムと制御文、入力データ、および各試験Runの特徴等をまとめたものである。また、原研の計算センター以外の計算機でデータ処理をする場合の手続き等についても示した。

## 2. 収録試験データと公開テープ

ROSA-II試験では、主として前述の実験パラメータの効果をみるために、いくつかのRun毎にまとめてデータ報告書<sup>(3)~(17)</sup>を作成した。今回の公開テープも、これらの報告書と同じ収録Runを有する（UHI試験のみは10Run分を試験順序で分けて2分割とした）テープを作成した。各テープに収録されているRunの試験パラメータと公開テープ番号をTable 2に示す。なお、各Runの試験条件や現象上の解釈等については、それぞれを収録しているデータ報告書を参照されたい。

各Runで計測したデータは、Table 3~9に示すように模擬燃料棒集合体（1~5次炉心、UHI用炉心、および3次と4次の改造炉心の計8種類）毎に共通しており、それらの集合体毎の標準的なデータチャンネルの出力組合せをTable 10~15に示す。但し、計測機器のトラブル等により明らかにデータ不良と判断されたものと、計測していないデータについては出力させることができないが、各Run毎のそれらのデータチャンネル番号をTable 16~23にまとめて示

## 1. はじめに

ROSA-II試験は、加圧水型原子炉（PWR）の設計基準事故として想定されている冷却材喪失事故（LOCA）とその時に作動すべき非常用炉心冷却系（ECCS）の性能を模擬したシステム総合実験であり、冷却材の流出過程における一次系内の冷却材挙動や炉心の冷却状態、およびECCS水の炉心冷却に寄与する効果を調べることを目的として、1974年2月から実験を開始し、1977年7月までにミスランを除き60回の実験を行なった。これらの実験は、Table 1に示すような7つの実験パラメータのうちから選んだいくつかのパラメータの効果を調べるために、合計15冊のデータ報告書の中にまとめて収録されている。ROSA-II試験の研究計画<sup>(1)</sup>や試験装置の概要<sup>(2)</sup>、および上記15冊のデータ報告書<sup>(3)~(17)</sup>はそれぞれ刊行・公開されており、それらの試験結果の要点については原子力学会誌上の論文<sup>(18)~(21)</sup>や口頭発表で公表されている。

ROSA-II試験では、炉心等一次系内の流量や流体密度が得られていないという弱点はあるが、LOCA/ECCSの全過程を対象とした圧力、差圧、流体及び金属面温度、流出及び注入流量等が測定されており、冷却材挙動を理解する上で重要な物理量が得られているといえることができる。特に、世界的にもPWRのLOCA現象についてシステム効果を考慮した模擬総合実験は数少なく、国内においてはこのROSA-II試験のみであり、ブローダウン過程から再冠水過程まで一貫した物理現象を対象としてLOCA解析コードを評価する上で有用な実験データを有していることを考え、今回、ROSA-II試験結果を利用しやすくするために公開データテープを作成した。本報は、原研の計算センターに保管されている上記ROSA-II公開データテープを使用し、データの数値リストと作図を得る上で必要な計算プログラムと制御文、入力データ、および各試験Runの特徴等をまとめたものである。また、原研の計算センター以外の計算機でデータ処理をする場合の手続き等についても示した。

## 2. 収録試験データと公開テープ

ROSA-II試験では、主として前述の実験パラメータの効果をみるために、いくつかのRun毎にまとめてデータ報告書<sup>(3)~(17)</sup>を作成した。今回の公開テープも、これらの報告書と同じ収録Runを有する（UHI試験のみは10Run分を試験順序で分けて2分割とした）テープを作成した。各テープに収録されているRunの試験パラメータと公開テープ番号をTable 2に示す。なお、各Runの試験条件や現象上の解釈等については、それぞれを収録しているデータ報告書を参照されたい。

各Runで計測したデータは、Table 3~9に示すように模擬燃料棒集合体（1~5次炉心、UHI用炉心、および3次と4次の改造炉心の計8種類）毎に共通しており、それらの集合体毎の標準的なデータチャンネルの出力組合せをTable 10~15に示す。但し、計測機器のトラブル等により明らかにデータ不良と判断されたものと、計測していないデータについては出力させることができないが、各Run毎のそれらのデータチャンネル番号をTable 16~23にまとめて示

した。従って、各Run毎に出力可能なのは、そのRunの標準的な出力組合せの中から、不良データのチャンネル番号を除外したものに限る必要がある。

次に、本報でいう公開テープは、実験時にデータ収録装置（DATAC 2000B）により収録した生データの磁気テープ（物理量に変換する前の段階）に対して、次の3段階の処理を行なったものである。

- (1) ステップ1 生データテープには、各データチャンネル毎に毎秒50 或いは100 点のデータが電圧の形で収録されている。この生データテープに対して、破断時刻を見い出し、データのサンプリングを行なう。サンプリングは、出力させる最大時間中に1000 点のデータが入るように適当な間隔が選ばれる。各Run 毎のサンプリング間隔等、このステップ1（RSTEP-1）に用いた入力データをTable 24 に示す。
- (2) ステップ2 ステップ1で破断時刻の確認とサンプリングしたファイル（ディスク）に対して、収録データを電圧量から物理量に変換し、タイトル、座標軸を指定して図面に出力させ、或いは数値リストの形で出力させる。物理量に変換する際に、明らかにゲインと零点のずれているデータについては正しい値に修正をする。データの中には、生データの物理量への変換で得られるものだけでなく、更にそれから二次変換（処理）して得られる計算チャンネルも入っている。この計算チャンネルには次の3つがある。
  - ・燃料棒表面における発熱量に対応した熱流束。
  - ・被覆管内外両面で測定した独立な温度相互の差。
  - ・独自のサブルーチンによる流出流量と流出クオリティの算出。
 なお、ステップ2では、上記の処理を行なったデータを編集テープ（NLTAPE）に収録している。（編集テープ、安工-研究室保管）。
- (3) ステップ3 ステップ2で作成した編集テープと同じものを計算センター保管の磁気テープ（SLTAPE）にコピーし、ユーザーが利用できる（公開テープの作成）状態になっている。この公開テープに収録されている各データの点数は最大1000 点と決っており、各Run においてデータのサンプリング間隔を変えることはこの段階ではできない。ユーザーの選べるオプションは、後に示すように、X軸（時間）最大値、Y軸（物理量）の最大値と最小値、および1つの図面に同時に描かせることのできるデータチャンネルの組合せ（最大7チャンネルまで可能）である。

### 3. データ出力の方法

#### 3.1 公開テープ利用の手続

ROSA-II 試験データの公開テープは原研の計算センターに保管されており、これを計算センターから持ち出すことはできない。従って公開テープの利用者は、計算センターの利用者（電子計算機組織の利用管理票を持っている人）に限られる。計算センター以外の計算機を用いて試験データを入手したい人は3.3 に示すように安全工学第一研究室まで別途申し込まれたい。

した。従って、各Run毎に出力可能なのは、そのRunの標準的な出力組合せの中から、不良データのチャンネル番号を除外したものに限る必要がある。

次に、本報でいう公開テープは、実験時にデータ収録装置（DATAC 2000B）により収録した生データの磁気テープ（物理量に変換する前の段階）に対して、次の3段階の処理を行なったものである。

- (1) ステップ1 生データテープには、各データチャンネル毎に毎秒50 或いは100 点のデータが電圧の形で収録されている。この生データテープに対して、破断時刻を見い出し、データのサンプリングを行なう。サンプリングは、出力させる最大時間中に1000 点のデータが入るように適当な間隔が選ばれる。各Run 毎のサンプリング間隔等、このステップ1（RSTEP-1）に用いた入力データをTable 24 に示す。
- (2) ステップ2 ステップ1で破断時刻の確認とサンプリングしたファイル（ディスク）に対して、収録データを電圧量から物理量に変換し、タイトル、座標軸を指定して図面に出力させ、或いは数値リストの形で出力させる。物理量に変換する際に、明らかにゲインと零点のずれているデータについては正しい値に修正をする。データの中には、生データの物理量への変換で得られるものだけでなく、更にそれから二次変換（処理）して得られる計算チャンネルも入っている。この計算チャンネルには次の3つがある。
  - ・燃料棒表面における発熱量に対応した熱流束。
  - ・被覆管内外両面で測定した独立な温度相互の差。
  - ・独自のサブルーチンによる流出流量と流出クオリティの算出。
 なお、ステップ2では、上記の処理を行なったデータを編集テープ（NLTAPE）に収録している。（編集テープ、安工-研究室保管）。
- (3) ステップ3 ステップ2で作成した編集テープと同じものを計算センター保管の磁気テープ（SLTAPE）にコピーし、ユーザーが利用できる（公開テープの作成）状態になっている。この公開テープに収録されている各データの点数は最大1000 点と決っており、各Run においてデータのサンプリング間隔を変えることはこの段階ではできない。ユーザーの選べるオプションは、後に示すように、X軸（時間）最大値、Y軸（物理量）の最大値と最小値、および1つの図面に同時に描かせることのできるデータチャンネルの組合せ（最大7チャンネルまで可能）である。

### 3. データ出力の方法

#### 3.1 公開テープ利用の手続

ROSA-II 試験データの公開テープは原研の計算センターに保管されており、これを計算センターから持ち出すことはできない。従って公開テープの利用者は、計算センターの利用者（電子計算機組織の利用管理票を持っている人）に限られる。計算センター以外の計算機を用いて試験データを入手したい人は3.3 に示すように安全工学第一研究室まで別途申し込まれたい。

さて、上記公開テープからデータを出力させる場合、利用者は計算センターの受付（システム B = クローズシステム）において、計算申込用紙（Fig. 1 参照）に必要な試験 Run の入っている公開テープのボリューム通番を記入し、出力制御文と出力用インプットを含めたカードとともに計算依頼する。この際、同一テープに収録されている異なる試験 Run のデータを同時に出力させることはできないので注意を要する。申込用紙に記入したテープのボリューム通番と制御文中のテープ番号とは一致しなければならない。また、公開テープを消去、或いはテープに書き込ませる指定（申込用紙の指定箇所、入力制御文中のテープ指定箇所）をしてはならない。計算結果のリストやプロッター・コムの結果は計算センターの同じ受付で受けとる。

### 3.2 データ出力用制御文とインプットデータ

利用者が公開テープから図面或いは数値表を出力させる場合のマニュアルを Table 25 に、制御文を Table 26, 27 に、そしてインプットデータのサンプルを Table 28 に示す。図面を出力させる場合、制御文はプロッター用とコム用とで若干異なることに注意を要する。利用者がこのインプット段階で選ぶことのできるオプションは、図面作成上の X 軸、Y 軸のスケールの大きさ（特に指定しなければ、既に処理されている X 軸、Y 軸の値が使用される）と、出力させるデータの種類および同一図面に描かせることのできるデータの組合せ方である。X 軸（時間軸）と Y 軸の設定は任意にできるが、収録されているデータ点数は 1 つの Run 毎に最大時間で 1000 点 / データ（全 Run については 1 ~ 8 点 / 秒、データ）であるため、データを拡大してみても単位時間当りのデータ点数は変化しないことに留意する必要がある。より詳細なデータを必要とする場合はこの公開テープではなく、試験結果をそのまま収録している生データテープ（安工一研究室所管）を利用する必要がある。この場合は直接安工一研究室に相談されたい。出力させるデータとそのチャンネル番号の対応は、その Run の計測一覧表（Table 3 ~ 9）を参照し、出力させるデータについては各 Run 毎の標準組合せ（Table 10 ~ 15）の中から出力できないデータのチャンネル番号（Table 16 ~ 23）を除いた上で行う必要がある。

### 3.3 原研以外の計算機を使用する場合

本報でいう公開データテープ（SLTAPE）は原研の計算センターに保管されている磁気テープであり、これをセンター外に持出すことはできない。また、データ処理用のプログラムは同センターの計算機（FACOM-230-75）用に作られたものである。従って同センター以外の場所でデータ処理を行なう場合は、公開テープの複写（Table 29 に複写用のプログラムを示す）をとり、使用する計算機システムにデータ処理プログラムが適合するかどうかをチェックした上で処理する必要がある。

これらのデータ処理を行ないたい人は安全工学第一研究室に申し込みをした上で、公開テープの複写を行なって頂きたい。なお、参考のために、ROSA-II 全 Run の試験条件一覧を Table 30 に、公開データテープの処理用プログラム（RSTEP-3）リストを Table 31 に示す。

## 参 考 文 献

- (1) 斯波正誼, 安達公道, 生田目健, 他 ; “ ROSA-II研究計画 ” JAERI -M6362 (1976)
- (2) 斯波正誼, 安達公道, 松本巖, 他 ; “ ROSA-II試験装置の概要 ” JAERI -M 6247 (1975)
- (3) 安全工学第一研究室, ROSAグループ ; “ ROSA-II試験データ報告・1 (Run 202, 203, 303, 304, 306) ” JAERI -M 6240 (1975)
- (4) “ 同報告・2 (Run 307, 308, 309) ” JAERI -M 6241 (1975)
- (5) “ 同報告・3 (Run 204, 301, 302) ” JAERI -M 6512 (1976)
- (6) “ 同報告・4 (Run 401, 403, 404) ” JAERI -M 6513 (1976)
- (7) “ 同報告・5 (Run 310, 311, 312, 313, 317) ” JAERI -M 6709 (1976)
- (8) “ 同報告・6 (Run 411, 314, 315, 316) ” JAERI -M 6849 (1976)
- (9) “ 同報告・7 (Run 320, 321, 322, 323) ” JAERI -M 7106 (1977)
- (10) “ 同報告・8 (Run 324, 325, 326) ” JAERI -M 7236 (1977)
- (11) “ 同報告・9 (Run 418, 419, 420, 423) ” JAERI -M 7239 (1977)
- (12) “ 同報告・10 (Run 415, 417, 421, 422) ” JAERI -M 7437 (1977)
- (13) “ 同報告・11 (Run 327, 328, 329, 330) ” JAERI -M 7505 (1978)
- (14) “ 同報告・12 (Run 332, 413, 425) ” JAERI -M 7944 (1978)
- (15) “ 同報告・13 (Run 502, 505, 506, 507) ” JAERI -M 7737 (1978)
- (16) 安全工学第一研究室, ROSAグループ ; “ ROSA-IIによる上部ヘッド注入系 (UHI) 挙動に関する試験研究 ” JAERI -M 6707 (1976)
- (17) “ 同報告 (続報) ” JAERI -M 7656 (1978)
- (18) 斯波正誼, 安達公道, 生田目健, 他 ; “ ROSA-IIによるPWRの冷却材喪失事故模擬試験(I) ” 日本原子力学会誌 18, No. 4 (1976)
- (19) 斯波正誼, 安達公道, 岡崎元昭, 他 ; “ ROSA-IIによるPWRの冷却材喪失事故模擬試験(II) ” 日本原子力学会誌 19, No. 6 (1977)
- (20) 安達公道, 傍島真, 岡崎元昭, 他 ; “ ROSA-IIによるPWRの冷却材喪失事故模擬試験(III) ” 日本原子力学会誌, 20, No. 3, (1978)
- (21) 安達公道, 鈴木光弘, 傍島真, 他 ; “ ROSA-IIによるPWRの冷却材喪失事故模擬試験(IV) ” 日本原子力学会誌, 20, No. 5 (1978)

Table 1 Test Parameters of ROSA-II

- (1) Break Conditions
  - Break Type; Double-ended, Single-ended, Split Break
  - Break Location; Hot Leg, Cold Leg, Pump Suction
  - Break Diameter; 37.5, 30.5, 25.0, 20.5, 16.5  
(up to 240% Break of Commercial PWR)
- (2) Initial Fluid Conditions
  - Primary System Pressure,
  - Fluid Temperature Distribution
- (3) Pump Speed and Primary Coolant Flow Rate
- (4) Flow Resistance in Primary Loop
- (5) Core Heating Conditions
  - Power Distribution; Uniform, Axial and Radial Distribution
  - Transient Power Supply; Numerical Control  
(Decay Heat, Delayed Neutron Effect, Stored Heat)
- (6) Secondary System Conditions
  - System Pressure (Saturation), Blow-out or Closed
- (7) ECCS Injection Conditions (ACC, HPCI, LPCI, UHI)
  - Injection Location, Combination, Water Temperature, Flow Rate

Table 2 Open Tape Numbers and Abstracts of Run Recorded in the Tapes.

Data Rep. Number	Ref. Report (JAERI-M)	Open Tape Vol. No	Recorded Run Number	Abstracts of Test Parameters
1	6240	0001RD Vol.=011876	202, 304 203, 306 303	いずれも低温側配管における30.5φ両端破断の実験であり、蒸気発生器2次系放出の有無、およびECCS水を注入しない場合と、2ループのうちの一方にECCSを注入した場合の効果調べた。
2	6241	0002RD Vol.=011875	307 308 309	いずれも低温側配管における37.5φ最大口径両端破断の実験であり、2種類のECCS (ACCとLPCI)それぞれの個別注入効果、および両者の組合せ注入が、炉心冷却等に及ぼす効果を調べた。
3	6512	0003RD Vol.=021874	204 301 302	いずれも、低温側配管における30.5φ片側破断の実験であり、PVに近い方の破断口或いはポンプ側の破断口から放出させた場合で注入したECCSが必ず炉心を通過する際の効果、およびECCS注入なしの場合を調べた。
4	6513	0004RD Vol.=021863	401 403 404	低温側配管における30.5φおよび37.5φの両端破断の実験であり、破断口面積を上記2種類変えた効果、ECCS水注入の有無の効果、更に炉心上下温度差を3℃、9℃に変えた場合の効果調べた。
5	6709	0005RD Vol.=021862	310, 313 311, 317 312	低温側配管における大口径破断の実験 (1 Runのみ面積配分破断、他の4 Runは37.5φ最大口径両端破断) である。ECCS注入場所を実験条件に変えた効果や、LPCIのみの注入効果を調べた。また、面積配分破断や炉心断面内発熱分布の効果調べた。
6	6849	0006RD Vol.=011836	411, 316 314 315	低温側配管における大口径破断の実験 (1 Runのみ破断ループポンプの影響を調べるために下流側破断口径を小さくしたが、他の3 Runは37.5φ両端破断) である。ECCSの注入場所を変えた効果 (両ループやPV内注入) を調べた。
7	7106	0007RD Vol.=011766	318, 322 320, 323 321	低温側配管における片側破断と面積配分両端破断の実験である。予備解析で指摘された、炉心流れの停滞するような破断条件の効果調べた。また、破断初期にポンプが回転しつづけた場合の炉心流れ等に及ぼす効果を調べた。
8	7236	0008RD Vol.=011971	324 325 326	いずれも低温側配管における37.5φ最大口径両端破断である。ダウンカマールにおけるECCS水バイパス現象に及ぼすダウンカマール間隙の効果、破断ループポンプ改造の効果、およびECCS注入流量を変えた効果を調べた。各Runとも、炉心が細く低出力の実験である。



Table 2 (Cont'd)

Data Rep. Number	Ref. Report (JAERI-M)	Open Tape Vol. No.	Recorded Run Number	Abstracts of Test Parameters
9	7239	0009RD Vol.=031967	418, 423 419 420	いずれも高温側配管における3.75φ最大口径両端破断である。ECCSを注入した場合、注入場所を実炉条件に変えた効果を調べた。また、破断初期における循環ポンプを回転させつづけた効果を調べた。
10	7437	0010RD Vol.=031960	415, 422 417 421	低温側および高温側配管における小口径(24%相当)スプリット破断の実験である。蒸気発生器2次系放出の有無、およびECCSの1つ、HPCI注入の効果を調べた。
11	7505	0011RD Vol.=011937	327, 330 328 329	高温側配管における大口径面積配分両端破断の実験である。(破断口径は3.75φ/2.50φ)。予備解析で指摘された、炉心流れが停滞するような破断条件の効果を調べた。また、破断初期のポンプ回転の効果も調べた。
12	7944	0012RD Vol.=011922	332 413 425	いずれも低温側配管における3.75φ最大口径両端破断の実験である。ECCS注入の有無、破断初期におけるポンプ回転の効果、および初期炉心温度差を実炉並みに大きくした場合の効果も調べた。
13	7737	0013RD Vol.=011921	502, 507 505 506	いずれも低温側配管における3.75φ最大口径両端破断の実験である。これまでの実験結果をふまえて、ECCS注入方式(改良型、実炉型)の効果を調べた。破断ループ高温側配管に設置されていた抵抗体(ベンチュリー流量計)をはずした効果も調べた。
UHI	6707 7656	0014RD Vol.=011919	601, 604 602, 605 603	いずれも低温側配管における3.75φ最大口径両端破断の実験である。従来方式のECCSに加えて、上部ヘッド注入系(UHI)を設けた効果、燃料棒蓄積熱放出や零出力等発熱条件の効果を調べた。UHI用に燃料集合体とPV内構造物が改造された。
UHI	6707 7656	0015RD Vol.=011918	606, 609 607, 610 608	低温側配管破断実験であり、I Runのみ小口径スプリット破断、他は3.75φ最大口径両端破断である。上部ヘッド注入系(UHI)用に改造した装置において、UHI作動時刻、注入水温、実験Runの再現性の効果を調べた。また小口径破断の効果も調べた。

Table 3 Measurement List (For No.1 & No.2 Assembly)

DATA CH. NO.	MEAS. ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR	SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY		
1	PRESSURE	P-1	PV UPPER PLENUM	SEMI CONDUCTIVE PRESSURE TRANSDUCER	PMS-10KTM-200H	0-165 Kg/cm <sup>2</sup> 0-±5V	± 2.4 %		
2		P-2	PV LOWER PLENUM		"	"	"	"	
3		P-3	ABOVE NO.1 ORIFICE		"	"	"	"	
4		P-4	BELOW NO.1 ORIFICE		"	"	"	"	
5		P-5	ABOVE NO.2 ORIFICE		"	"	"	"	
6		P-6	BELOW NO.2 ORIFICE		"	"	"	"	
7		P-7	SG 1 INLET		"	"	"	"	
8		P-8	P 1 PUMP SUCTION		"	"	"	"	
9		P-9	SG 2 INLET		"	"	"	"	
10		P-10	SG 2 OUTLET		"	"	"	"	
11		P-11	P 2 PUMP DELIVERY		"	"	"	"	
12		P-12	PRESSURIZER		"	"	"	"	
13		P-13	SG SHELL SIDE		"	"	"	"	
14	DIFF. PRESS.	D-1	PV TOP-BOTTOM	HIGH DIFF-PRESSURE TRANSDUCER	PMS-10KTM-100H	0-60 Kg/cm <sup>2</sup> 0-±5V	± 1.0 %		
15		D-2	PV TOP-BOTTOM		ECH	0-0.6Kg/cm <sup>2</sup> 2-10V	"	"	
16		D-3	PV TOP-NO.1 ORIFICE		EIDM-SP	0-10 Kg/cm <sup>2</sup>	"	"	
17		D-4	PV BOTTOM-NO.2 ORIFICE		"	"	"	"	
18		D-5	SG 1 INLET-OUTLET		"	"	"	"	
19		D-6	SG 2 INLET-OUTLET		"	"	"	"	
20		D-7	P 1 PUMP DELIVERY-SUCTION		"	"	"	"	
21		D-8	P 2 PUMP DELIVERY-SUCTION		"	"	"	"	
22	FLOW RATE	F-1	CONDENSATE NO.1	ELECTROMAGNETIC FLOW RATE METER 6159		0-250 kg/sec.	± 1.4 %		
23		F-2	CONDENSATE NO.2						
24		F-3	COOLING WATER NO.1						
25		F-4	COOLING WATER NO.2						
26		F-5	HPCI (1)		TURBINE FLOW RATE METER		0-20 l/min 0-10V	± 1.2 %	
27		F-6	" (2)						
28		F-7	" (3)						
29		F-8	" (4)						
30		F-9	ACC 1					0-50 l/min	
31		F-10	ACC 2 (1)					0-300 l/min	
32	F-11	ACC 2 (2)				0-1000 l/min			
33	F-12	LPCI (1)				0-110 l/min			
34	F-13	" (2)				0-300 l/min			
35	POWER	W-1	HIGH FLUX RODS	POWER TRANSDUCER 2885			0-600KVA 0-10V	± 1.0 %	
36		W-2	LOW FLUX RODS				0-1800KVA		
37	TEMP(FUEL)	TF-1	NO.1 POSITION 1	THERMOCOUPLE CA UNGROUND		0-800°C 0-10V	± 1.4 %		
38		TF-2	" 2						
39		TF-3	" 3						
40		TF-4	" 4						
41		TF-5	" 5						
42		TF-6	NO.2 POSITION 1						
43		TF-7	" 2						
44		TF-8	" 3						
45		TF-9	" 4						
46		TF-10	" 5						
47		TF-11	NO.3 POSITION 1						
48		TF-12	" 2						
49		TF-13	" 3						
50		TF-14	" 4						
51		TF-15	" 5						
52		TF-16	NO.4 POSITION 1					0-400°C 0-10V	
53		TF-17	" 2						
54		TF-18	" 3						
55		TF-19	" 4						
56		TF-20	" 5						± 1.0 %
57	TEMP(SYSTEM)	T-1	PV UPPER PLENUM	TACHO GENERATOR		0-5000 r.p.m. 0-10V	± 1.0 %		
58		T-2	PV LOWER PLENUM						
59		T-3	CONDENSATE NO.1						
60		T-4	CONDENSATE NO.2						
61		T-5	SG 1 INLET						
62		T-6	SG 1 OUTLET						
63		T-7	P 1 PUMP DELIVERY						
64		T-8	PV INLET NOZZLE						
65		T-9	SG 2 INLET						
66		T-10	SG 2 OUTLET						
67		T-11	P 2 PUMP DELIVERY						
68		T-12	PRESSURIZER						
69		T-13	SG 1 SHELL OUTLET						
70		T-14	SG 2 SHELL OUTLET						
71	REVOLUTION	N-1	P 1 PUMP	COPPER WIRE VOLTAGE GENERATOR		RUPTURE 0-10V			
72		N-2	P 2 PUMP						
73	ON-OFF SIGNAL	S-1	RUPTURE DISC NO.1	LIMIT SW CONTACT, VOLTAGE GENERATOR		OPEN-CLOSE 0-10V			
74		S-2	RUPTURE DISC NO.2						
75		S-3	QSV VALVE					CLOSE HALF-OPEN, 0-10-5V	
76		S-4	RCN VALVE NO.1						
77		S-5	RCN VALVE NO.2						
78		S-6	ACC 1 VALVE						
79		S-7	ACC 2 VALVE						
80		S-8	SST DISCHARGE VALVE		ELECTROMAGNETIC CONTACT	VOLTAGE GENERATOR		CLOSE-OPEN 0-10V	
81		S-9	P 1 PUMP POWER SUPPLY						
82		S-10	P 2 PUMP POWER SUPPLY		LIMIT SW CONTACT	GENERATOR		OPEN-CLOSE (VALVE) ?	
83		S-11	HPCI VALVE						
84		S-12	LPCI VALVE		RELAY CONTACT				
85		S-13	P 1 PUMP REV. DIREC.						FORWARD REVERSE, 0-5V
86		S-14	P 2 PUMP REV. DIREC.						" "

Table 4 Measurement List (For No.3 Assembly)

Table 2-2 (cont'd) MEASUREMENT LIST 2-2

DATA NO.	MEASUREMENT SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY
1	PRESSURE	PV UPPER PLENUM	PMS-10KTM-200H	0~160 kg/cm <sup>2</sup> , 0~15V	± 2.4 %
2		PV LOWER PLENUM			
3		ABOVE NO.1 ORIFICE			
4		BELOW NO.1 ORIFICE			
5		ABOVE NO.2 ORIFICE			
6		BELOW NO.2 ORIFICE			
7		SG 1 INLET			
8		PI PUMP SUCTION			
9		SG 2 INLET			
10		SG 2 OUTLET			
11		P2 PUMP DELIVERY			
12		P2 PUMP DELIVERY			
13	DIFF PRESS	SG SHELL SIDE	PMS-10KTM-100H	0~60 kg/cm <sup>2</sup> , 0~15V	± 1.0 %
14		PV TOP-BOTTOM	EDH	0~0.6 kg/cm <sup>2</sup> , 2~10V	± 1.0 %
15		PV TOP-NO.1 ORIFICE *	ETIDM-5P	0~10 kg/cm <sup>2</sup>	
16		PV BOTTOM-NO.2 ORIFICE *			
17		SG 1 INLET-OUTLET			
18		SG 2 INLET-OUTLET			
19		SG 2 INLET-OUTLET			
20		P2 PUMP DELIVERY-SUCTION			
21		CONDENSATE NO.1			
22	FLOWRATE	CONDENSATE NO.2			
23		COOLING WATER NO.2			
24		COOLING WATER NO.2			
25		HFC1 (1)			
26		HFC1 (2)			
27		HFC1 (3)			
28		HFC1 (4)			
29		ACC 1			
30		ACC 2 (1)			
31		ACC 2 (2)			
32		LPC 1			
33		LPC 1 (1)			
34		LPC 1 (2)			
35	POWER	W-1 HIGH FLUX RODS	POWER TRANSDUCER 2885	0~600KVA, 0~10V	± 1.0 %
36		W-2 LOW FLUX RODS		0~1800KVA, 0~10V	
37	TEMP/FLUX	TF-1 HIGH FLUX NO.1 ROD		0~1200°C, 0~10V	± 1.4 %
38		TF-2			
39		TF-3			
40		TF-4			
41		TF-5			
42		TF-6			
43		TF-7			
44		TF-8			
45		TF-9			
46		TF-10			
47		TF-11			
48		TF-12			
49		TF-13			
50		TF-14			
51		TF-15			
52		LOW FLUX NO.12 ROD			
53		TF-17			
54		TF-18			
55		TF-19			
56		TF-20			
57		TF-21			
58		TF-22			
59		TF-23			
60		TF-24			
61		TF-25			
62		TF-26			
63		TF-27			
64		TF-28			
65		TF-30			

Note \* will be changed for hot leg break piping

Remark: Calculated data from original data are as follows.

Data Ch.No.	Title	Data Ch.No.	Title
110	No.1 Discharge Flow Rate	116	Temp.Difference (No.1 Rod, P.3)
111	Discharge Quality	117	" " " " ( " P.4)
112	No.2 Discharge Flow Rate	118	" " " " ( " P.5)
113	Discharge Quality	119	Surface Heat Flux, No.1 Power
114	Temp.Difference (No.1 Rod, P.1)	120	" " " " No.2 Power
115	" " " " ( " P.2)		

Table 5 Measurement List (For No.3A Assembly)

DATA CH. NO.	MEAS. ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY	
1	PRESSURE	P-1	PV. UPPER PLENUM	SEMI CONDUCTIVE PRESSUER TRANSDUCER	PMS-10KTM-200H	0~165 kg/cm <sup>2</sup> , 0~±5V	± 2.4 %
2	"	P-2	PV. LOWER PLENUM		"	" " "	"
3	"	P-3	ABOVE NO.1 ORIFICE		"	" " "	"
4	"	P-4	BELOW NO.1 ORIFICE		"	" " "	"
5	"	P-5	ABOVE NO.2 ORIFICE		"	" " "	"
6	"	P-6	BELOW NO.2 ORIFICE		"	" " "	"
7	"	P-7	SG 1 INLET		"	" " "	"
8	"	P-8	P1 PUMP SUCTION		"	" " "	"
9	"	P-9	SG 2 INLET		"	" " "	"
10	"	P-10	SG 2 OUTLET		"	" " "	"
11	"	P-11	P2 PUMP DELIVERY		"	" " "	"
12	"	P-12	PRESSURIZER		"	" " "	"
13	"	P-13	SG SHELL SIDE		PMS-10KTM-100H	0~60 kg/cm <sup>2</sup> , 0~±5V	"
14	DIFF. PRESS	D-1	PV. TOP - BOTTOM	HIGH DIFF-PRESSURE TRANSDUCER	EDH	0~0.6 kg/cm <sup>2</sup> , 2~10V	± 1.0 %
15	"	D-2	PV. TOP - BOTTOM		EIIDM - SP	0~10 kg/cm <sup>2</sup> , "	"
16	"	D-3	PV. TOP - NO.1 ORIFICE *		"	" " "	"
17	"	D-4	PV. BOTTOM - NO.2 ORIFICE *		"	" " "	"
18	"	D-5	SG 1 INLET - OUTLET		"	-5~+5 kg/cm <sup>2</sup> , "	"
19	"	D-6	SG 2 INLET - OUTLET		"	" " "	"
20	"	D-7	P1 PUMP DELIVERY - SUCTION		"	" " "	"
21	"	D-8	P2 PUMP DELIVERY - SUCTION		"	-3~+3 kg/cm <sup>2</sup> , "	"
22	FLOWRATE	F-1	CONDENSATE NO.1	ELECTROMAGNETIC FLOW. RATE METER 6159	"	0~250 kg/sec	± 1.4 %
23	"	F-2	CONDENSATE NO.2		"	"	"
24	"	F-3	COOLING WATER NO.1		"	"	"
25	"	F-4	COOLING WATER NO.2		"	"	"
26	"	F-5	HPCI (1)	TURBINE FLOW RATE METER	"	0~20 l/min, 0~10V	± 1.2 %
27	"	F-6	" (2)		"	"	"
28	"	F-7	" (3)		"	"	0~50 l/min, "
29	"	F-8	" (4)		"	"	"
30	"	F-9	ACC 1		"	"	0~300 l/min, "
31	"	F-10	ACC 2 (1)		"	"	0~1000 l/min, "
32	"	F-11	ACC 2 (2)		"	"	"
33	"	F-12	LPC 1 (1)	"	"	0~110 l/min, "	
34	"	F-13	" (2)	"	"	0~300 l/min, "	
35	POWER	W-1	HIGH FLUX RODS	POWER TRANSDUCER 2885	"	0~600KVA, 0~10V	± 1.0 %
36	"	W-2	LOW FLUX RODS		"	"	0~1800KVA, 0~10V
37	TEMP.(FUEL)	TF-1	HIGH FLUX NO.1 ROD	THERMOCOUPLE C/A UNGROUND	"	0~1200°C, 0~10V	± 1.4 %
38	"	TF-2	" " 2		"	" " "	"
39	"	TF-3	" " 3		"	" " "	"
40	"	TF-4	" " 4		"	" " "	"
41	"	TF-5	" " 5		"	" " "	"
42	"	TF-6	" NO.3 ROD 1		"	" " "	"
43	"	TF-7	" " 2		"	" " "	"
44	"	TF-8	" " 3		"	" " "	"
45	"	TF-9	" " 4		"	" " "	"
46	"	TF-10	" " 5		"	" " "	"
47	"	TF-11	" NO.9 ROD 1		"	" " "	"
48	"	TF-12	" " 2		"	" " "	"
49	"	TF-13	" " 3		"	" " "	"
50	"	TF-14	" " 4		"	" " "	"
51	"	TF-15	" " 5		"	" " "	"
52	"	TF-16	LOW FLUX NO.12 ROD 1		"	" " "	"
53	"	TF-17	" " 2		"	" " "	"
54	"	TF-18	" " 3		"	" " "	"
55	"	TF-19	" " 4		"	" " "	"
56	"	TF-20	" " 5		"	" " "	"
57	"	TF-21	" NO.41 ROD 1		"	" " "	"
58	"	TF-22	" " 2		"	" " "	"
59	"	TF-23	" " 3		"	" " "	"
60	"	TF-24	" " 4		"	" " "	"
61	"	TF-25	" " 5		"	" " "	"
62	"	TF-26	HIGH FLUX NO. 8 ROD 1		"	" " "	"
63	"	TF-27	" " 2		"	" " "	"
64	"	TF-28	" " 3		"	" " "	"
65	"	TF-29	" " 4		"	" " "	"
66	"	TF-30	" " 5		"	" " "	"

Table 5 (Cont'd)

DATA CH.NO	MEAS. ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY
67	TEMP.(FUEL)	TF-31	INNER SURFACE 1	THERMOCOUPLE CA UNGROUND	0~1200°C, 0~10V	± 1.4 %
68	"	TF-32	" 2	"	" " "	"
69	"	TF-33	" 3	"	" " "	"
70	"	TF-34	" 4	"	" " "	"
71	"	TF-35	" 5	"	" " "	"
72	TEMP(SYSTEM)	T-1	PV UPPER PLENUM	"	0~400°C, 0~10V	± 1.0 %
73	"	T-2	PV LOWER PLENUM	"	" " "	"
74	"	T-3	CONDENSATE NO.1	"	" " "	"
75	"	T-4	CONDENSATE NO.2	"	" " "	"
76	"	T-5	SG 1 INLET	"	" " "	"
77	"	T-6	SG 1 OUTLET	"	" " "	"
78	"	T-7	PI PUMP DELIVERY	"	" " "	"
79	"	T-8	PV INLET NOZZLE	"	" " "	"
80	"	T-9	SG 2 INLET	"	" " "	"
81	"	T-10	SG 2 OUTLET	"	" " "	"
82	"	T-11	P2 PUMP DELIVERY	"	" " "	"
83	"	T-12	PRESSURIZER	"	" " "	"
84	"	T-13	SG 1 SHELL OUTLET	"	" " "	"
85	"	T-14	SG 2 SHELL OUTLET	"	" " "	"
86	ON-OFF SIGNAL	S-1	RUPTURE DISC NO.1	COPPER WIRE VOLTAGE GENERATOR	RUPTURE, 0~10V	"
87	"	S-2	RUPTURE DISC NO.2	"	"	"
88	"	S-3	QUICK SHUT VALVE	LIMIT SW. CONTACT VOLTAGE GENERATOR	OPEN-CLOSE, 0~10V	"
89	"	S-4	RCN VALVE NO.1	"	CLOSE-HALF-OPEN 0~10V	"
90	"	S-5	RCN VALVE NO.2	"	"	"
91	"	S-6	ACC 1 VALVE	"	" 0~10V	"
92	"	S-7	ACC 2 VALVE	"	CLOSE-OPEN, 0~10V	"
93	"	S-8	HPC 1 VALVE	"	"	"
94	"	S-9	LPC 1 VALVE	"	"	"
95	"	S-10	SST DISCHARGE VALVE	"	CLOSE-OPEN, 0~10V	"
96	"	S-11	P 1 PUMP POWER SUPPLY	ELECTROMAGNETIC	ON-OFF, 0~10V	"
97	"	S-12	P 2 PUMP POWER SUPPLY	CONTACT	"	"
98	FLOW DIRECTN	FD-1	IN CORE		+0, -10V, +0~10V	"
99	"	FD-2	"		"	"
100	"	FD-3	"		"	"
101	PUMP REVOLUTION	N-1	P 1 PUMP	TACHO GENERATOR	0~5000r.p.m, 0~10V	"
102	"	N-2	P 2 PUMP	"	"	"
103	CORE FLOW VELOCITY	F-14	IN CORE	ELECTROMAGNETIC FLOW RATE METER	0~10 <sup>4</sup> sec, 0~10V	"
104	VOID FRACTION	V-1	IN CORE	ELECTRIC RESISTANCE	ON-OFF, 10V-0	"
105						
106						
107						
108						
109						
110						
111						
112						
113						
114						
115						
116						

Note \* will be changed for hot leg break piping

Remark Calculated data from original data are as follows.

Data Ch.No	Title	Data Ch.No	Title
115	No.1 Discharge Flow Rate	121	Temp. Difference (No.1 Rod, P.1)
116	" Quality	122	" ( " P.2)
117	No.2 Discharge Flow Rate	123	" ( " P.3)
118	" Quality	124	" ( " P.4)
119	Surface Heat Flux, No.1 Power	125	" ( " P.5)
120	" No.2 Power		

Table 6 Measurement List (For No.4 Assembly)

DATA CH.NO	MEAS.ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION		MEAS. RANGE & OUTPUT	ACCURACY
1	PRESSURE	P-1	PV. UPPER PLENUM	SEMI CONDUCTIVE PRESSURER TRANSDUCER	PMS-10KTM-200H	0~165 kg/cm <sup>2</sup> , 0~±5V	± 2.4 %
2	"	P-2	PV. LOWER PLENUM		"	"	"
3	"	P-3	ABOVE NO.1 ORIFICE		"	"	"
4	"	P-4	BELOW NO.1 ORIFICE		"	"	"
5	"	P-5	ABOVE NO.2 ORIFICE		"	"	"
6	"	P-6	BELOW NO.2 ORIFICE		"	"	"
7	"	P-7	SG 1 INLET		"	"	"
8	"	P-8	P1 PUMP SUCTION		"	"	"
9	"	P-9	SG 2 INLET		"	"	"
10	"	P-10	SG 2 OUTLET		"	"	"
11	"	P-11	P2 PUMP DELIVERY		"	"	"
12	"	P-12	PRESSURIZER		"	"	"
13	"	P-13	SG SHELL SIDE		PMS-10KTM-100H	0~60 kg/cm <sup>2</sup> , 0~±5V	"
14	DIFF. PRESS	D-1	PV. TOP-BOTTOM	HIGH DIFF-PRESSURE TRANSDUCER	E0H	0~0.6 kg/cm <sup>2</sup> , 2~10V	± 1.0 %
15	"	D-2	PV. TOP-BOTTOM		E11DM-SP	0~10 kg/cm <sup>2</sup> , "	"
16	"	D-3	PV. TOP-NO.1 ORIFICE *		"	"	"
17	"	D-4	PV. BOTTOM-NO.2 ORIFICE *		"	"	"
18	"	D-5	SG 1 INLET-OUTLET		"	-5~+5 kg/cm <sup>2</sup> , "	"
19	"	D-6	SG 2 INLET-OUTLET		"	"	"
20	"	D-7	P1 PUMP DELIVERY-SUCTION		"	"	"
21	"	D-8	P2 PUMP DELIVERY-SUCTION		"	-3~+3 kg/cm <sup>2</sup> , "	"
22	FLOWRATE	F-1	CONDENSATE NO.1	ELECTROMAGNETIC FLOW RATE METER 6159	"	0~250 kg/sec	± 1.4 %
23	"	F-2	CONDENSATE NO.2		"	"	"
24	"	F-3	COOLING WATER NO.1		"	"	"
25	"	F-4	COOLING WATER NO.2		"	"	"
26	"	F-5	HPC1 (1)	TURBINE FLOW RATE METER	"	0~20 l/min, 0~10V	± 1.2 %
27	"	F-6	" (2)		"	"	"
28	"	F-7	" (3)		"	0~50 l/min, "	"
29	"	F-8	" (4)		"	"	"
30	"	F-9	ACC 1		"	0~300 l/min, "	"
31	"	F-10	ACC 2 (1)		"	0~1000 l/min, "	"
32	"	F-11	ACC 2 (2)		"	"	"
33	"	F-12	LPC 1 (1)		"	0~110 l/min, "	"
34	"	F-13	" (2)		"	0~300 l/min, "	"
35	POWER	W-1	HIGH FLUX RODS	POWER TRANSDUCER 2885	"	0~600KVA, 0~10V	± 1.0 %
36	"	W-2	LOW FLUX RODS		"	0~1800KVA, 0~10V	"
37	TEMP.(FUEL)	TF-1	HIGH FLUX NO.1 ROD	THERMOCOUPLE %A UNGROUND	"	0~1200°C, 0~10V	± 1.4 %
38	"	TF-2	" " 2		"	"	"
39	"	TF-3	" " 3		"	"	"
40	"	TF-4	" " 4		"	"	"
41	"	TF-5	" " 5		"	"	"
42	"	TF-6	" NO.3 ROD 1		"	"	"
43	"	TF-7	" " 2		"	"	"
44	"	TF-8	" " 3		"	"	"
45	"	TF-9	" " 4		"	"	"
46	"	TF-10	" " 5		"	"	"
47	"	TF-11	" NO.9 ROD 1		"	"	"
48	"	TF-12	" " 2		"	"	"
49	"	TF-13	" " 3		"	"	"
50	"	TF-14	" " 4		"	"	"
51	"	TF-15	" " 5		"	"	"
52	"	TF-16	LOW FLUX NO.12 ROD 1		"	"	"
53	"	TF-17	" " 2		"	"	"
54	"	TF-18	" " 3		"	"	"
55	"	TF-19	" " 4		"	"	"
56	"	TF-20	" " 5		"	"	"
57	"	TF-21	" NO.41 ROD 1		"	"	"
58	"	TF-22	" " 2		"	"	"
59	"	TF-23	" " 3		"	"	"
60	"	TF-24	" " 4		"	"	"
61	"	TF-25	" " 5		"	"	"
62	"	TF-26	" NO.111 ROD 1		"	"	"
63	"	TF-27	" " 2		"	"	"
64	"	TF-28	" " 3		"	"	"
65	"	TF-29	" " 4		"	"	"
66	"	TF-30	" " 5		"	"	"

Table 6 (Cont'd)

DATA CH.NO.	MEAS. ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY
67	TEMP. (FUEL)	TF-31	INNER SURFACE 1	THERMOCOUPLE %A UNGROUND	0~1200°C , 0~10V	± 1.4 %
68	"	TF-32	" 2	"	" " "	"
69	"	TF-33	" 3	"	" " "	"
70	"	TF-34	" 4	"	" " "	"
71	"	TF-35	" 5	"	" " "	"
72	TEMP. (SYSTEM)	T-1	PV. UPPER PLENUM	"	0~400°C , 0~10V	± 1.0 %
73	"	T-2	PV. LOWER PLENUM	"	" " "	"
74	"	T-3	CONDENSATE NO. 1	"	" " "	"
75	"	T-4	CONDENSATE NO. 2	"	" " "	"
76	"	T-5	SG 1 INLET	"	" " "	"
77	"	T-6	SG 1 OUTLET	"	" " "	"
78	"	T-7	P1 PUMP DELIVERY	"	" " "	"
79	"	T-8	PV INLET NOZZLE	"	" " "	"
80	"	T-9	SG 2 INLET	"	" " "	"
81	"	T-10	SG 2 OUTLET	"	" " "	"
82	"	T-11	P 2 PUMP DELIVERY	"	" " "	"
83	"	T-12	PRESSURIZER	"	" " "	"
84	"	T-13	SG 1 SHELL OUTLET	"	" " "	"
85	"	T-14	SG 2 SHELL OUTLET	"	" " "	"
86	ON-OFF SIGNAL	S-1	RUPTURE DISC NO.1	COPPER WIRE, VOLTAGE GENERATOR	RUPTURE , 0~10V	"
87	"	S-2	RUPTURE DISC NO.2	"	"	"
88	"	S-3	QUICK SHUT VALVE	LIMIT SW. CONTACT, VOLTAGE GENERATOR	OPEN-CLOSE, 0~10V	"
89	"	S-4	RCN VALVE NO. 1	"	CLOSE-HALF-OPEN 0~10V	"
90	"	S-5	RCN VALVE NO. 2	"	" " "	"
91	"	S-6	ACC 1 VALVE	"	" , 0~10V	"
92	"	S-7	ACC 2 VALVE	"	CLOSE-OPEN, 0~10V	"
93	"	S-8	HPC 1 VALVE	"	" " "	"
94	"	S-9	LPC 1 VALVE	"	" " "	"
95	"	S-10	SST DISCHARGE VALVE	"	CLOSE-OPEN, 0~10V	"
96	"	S-11	P 1 PUMP POWER SUPPLY	ELECTROMAGNETIC	ON-OFF , 0~10V	"
97	"	S-12	P 2 PUMP POWER SUPPLY	CONTACT	" " "	"
98	FLOW DIRECTN	FD-1	IN CORE	"	+0, -10V → 0 → 10V	"
99	"	FD-2	"	"	" " "	"
100	"	FD-3	"	"	" " "	"
101	PUMP REVOLUTION	N-1	P 1 PUMP	TACHO GENERATOR	0~5000r.p.m. 0~10V	"
102	"	N-2	P 2 PUMP	"	" " "	"
103	CORE FLOW VELOCITY	F-14	IN CORE	ELECTROMAGNETIC FLOW RATE METER	0~10m/sec , 0~10V	"
104	VOID FRACTION	V-1	IN CORE	ELECTRIC RESISTANCE	ON → OFF , 10V → 0	"
105						
106						
107						
108						
109						
110						
111						
112						
113						
114						
115						
116						

Note \* will be changed for hot leg break piping

Remark Calculated data from original data are as follows.

Data Ch.No.	Title	Data Ch.No.	Title
110	No.1 Discharge Flow Rate	113	No.2 Discharge Quality
111	" Quality	119	Surface Heat Flux, No.1 Power
112	No.2 Discharge Flow Rate	120	" No.2 Power

Table 7 Measurement List (For No.40 Assembly)

DATA CH NO	MEAS. ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY	
1	PRESSURE	P-1	PV. UPPER PLENUM	SEMICONDUCTIVE PRESSURE TRANSDUCER	PMS-10KTM-200M 0~165 Kg/cm <sup>2</sup> , 0~±5V	±2.4 %	
2	"	P-2	PV. LOWER PLENUM		"	"	
3	"	P-3	ABOVE NO.1 ORIFICE		"	"	
4	"	P-4	BELOW NO.1 ORIFICE		"	"	
5	"	P-5	ABOVE NO.2 ORIFICE		"	"	
6	"	P-6	BELOW NO.2 ORIFICE		"	"	
7	"	P-7	SG1 INLET		"	"	
8	"	P-8	PI PUMP SUCTION		"	"	
9	"	P-9	SG2 INLET		"	"	
10	"	P-10	SG2 OUTLET		"	"	
11	"	P-12	P2 PUMP DELIVERY		"	"	
12	"	P-12	PRESSURIZER		"	"	
13	"	P-13	SG SHELL SIDE		PMS-10KTM-100M 0~60 Kg/cm <sup>2</sup> , 0~±5V	"	
14	DIFF. PRESS	D-1	PV-TOP-BOTTOM	HIGH DIFF-PRESURE TRANSDUCER	0~0.6 Kg/cm <sup>2</sup> , 2~10V	±1.0 %	
15	"	D-2	PV-TOP-BOTTOM		0~10 Kg/cm <sup>2</sup> , 2~10V	"	
16	"	D-3	PV. TOP-NO.1 ORIFICE		0~0.6 Kg/cm <sup>2</sup> , 2~10V	"	
17	"	D-4	PV. BOT TOM-NO.2 ORIFICE		"	"	
18	"	D-5	SG1 INLET-OUTLET		-3~+3 Kg/cm <sup>2</sup>	"	
19	"	D-6	SG2 INLET-OUTLET		-5~+5 Kg/cm <sup>2</sup>	"	
20	"	D-7	P1 PUMP DELIVERY-SUCTION		"	"	
21	"	D-8	P2 PUMP DELIVERY-SUCTION		-3~+3 Kg/cm <sup>2</sup>	"	
22	FLOW RATE	F-1	CONDENSED NO.1	ELECTROMAGNETIC FLOW RATE METER 6159	0~250 Kg/sec	±1.4 %	
23	"	F-2	CONDENSED NO.2		"	"	
24	"	F-3	COOLING WATER NO.1	TURBIN FLOW RATE METER	0~20 l/min, 0~10V	±1.2 %	
25	"	F-4	COOLING WATER NO.2		"	"	
26	"	F-5	HPCI (1)		"	"	
27	"	F-6	" (2)		"	"	
28	"	F-7	" (3)		0~50 l/min	"	
29	"	F-8	" (4)		"	"	
30	"	F-9	ACC 1		0~300 l/min	"	
31	"	F-10	ACC 2 (1)		0~1000 l/min	"	
32	"	F-11	ACC 2 (2)		"	"	
33	"	F-12	LPCI (1)		0~110 l/min	"	
34	"	F-13	" (2)		0~300 l/min	"	
35	POWER	W-1	POWER SUPPLY NO.1		POWER TRANSDUCER 2885	0~600 KVA	±1.0 %
36	"	W-2	POWER SUPPLY NO.2		POWER TRANSDUCER	0~1800 KVA	±1.0 %
37	TEMP. FUEL	TF-1	NO.1 ROD	THERMOCOUPLE % UNGROUND	0~1200 °C	±1.0 %	
38	"	TF-2	"		"	"	
39	"	TF-3	"		"	"	
40	"	TF-4	"		"	"	
41	"	TF-5	"		"	"	
42	"	TF-6	NO.3 ROD		"	"	
43	"	TF-7	"		"	"	
44	"	TF-8	"		"	"	
45	"	TF-9	"		"	"	
46	"	TF-10	"		"	"	
47	"	TF-11	NO.19 ROD		"	"	
48	"	TF-12	"		"	"	
49	"	TF-13	"		"	"	
50	"	TF-14	"		"	"	
51	"	TF-15	"		"	"	
52	"	TF-16	NO.12 ROD		"	"	
53	"	TF-17	"		"	"	
54	"	TF-18	"		"	"	
55	"	TF-19	"		"	"	
56	"	TF-20	"		"	"	
57	"	TF-21	NO.41 ROD		"	"	
58	"	TF-22	"		"	"	
59	"	TF-23	"		"	"	
60	"	TF-24	"		"	"	
61	"	TF-25	"		"	"	
62	"	TF-26	NO.111 ROD		"	"	
63	"	TF-27	"		"	"	
64	"	TF-28	"		"	"	
65	"	TF-29	"		"	"	
66	"	TF-30	"		"	"	
67	"	TF-31	NO.8 ROD		"	"	
68	"	TF-32	"		"	"	
69	"	TF-33	"		"	"	
70	"	TF-34	"		"	"	
71	"	TF-35	"		"	"	
72	"	TF-36	NO.44 ROD		"	"	
73	"	TF-37	"		"	"	
74	"	TF-38	"		"	"	
75	"	TF-39	"		"	"	

Remark; Calculated data from original data are as follows.

Data Ch.No.	Title	Data Ch.No.	Title
151	No.1 Discharge Flow Rate	154	No.2 Discharge Quality
152	" Quality	155	Surface Heat Flux, No.1 Power
153	No.2 Discharge Flow Rate	156	" No.2 Power



Table 7 (Cont'd)

DATA CH NO	MEAS ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS RANGE & OUTPUT	ACCURACY
76	TEMP (FUEL)	TF-40	NO. 44 ROD	5 THERMOCOUPLE % UNGROUND	0~1200°C, 0~10V	±1.0%
77	"	TF-41	NO. 66 ROD	1	"	"
78	"	TF-42	"	2	"	"
79	"	TF-43	"	3	"	"
80	"	TF-44	"	4	"	"
81	"	TF-45	"	5	"	"
82	TEMP (SYSTEM)	T-1	PV UPPER PLENUM	"	0~400°C, 0~10V	"
83	"	T-2	PV LOWER PLENUM	"	"	"
84	"	T-3	CONDENSED NO.1	"	"	"
85	"	T-4	CONDENSED NO.2	"	"	"
86	"	T-5	SG 1 INLET	"	"	"
87	"	T-6	SG 1 OUTLET	"	"	"
88	"	T-7	P1 PUMP DELIVERY	"	"	"
89	"	T-8	PV INLET NOZZLE	"	"	"
90	"	T-9	SG 2 INLET	"	"	"
91	"	T-10	SG 2 OUTLET	"	"	"
92	"	T-11	P2 PUMP DELIVERY	"	"	"
93	"	T-12	PRESSURIZER	"	"	"
94	"	T-13	SG 1 SHELL OUTLET	"	"	"
95	"	T-14	SG 2 SHELL OUTLET	"	"	"
96	"	TS-1	SUPPORT TUBE (70°)*	"	"	"
97	"	TS-3	"	"	"	"
98	"	TS-5	"	"	"	"
99	"	TS-7	"	"	"	"
100	"	TS-9	"	"	"	"
101	"	TS-10	" (250°)*	"	"	"
102	"	TS-12	"	"	"	"
103	"	TS-14	"	"	"	"
104	"	TS-16	"	"	"	"
105	"	TS-18	"	"	"	"
106	DN-OFF SIGNAL	S-1	RUPTURE DISC NO.1	COPPER WIRE VOLTAGE GENERATOR	RUPTURE	"
107	"	S-2	RUPTURE DISC NO.2	"	"	"
108	"	S-3	QUICK SHUT VALVE	LIMIT SW CONTACT VOLTAGE GENERATOR	OPEN-CLOSE	"
109	"	S-4	RCN VALVE NO.1	"	CLOSE-HALF-OPEN, 0-5-10V	"
110	"	S-5	RCN VALVE NO.2	"	"	"
111	"	S-6	ACC 1 VALVE	"	"	"
112	"	S-7	ACC 2 VALVE	"	CLOSE-OPEN, 0-10V	"
113	"	S-8	HPCI VALVE	"	"	"
114	"	S-9	LPCI VALVE	"	"	"
115	"	S-10	SST DISCHARGE VALVE	"	"	"
116	"	S-11	P1 PUMP POWER SUPPLY	ELECTROMAGNETIC CONTACT	ON-OFF	"
117	"	S-12	P2 PUMP POWER SUPPLY	"	"	"
118	PUMP REVOLUTION	N-1	P1 PUMP	TACHO GENERATOR	0-5000 r.p.m., 0~10V	"
119	"	N-2	P2 PUMP	"	"	"
120	FLOW DIRECTION	FD-1	IN CORE	"	+0~-10V, 0~10V	"
121	"	FD-2	"	"	"	"
122	"	FD-3	"	"	"	"
123	WATER LEVEL	LS-1	" (70°)*	PROBE TYPE LEVEL M	ON-OFF, 0~10V	"
124	"	LS-2	"	"	"	"
125	"	LS-3	"	"	"	"
126	"	LS-4	"	"	"	"
127	"	LS-5	"	"	"	"
128	"	LS-6	"	"	"	"
129	"	LS-7	"	"	"	"
130	"	LS-8	"	"	"	"
131	"	LS-9	"	"	"	"
132	"	LS-10	" (250°)*	"	"	"
133	"	LS-11	"	"	"	"
134	"	LS-12	"	"	"	"
135	"	LS-13	"	"	"	"
136	"	LS-14	"	"	"	"
137	"	LS-15	"	"	"	"
138	"	LS-16	"	"	"	"
139	"	LS-17	"	"	"	"
140	"	LS-18	"	"	"	"
141						
142						
143						
144						
145	DIFF. PRESS.	D-9	DOWNCOMER - LOWER PLENUM	HIGH DIFF-PRESSURE TRANSDUSER	-0.25~+0.25%/m <sup>2</sup> , 2~10V	±1.4%
146						
147						
148						
149						
150						

Note \* Will be changed for hot leg break piping

‡ 0° : Blowdown loop outlet nozzle side

90° : Blowdown loop inlet nozzle side

180° : Operating loop outlet nozzle side

270° : Operating loop inlet nozzle side

Table 8 Measurement List (For No.5 Assembly)

DATA CH NO.	MEAS. ITEMS	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY
1	PRESSURE	P-1	PV. UPPER PLENUM	SEMICONDUCTIVE PRESSURE TRANSDUCER	PMS-10KTM-200K 0~165kg/cm <sup>2</sup> , 0~±5V	±2.4 %
2	"	P-2	PV. LOWER PLENUM		"	"
3	"	P-3	ABOVE NO.1 ORIFICE		"	"
4	"	P-4	BELOW NO.1 ORIFICE		"	"
5	"	P-5	ABOVE NO.2 ORIFICE		"	"
6	"	P-6	BELOW NO.2 ORIFICE		"	"
7	"	P-7	SG1 INLET		"	"
8	"	P-8	P1 PUMP SUCTION		"	"
9	"	P-9	SG2 INLET		"	"
10	"	P-10	SG2 OUTLET		"	"
11	"	P-11	P2 PUMP DELIVERY		"	"
12	"	P-12	PRESSURIZER		"	"
13	"	P-13	SG SHELL SIDE		PMS-10KTM-100K 0~60kg/cm <sup>2</sup> , 0~±5V	"
14	DIFF. PRESS	D-1	PV-TOP-BOTTOM	HIGH DIFF-PRESURE TRANS DUSER	0~0.6kg/cm <sup>2</sup> , 2~10V	±1.0 %
15	"	D-2	PV-TOP-BOTTOM		"	"
16	"	D-3	*PV-TOP-NO.1 ORIFICE		"	"
17	"	D-4	*PV-BOTTOM-NO.2 ORIFICE		"	"
18	"	D-5	SG1 INLET-OUTLET		"	"
19	"	D-6	SG2 INLET-OUTLET		"	"
20	"	D-7	P1 PUMP DELIVERY-SUCTION		"	"
21	"	D-8	P2 PUMP DELIVERY-SUCTION		"	"
22	FLOW RATE	F-1	CONDENSED NO.1	ELECTROMAGNETIC FLOW RATE METER 6159	0~280kg/sec, ±	±1.4 %
23	"	F-2	CONDENSED NO.2		"	"
24	"	F-3	COOLING WATER NO.1		"	"
25	"	F-4	COOLING WATER NO.2		"	"
26	"	F-5	HPCI (1)	TURBIN FLOW RATE METER	0~20l/min, 0~10V	±1.2 %
27	"	F-6	(2)		"	"
28	"	F-7	(3)		"	"
29	"	F-8	(4)		"	"
30	"	F-9	ACC1		"	"
31	"	F-10	ACC2 (1)		"	"
32	"	F-11	ACC2 (2)		"	"
33	"	F-12	LPCI (1)		"	"
34	"	F-13	(2)		"	"
35	POWER	W-1	POWER SUPPLY NO.1		POWER TRANSDUSER 2885	0~600 KVA, ±
36	"	W-2	POWER SUPPLY NO.2	POWER TRANSDUSER	0~1800 KVA, ±	±1.0 %
37	TEMP (FUEL)	TF-1	NO.1 ROD	THERMOCOUPLE %A UNGROUND	0~1200°C	"
38	"	TF-2	"		"	"
39	"	TF-3	"		"	"
40	"	TF-4	"		"	"
41	"	TF-5	"		"	"
42	"	TF-6	NO.20 ROD		"	"
43	"	TF-7	"		"	"
44	"	TF-8	"		"	"
45	"	TF-9	"		"	"
46	"	TF-10	"		"	"
47	"	TF-11	NO.26 ROD		"	"
48	"	TF-12	"		"	"
49	"	TF-13	"		"	"
50	"	TF-14	"		"	"
51	"	TF-15	"		"	"
52	"	TF-16	NO.89 ROD		"	"
53	"	TF-17	"		"	"
54	"	TF-18	"		"	"
55	"	TF-19	"		"	"
56	"	TF-20	"		"	"
57	"	TF-21	NO.110 ROD		"	"
58	"	TF-22	"		"	"
59	"	TF-23	"		"	"
60	"	TF-24	"		"	"
61	"	TF-25	"		"	"
62	"	TF-26	NO.12 ROD		"	"
63	"	TF-27	"		"	"
64	"	TF-28	"		"	"
65	"	TF-29	"		"	"
66	"	TF-30	"		"	"
67	"	TF-31	NO.16 ROD		"	"
68	"	TF-32	"		"	"
69	"	TF-33	"		"	"
70	"	TF-34	"		"	"
71	"	TF-35	"		"	"
72	"	TF-36	NO.24 ROD		"	"
73	"	TF-37	"		"	"
74	"	TF-38	"		"	"
75	"	TF-39	"		"	"

Remark

Calculated data from original data are the same as Table 7 (Ch.151 ~ Ch.156)

Table 8 (Cont'd)

DATA CH NO.	MEAS ITEM	SYMBOL	NAME(MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY
76	TEMP.(FUEL)	TF-40	NO. 24 ROD	5 THERMOCOUPLE % UNGROUND	0~1200°C, 0~10V	± 1.0 %
77	*	TF-41	NO. 44 ROD	1	0~ 500°C, 0~10V	*
78	*	TF-42	*	2	*	*
79	*	TF-43	*	3	*	*
80	*	TF-44	*	4	*	*
81	*	TF-45	*	5	*	*
82	TEMP(SYSTEM)	T - 1	PV. UPPER PLENUM	*	0~ 400°C, 0~ 10V	*
83	*	T - 2	PV. LOWER PLENUM	*	*	*
84	*	T - 3	CONDENSED NO.1	*	*	*
85	*	T - 4	CONDENSED NO.2	*	*	*
86	*	T - 5	SG 1 INLET	*	*	*
87	*	T - 6	SG 1 OUTLET	*	*	*
88	*	T - 7	P1 PUMP DELIVERY	*	*	*
89	*	T - 8	PV. INLET NOZZLE	*	*	*
90	*	T - 9	SG 2 INLET	*	*	*
91	*	T - 10	SG 2 OUTLET	*	*	*
92	*	T - 11	P2 PUMP DELIVERY	*	*	*
93	*	T - 12	PRESSURIZER	*	*	*
94	*	T - 13	SG 1 SHELL OUTLET	*	*	*
95	*	T - 14	SG 2 SHELL OUTLET	*	*	*
96	*	TS - 1	SUPPORT TUBE (70°)*	*	*	*
97	*	TS - 5	*	( * )*	*	*
98	*	TS - 9	*	( * )*	*	*
99	*	TS - 10	*	(250°)*	*	*
100	*	TS - 14	*	( * )*	*	*
101	*	TS - 18	*	( * )*	*	*
102	*	TB - 1	CORE BARREL (0°)*	*	*	*
103	*	TB - 6	*	( * )*	*	*
104	*	TB - 7	*	(180°)*	*	*
105	*	TB - 12	*	( * )*	*	*
106	ON-OFF SIGNAL	S - 1	RUPTURE DISC NO. 1	COPPER WIRE VOLTAGE GENERATOR	RUPTURE	*
107	*	S - 2	RUPTURE DISC NO. 2	*	*	*
108	*	S - 3	QUICK SHUT VALVE	LIMIT SW. CONTACT VOLTAGE GENERATOR	OPEN-CLOSE	*
109	*	S - 4	RCN VALVE NO. 1	*	CLOSE-HALF-OPEN, 0-5-10	*
110	*	S - 5	RCN VALVE NO. 2	*	*	*
111	*	S - 6	ACC 1 VALVE	*	CLOSE-OPEN, 0~10V	*
112	*	S - 7	ACC 2 VALVE	*	*	*
113	*	S - 8	HPCI VALVE	*	*	*
114	*	S - 9	LPCI VALVE	*	*	*
115	*	S - 10	SST DISCHARGE VALVE	*	*	*
116	*	S - 11	P1 PUMP POWER SUPPLY	ELECTROMAGNETIC CONTACT	ON - OFF	*
117	*	S - 12	P2 PUMP POWER SUPPLY	TACHO GENERATOR	0-5000 r.p.m., 0~10V	*
118	REVOLUTION	N - 1	P1 PUMP	*	*	*
119	*	N - 2	P2 PUMP	*	*	*
120	FLOW DIRECTION	FD - 1	IN CORE	*	+0~-10V, 0~10V	*
121	*	FD - 2	*	*	*	*
122	*	FD - 3	*	*	*	*
123	WATER LEVEL	LS - 1	(70°)*	PROBE TYPE LEVEL M.	ON - OFF, 0~10V	*
124	*	LS - 2	( * )*	*	*	*
125	*	LS - 3	( * )*	*	*	*
126	*	LS - 4	( * )*	*	*	*
127	*	LS - 5	( * )*	*	*	*
128	*	LS - 6	( * )*	*	*	*
129	*	LS - 7	( * )*	*	*	*
130	*	LS - 8	( * )*	*	*	*
131	*	LS - 9	( * )*	*	*	*
132	*	LS - 10	(250°)*	*	*	*
133	*	LS - 11	( * )*	*	*	*
134	*	LS - 12	( * )*	*	*	*
135	*	LS - 13	( * )*	*	*	*
136	*	LS - 14	( * )*	*	*	*
137	*	LS - 15	( * )*	*	*	*
138	*	LS - 16	( * )*	*	*	*
139	*	LS - 17	( * )*	*	*	*
140	*	LS - 18	( * )*	*	*	*
141						
142						
143						
144						
145	DIFF. PRESS.	D - 9	DOWNCOMER - LOWER PLENUM	HIGH DIFF-PRESSURE TRANSDUSER	-0.25~+0.25 <sup>0</sup> m <sup>2</sup> z - 10V	± 1.4 %
146						
147						
148						
149						
150						

Note \* Will be changed for hot leg break piping

\* 0° : Blowdown loop outlet nozzle side  
 90° : Blowdown loop inlet nozzle side

180° : Operating loop outlet nozzle side  
 270° : Operating loop inlet nozzle side

Table 9 Measurement List (For UHI Assembly)

DATA CH.NO	MEAS.ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY	
1	PRESSURE	P-1	PV. UPPER HEAD	SEMI CONDUCTIVE PRESSUER TRANSDUCER	PMS-10KTM-200H	0~165 kg/cm <sup>2</sup> , 0~±5V	± 2.4 %
2	"	P-2	PV. LOWER PLENUM		"	"	"
3	"	P-3	ABOVE NO.1 ORIFICE		"	"	"
4	"	P-4	BELOW NO.1 ORIFICE		"	"	"
5	"	P-5	ABOVE NO.2 ORIFICE		"	"	"
6	"	P-6	BELOW NO.2 ORIFICE		"	"	"
7	"	P-7	SG 1 INLET		"	"	"
8	"	P-8	P1 PUMP SUCTION		"	"	"
9	"	P-9	SG 2 INLET		"	"	"
10	"	P-10	SG 2 OUTLET		"	"	"
11	"	P-11	P2 PUMP DELIVERY		"	"	"
12	"	P-12	PRESSURIZER		"	"	"
13	"	P-13	SG SHELL SIDE		PMS-10KTM-100H	0~60 kg/cm <sup>2</sup> , 0~±5V	"
14	DIFF. PRESS	D-1	PV. TOP-BOTTOM	EDH	0~0.6 kg/cm <sup>2</sup> , 2~10V	± 1.0 %	
15	"	"	"	"	"	"	
16	"	D-3	PV. TOP-NO.1 ORIFICE *	HIGH DIFF-PRESSURE TRANSDUCER	"	"	
17	"	D-4	PV. BOTTOM-NO.2 ORIFICE *	"	"	"	
18	"	D-5	SG 1 INLET-OUTLET	"	-5~+5 kg/cm <sup>2</sup>	"	
19	"	D-6	SG 2 INLET-OUTLET	"	"	"	
20	"	D-7	P1 PUMP DELIVERY-SUCTION	"	"	"	
21	"	D-8	P2 PUMP DELIVERY-SUCTION	"	-3~+3 kg/cm <sup>2</sup>	"	
22	FLOWRATE	F-1	CONDENSATE NO.1	ELECTROMAGNETIC FLOW. RATE METER 6159	0~250 kg/sec	± 1.4 %	
23	"	F-2	CONDENSATE NO.2		"	"	"
24	"	F-3	COOLING WATER NO.1		"	"	"
25	"	F-4	COOLING WATER NO.2		"	"	"
26	"	F-5	HPCI (1)	TURBINE FLOW RATE METER	0~20 l/min, 0~10V	± 1.2 %	
27	"	F-6	" (2)	"	"	"	
28	"	F-7	" (3)	"	0~50 l/min	"	
29	"	F-8	" (4)	"	"	"	
30	"	F-9	ACC 1	"	0~300 l/min	"	
31	"	F-10	ACC 2 (1)	"	0~1000 l/min	"	
32	"	F-11	ACC 2 (2)	"	"	"	
33	"	F-12	LPC 1 (1)	"	0~110 l/min	"	
34	"	F-13	" (2)	"	0~300 l/min	"	
35	POWER	W-1	POWER SUPPLY NO.1	POWER TRANSDUCER 2885	0~600KVA, 0~10V	± 1.0 %	
36	"	W-2	POWER SUPPLY NO.2	"	0~1800KVA, 0~10V	"	
37	TEMP(FUEL)	TF-1	NO.1 ROD	THERMOCOUPLE CA UNGROUND	0~1200°C, 0~10V	± 1.0 %	
38	"	TF-2	"	"	"	"	
39	"	TF-3	"	"	"	"	
40	"	TF-4	"	"	"	"	
41	"	TF-5	"	"	"	"	
42	"	TF-6	NO.33 ROD	"	"	"	
43	"	TF-7	"	"	"	"	
44	"	TF-8	"	"	"	"	
45	"	TF-9	"	"	"	"	
46	"	TF-10	"	"	"	"	
47	"	TF-11	NO.125 ROD	"	"	"	
48	"	TF-12	"	"	"	"	
49	"	TF-13	"	"	"	"	
50	"	TF-14	"	"	"	"	
51	"	TF-15	"	"	"	"	
52	"	TF-16	NO.146 ROD	"	"	"	
53	"	TF-17	"	"	"	"	
54	"	TF-18	"	"	"	"	
55	"	TF-19	"	"	"	"	
56	"	TF-20	"	"	"	"	
57	"	TF-21	TIE ROD (NO.44 ROD)	"	0~500°C, 0~10V	"	
58	"	TF-22	"	"	"	"	
59	"	TF-23	"	"	"	"	
60	"	TF-24	"	"	"	"	
61	"	TF-25	"	"	"	"	
62	TEMP(UH)	TU-1	UPPER PLENUM	"	"	"	
63	"	TU-2	UHI COLUMN NO.1	"	"	"	
64	"	TU-3	UHI COLUMN NO.2	"	"	"	
65	"	TU-4	UHI COLUMN NO.3	"	"	"	
66	"	TU-5	UHI COLUMN NO.4	"	"	"	

Table 9 (Cont'd)

MEASUREMENT LIST

DATA CH.NO.	MEAS. ITEM	SYMBOL	NAME (MEASURING POINT)	SENSOR SPECIFICATION	MEAS. RANGE & OUTPUT	ACCURACY
67	TEMP(SYSTEM)	TU-6	GUIDE TUBE	THERMOCOUPLE C/A UNGROUND	0~500°C, 0~10V	± 1.4 %
68	"	TU-7	UP. HEAD POSITION NO.1	"	"	"
69	"	TU-8	UP. HEAD POSITION NO.2	"	"	"
70	"	TU-9	UP. HEAD POSITION NO.3	"	"	"
71						
72	TEMP(SYSTEM)	T-1	UP. HEAD POSITION NO.0	THERMOCOUPLE C/A UNGROUND	0~400°C, 0~10V	± 1.0 %
73	"	T-2	PV. LOWER PLENUM	"	"	"
74	"	T-3	CONDENSATE NO.1	"	"	"
75	"	T-4	CONDENSATE NO.2	"	"	"
76	"	T-5	SG 1 INLET	"	"	"
77	"	T-6	SG 1 OUTLET	"	"	"
78	"	T-7	P1 PUMP DELIVERY	"	"	"
79	"	T-8	PV INLET NOZZLE	"	"	"
80	"	T-9	SG 2 INLET	"	"	"
81	"	T-10	SG 2 OUTLET	"	"	"
82	"	T-11	P2 PUMP DELIVERY	"	"	"
83	"	T-12	PRESSURIZER	"	"	"
84	"	T-13	SG 1 SHELL OUTLET	"	"	"
85	"	T-14	SG 2 SHELL OUTLET	"	"	"
86	ON-OFF SIGNAL	S-1	RUPTURE DISC NO.1	COPPER WIRE, VOLTAGE GENERATOR	RUPTURE, 0~10V	
87	"	S-2	RUPTURE DISC NO.2	"	"	
88	"	S-3	QUICK SHUT VALVE	LIMIT SW. CONTACT, VOLTAGE GENERATOR	OPEN-CLOSE, 0~10V	
89	"	S-4	RCN VALVE NO.1	"	CLOSE-HALF-OPEN, 0~10V	
90	"	S-5	RCN VALVE NO.2	"	"	
91	"	S-6	ACC 1 VALVE	"	"	0~10V
92	"	S-7	ACC 2 VALVE	"	CLOSE-OPEN, 0~10V	
93	"	S-8	HPC 1 VALVE	"	"	
94	"	S-9	LPC 1 VALVE	"	"	
95	"	S-10	SST DISCHARGE VALVE	"	CLOSE-OPEN, 0~10V	
96	"	S-11	P1 PUMP POWER SUPPLY	ELECTROMAGNETIC	ON-OFF, 0~10V	
97	"	S-12	P2 PUMP POWER SUPPLY	CONTACT	"	
98	FLOW DIRECTION	FD-1	IN CORE	"	+0, -10V, 0~10V	
99	"	FD-2	"	"	"	
100	"	FD-3	"	"	"	
101	PUMP REVOLUTION	N-1	P1 PUMP	TACHO GENERATOR	0~5000 r.p.m., 0~10V	
102	"	N-2	P2 PUMP	"	"	
103						
104						
105						
106						
107						
108	TEMP(SYSTEM)	TU-10	UHI WATER TEMPERATURE	THERMOCOUPLE C/A UNGROUND	0~200°C, 0~10V	
109	PRESSURE	P-14	UHI TANK PRESSURE	PMS-10KTM-100H	0~100 kg/cm <sup>2</sup> , 0~15V	
110	FLOWRATE	P-14	UHI FLOW RATE	TURBINE FLOW RATE METER	0~500 l/min, 1~5V	
111	ON-OFF SIGNAL	S-13	UHI VALVE SIGNAL	LIMIT SW. CONTACT, VOLTAGE GENERATOR	OPEN-CLOSE, 0~10V	
112						
113						
114						
115						
116						

Note \* will be changed for hot leg break piping

Remark; Calculated data from original data are as follows.

Data Ch.No.	Title	Data Ch.No.	Title
115	No.1 Discharge Flow Rate	118	No.2 Discharge Quality
116	" Quality	119	Surface Heat Flux, No.1 Power
117	No.2 Discharge Flow Rate	120	" , No.2 Power

Table 10 Standard Set of Output for the Test Data Using No.1 & No.2 Assembly

No.	1		2		3		4		5		Data
	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	
	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	
1	1	1	2	2	12	3					} Primary Pressure
2	3	1	5	2	7	3	8	4			
3	4	1	6	2							
4	9	1	10	2	11	3					} Sec. Pressure
5	13	1									
6	14	1									} Diff. Pressure
7	16	1	17	2	18	3	20	4			
8	19	1	21	2							
9	26	1	27	2							} ECCS Flow Rate
10	28	1	29	2							
11	30	1	31	2							} Power
12	33	1	34	2							
13	35	1	87	2							} Power
14	36	1	88	2							
15	37	1	38	2	39	3	40	4	41	5	} Cladding Temperature
16	42	1	43	2	44	3	45	4	46	5	
17	47	1	48	2	49	3	50	4	51	5	
18	52	1	53	2	54	3	55	4	56	5	} Primary Fluid Temperature
19	57	1	58	2	68	3					
20	61	1	62	2	63	3	64	4			} Primary Fluid Temperature
21	65	1	66	2	67	3					
22	69	1	70	2							} Sec. Fluid Temp. Pump Speed
23	71	1	72	2							

Table 11 Standard Set of Output for the Test Data Using No.3 & No.4 Assembly

No.	1		2		3		4		5		Data
	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	
	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	
1	1	1	2	2	12	3					} Primary Pressure
2	3	1	5	2	7	3	8	4			
3	4	1	6	2							
4	9	1	10	2	11	3					} Sec. Pressure
5	13	1									
6	14	1									} Diff. Pressure
7	16	1	17	2	18	3	20	4			
8	19	1	21	2							} Leak Flow Rate, Quality
9	22	1	24	2	74	3					
10	23	1	25	2	75	3					} Fluid Temp.
11	110	1	111	2							
12	112	1	113	2							} ECCS Flow Rate
13	26	1	27	2							
14	28	1	29	2							} Power
15	30	1	31	2	32	3					
16	33	1	34	2							} Cladding Temperature
17	35	1	119	2							
18	36	1	120	2							} *Cladding ΔT
19	37	1	38	2	39	3	40	4	41	5	
20	42	1	43	2	44	3	45	4	46	5	} Primary Fluid Temp.
21	47	1	48	2	49	3	50	4	51	5	
22	52	1	53	2	54	3	55	4	56	5	} Sec. Fluid Temp.
23	57	1	58	2	59	3	60	4	61	5	
24	62	1	63	2	64	3	65	4	66	5	} Pump Speed
25	67	1	68	2	69	3	70	4	71	5	
26	114	1	115	2	116	3	117	4	118	5	
27	72	1	73	2	83	3					
28	76	1	77	2	78	3	79	4			
29	80	1	81	2	82	3					
30	84	1	85								
31	101	1	102								

\* No data in Ch.114~118 for No.4 assembly.

Table 12 Standard Set of Output for Test Data  
Using No.3A Assembly

No.	1		2		3		4		5		Data
	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	
	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	
1	1	1	2	2	12	3					} Primary Pressure
2	3	1	5	2	7	3	8	4			
3	4	1	6	2							
4	9	1	10	2	11	3					} Sec. Pressure
5	13	1									
6	14	1									} Diff. Pressure
7	16	1	17	2	18	3	20	4			
8	19	1	21	2							
9	22	1	24	2	74	3					} Leak Flow Rate Quality, Fluid Temp.
10	23	1	25	2	75	3					
11	115	1	116	2							
12	117	1	118	2							} ECCS
13	26	1	27	2							
14	28	1	29	2							} Flow Rate
15	30	1	31	2	32	3					
16	33	1	34	2							
17	35	1	119	2							} Power
18	36	1	120	2							
19	37	1	38	2	39	3	40	4	41	5	} Cladding Temperature
20	42	1	43	2	44	3	45	4	46	5	
21	47	1	48	2	49	3	50	4	51	5	
22	52	1	53	2	54	3	55	4	56	5	} Cladding $\Delta T$
23	57	1	58	2	59	3	60	4	61	5	
24	62	1	63	2	64	3	65	4	66	5	
25	67	1	68	2	69	3	70	4	71	5	} Primary Fluid Temp.
26	121	1	122	2	123	3	124	4	125	5	
27	72	1	73	2	83	3					} Sec. Fluid Temp. Pump Speed
28	76	1	77	2	78	3	79	4			
29	80	1	81	2	82	3					
30	84	1	85	2							} Sec. Fluid Temp. Pump Speed
31	101	1	102	2							



Table 13 Standard Set of Output for Test Data  
Using No.40 Assembly

No.	1		2		3		4		5		Data
	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	
	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	
1	1	1	2	2	12	3					Primary Pressure
2	3	1	5	2	7	3	8	4			
3	4	1	6	2							
4	9	1	10	2	11	3					Sec. Pressure
5	13	1									
6	14	1									Diff. Pressure
7	16	1	17	2	18	3	20	4			
8	19	1	21	2							
9	22	1	24	2	84	3					Leak Flow Rate Quality
10	23	1	25	2	85	3					
11	151	1	152	2							Fluid Temp.
12	153	1	154	2							ECCS
13	26	1	27	2	28	3	29	4			
14	30	1	31	2	32	3	33	4	34	5	
15	35	1	155	2	36	3	156	4			Flow Rate Power
16	37	1	38	2	39	3	40	4	41	5	Cladding Temperature
17	42	1	43	2	44	3	45	4	46	5	
18	47	1	48	2	49	3	50	4	51	5	
19	52	1	53	2	54	3	55	4	56	5	
20	57	1	58	2	59	3	60	4	61	5	
21	62	1	63	2	64	3	65	4	66	5	
22	67	1	68	2	69	3	70	4	71	5	
23	72	1	73	2	74	3	75	4	76	5	
24	77	1	78	2	79	3	80	4	81	5	
25	82	1	83	2	93	3					Primary Fluid Temp.
26	86	1	87	2	88	3	89	4			
27	90	1	91	2	92	3					Sec. Fluid Temp.
28	94	1	95	2							
29	96	1	97	2	98	3	99	4	100	5	Metal Surface Temperature
30	101	1	102	2	103	3	104	4	105	5	
31	118	1	119	2							
32											Pump Speed

Table 14 Standard Set for Output Test Data  
Using No.5 Assembly

No.	1		2		3		4		5		6		Date
	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	
	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	
1	1	1	2	2	12	3							
2	3	1	5	2	7	3	8	4					} Primary Pressure
3	4	1	6	2									
4	9	1	10	2	11	3							} Sec. Pressure
5	13	1											
6	14	1											} Diff. Pressure
7	16	1	17	2	18	3	20	4					
8	19	1	21	2									} Leak Flow Rate
9	22	1	24	2	84	3							
10	23	1	25	2	85	3							} Quality, Fluid Temp.
11	151	1	152	2									
12	153	1	154	2									} ECCS Flow Rate Power
13	26	1	27	2	28	3	29	4					
14	30	1	31	2	32	3	33	4	34	5			} Cladding Temperature
15	35	1	155	2	46	3	156	4					
16	37	1	38	2	39	3	40	4	41	5			} Primary Fluid Temp.
17	42	1	43	2	44	3	45	4	46	5			
18	47	1	48	2	49	3	50	4	51	5			} Sec. Fluid Temp.
19	52	1	53	2	54	3	55	4	56	5			
20	57	1	58	2	59	3	60	4	61	5			} Metal Surface Temperature
21	62	1	63	2	64	3	65	4	66	5			
22	67	1	68	2	69	3	70	4	71	5			} Pum Speed
23	72	1	73	2	74	3	75	4	76	5			
24	77	1	78	2	79	3	80	4	81	5			} Primary Fluid Temp.
25	82	1	83	2	93	3							
26	86	1	87	2	88	3	89	4					} Sec. Fluid Temp.
27	90	1	91	2	92	3							
28	94	1	95	2									} Metal Surface Temperature
29	96	1	97	2	98	3	99	4	100	5	101	6	
30	102	1	103	2	104	3	105	4					} Pum Speed
31	118	1	119	2									

Table 15 Standard Set for Output of Test Data  
Using UHI Assembly

No.	1		2		3		4		5		Data
	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	Ch.	Sig.	
	No.	No.	No.	No.	No.	No.	No.	No.	No.	No.	
1	1	1	2	2	12	3					} Primary Pressure
2	3	1	5	2	7	3	8	4			
3	4	1	6	2							
4	9	1	10	2	11	3					} Sec. Pressure
5	13	1									
6	14	1									} Diff. Pressure
7	16	1	17	2	18	3	20	4			
8	19	1	21	2							
9	22	1	24	2	74	3					} Leak Flow Rate Quality, Fluid Temp.
10	23	1	25	2	75	3					
11	115	1	116	2							} ECCS Flow Rate
12	117	1	118	2							
13	108	1	109	2	110	3					} Power
14	26	1	27	2	28	3	29	4			
15	30	1	31	2	32	3	33	4	34	5	
16	35	1	119	2							} Cladding Temperature
17	36	1	120	2							
18	37	1	38	2	39	3	40	4	41	5	} Primary Fluid Temp.
19	42	1	43	2	44	3	45	4	46	5	
20	47	1	48	2	49	3	50	4	51	5	
21	52	1	53	2	54	3	55	4	56	5	} Sec. Fluid Temp.
22	57	1	58	2	59	3	60	4	61	5	
23	62	1	67	2							} Pump Speed
24	63	1	64	2	65	3	66	4			
25	68	1	69	2	70	3	72	4			
26	73	1	83	2							} Primary Fluid Temp.
27	76	1	77	2	78	3	79	4			
28	80	1	81	2	82	3					} Sec. Fluid Temp.
29	84	1	85	2							
30	101	1	102	2							Pump Speed

Table 16 Elimination Channel Number for Output in the Test Data of Nol. Assembly

RUN No.	SLTAPE		Elimination channel Number for Each Run
	Vol.	FNAME	
202	011876	J3019. ROSA202	15~17, 19~34, 36, 59, 60 73~86, 88
203	"	J3019. ROSA203	15~17, 19~26, 28, 29, 31, 32, 34, 36, 41, 59, 60, 73~86, 88
204	021874	J3019. ROSA204	2~4, 6, 7, 15~17, 19~25, 27~29, 31, 32, 34, 36, 38, 59, 60, 73~86, 88
301	"	J3019. ROSA301	2, 5, 6, 15~17, 19~34, 36, 59, 60, 68, 73~86, 88
302	"	J3019. ROSA302	4~6, 15~17, 19~27, 29~33, 36, 57~60, 73~86, 88
303	011876	J3019, ROSA303	6~8, 14~17, 19~25, 28, 29, 31, 32, 34, 36, 57~60, 62, 71, 73~86, 88
304	"	J3019. ROSA304	4, 6, 15~17, 19~33, 36, 42, 57, 59, 60, 71, 73~86, 88
307	011875	J3019. ROSA307	6, 15~17, 19~29, 32, 36, 42, 57 59~60, 63, 73~86, 88
308	"	J3019. ROSA308	6, 15~17, 19~29, 32~34, 36, 42, 59, 60, 73~86, 88
309	"	J3019. ROSA309	4, 15~17, 19~32, 34, 36, 42, 59, 60, 73~86, 88
401	021863	J3019. ROSA401	3, 4, 6, 7, 15~17, 19~25, 28, 29, 31, 32, 36, 42, 58~60, 73~86, 88
403	"	J3019. ROSA403	15~17, 19~34, 36, 42, 51, 55 59, 60, 73~86, 88
404	"	J3019. ROSA404	15~17, 19~26, 29, 31, 32, 36, 42, 55, 58~60, 71, 73~86, 88

Table 17 Elimination Channel Number for Output  
in the Test Data of No.2 Assembly

RUN NO.	SLTAPE		Elimination Channel Number for Each Run
	Vol.	FNAME	
306	011876	J3019. ROSA306	1, 4, 6, 10, 15~33, 36, 59~60, 68, 73~86, 88

Table 18 Elimination Channel Number for Output  
in the Test Data of No.3 Assembly

RUN No.	SLTAPE		Elimination Channel Number for Each Run
	Vol.	FNAME	
310	021862	J3019. ROSA310	1, 2, 4~6, 15~17, 19, 20, 22~30, 32, 36, 56, 74, 75, 86~100, 103~113, 120
311	"	J3019. ROSA311	4~6, 15~17, 19, 20, 23, 25~32, 38, 40, 42, 44, 46, 48, 50, 52, 56, 75, 78, 86~100, 103~109, 112, 113, 115, 117
312	"	J3019. ROSA312	4~6, 15~17, 19, 20, 23, 25~29, 32, 38, 40, 42, 44, 46, 48, 50, 52, 54~56, 75, 86~100, 103~109, 112, 113, 115, 117
313	"	J3019. ROSA313	4, 6, 15~17, 20, 22, 24, 26~29, 32, 37, 45, 52, 74, 86~100, 103~111, 113, 114
314	011836	J3019. ROSA314	4, 6, 7, 15~17, 19, 20, 22~29, 32, 45, 51, 74 75, 86~100, 103~113
315	"	J3019. ROSA315	6, 15~17, 20, 26~30, 32, 36, 37, 45, 52, 73, 79 82, 86~100, 103~109, 114, 120
411	"	J3019. ROSA411	4, 5, 15~17, 20, 22~29, 32, 52, 72, 74, 75, 79, 85~113

Table 19 Elimination Channel Number for Output  
in the Test Data of No.3A Assembly

RUN No.	SLTAPE		Elimination Channel Number for Each Run
	Vol.	FNAME	
324	011971	J3019. ROSA324	2, 5, 15~17, 26~29, 32, 81, 82, 84 80~100, 103~114
325	"	J3019. ROSA325	4, 6, 15, 16, 26~29, 32, 77, 84, 86~101, 103~114
326	"	J3019. ROSA326	4, 6, 15, 16, 19, 23, 25~29, 32, 75, 77, 84, 86~101, 103~114

Table 21 Elimination Channel Number for Output  
in the Test Data of No.40 Assembly

RUN No.	SLTAPE		Elimination channel Number for Each Run
	Vol.	FNAME	
502	011921	J3019. ROSA502	9, 15, 19, 26~29, 31~33, 39, 47, 75, 91, 106~118, 120~122, 141~144, 146~150
505	"	J3019. ROSA505	10, 15, 18, 22~30, 32, 33, 39, 47, 49, 75, 84, 85, 89, 106~118, 120~122, 141~144, 146~154
506	"	J3019. ROSA506	15, 17, 26~29, 32, 33, 39, 47, 49, 97, 106~118, 120~122, 141~144, 146~150
507	"	J3019. ROSA507	5, 7, 9, 15, 23, 25~29, 32, 33, 39, 47, 49, 85, 106~118, 120~122, 141~144, 146~150, 153, 154
332	011922	J3019. ROSA332	15~17, 26~34, 47, 82, 91, 106~118, 120~122, 124, 126, 127, 129, 131, 133, 134, 136~138, 140~150

Table 20 Elimination Channel Number for Output  
in the Test Data of No.4 Assembly

RUN NO.	SLTAPE		Elimination Channel Number for Each Run
	Vol.	FNAME	
316	011836	J3019. ROSA316	4, 9, 15~17, 26~30, 32, 45, 70, 73, 79, 81, 86~100, 103~109, 114~118
317	021862	J3019. ROSA317	15~17, 19, 23, 25~29, 32, 38, 45, 52, 70, 75, 84, 86~100, 103~109, 112, 113~118
318	011766	J3019. ROSA318	6, 15~17, 22~25, 32, 35, 36, 69, 70, 74, 75, 79, 86~100, 103~120
320	"	J3019. ROSA320	9, 15~17, 19, 22~26, 29, 32, 70, 74, 75, 86~100, 103~118
321	"	J3019. ROSA321	5, 6, 15~19, 22~25, 27, 32, 69, 70, 74, 75, 79~81, 86~100, 103~118
322	"	J3019. ROSA322	5, 6, 13, 15~18, 22~27, 32, 69, 70, 74, 75, 81, 86~100, 103~118
323	"	J3019. ROSA323	15~17, 22~27, 29, 32, 50, 69, 70, 74~76, 81, 86~100, 103~118
415	031960	J3019. ROSA415	3, 4, 11, 15~17, 22~29, 32, 38, 54, 55, 69, 70, 74, 75, 86~101, 103~118
413	011922	J3019. ROSA413	2, 10, 11, 15~17, 26~29, 32, 44, 55, 69, 70, 73, 85~100, 103~114
417	031960	J3019. ROSA417	3, 4, 11, 15~17, 20~25, 29, 32, 37, 38, 67~72, 74, 75, 78, 86~101, 103~118
418	031967	J3019. ROSA418	11, 15~17, 20, 26~34, 45, 67~71, 86~101, 103~114
419	"	J3019. ROSA419	11, 15, 20, 26~29, 32, 45, 67~71, 86~101, 103~114

Table 22 Elimination Channel Numbers for Output  
in the Test Data of No.5 Assembly

RUN No.	SLTAPE		Elimination Channel Number for Each Run
	Vol.	FNAME	
327	011937	J3019. ROSA327	14, 15, 22~29, 32, 33, 75, 82, 84, 85, 93~95, 106~118, 120~122, 128, 134, 141~154
328	"	J3019. ROSA328	15, 26~29, 32, 75, 82, 94, 106~118, 120~122, 134, 141~150
329	"	J3019. ROSA329	3, 15~17, 26~29, 32, 75, 82, 105~118, 120~122, 128, 134, 141~150, 154
330	"	J3019. ROSA330	15, 22, 24, 26~29, 32, 68, 75, 82, 84, 87, 94, 106~118, 120~122, 128, 141~152
420	031967	J3019. ROSA420	11, 15, 18, 19, 26~29, 32, 62, 82, 93, 106~118, 120~122, 128, 139, 141~150
421	031960	J3019. ROSA421	3, 4, 11, 15~17, 22, 24, 27, 29, 32, 75, 82, 84, 106~118, 120~122, 134, 141~152, 154
422	"	J3019. ROSA422	3, 4, 9, 11, 15~17, 22, 24, 27, 29, 32, 39, 82, 84, 106~118, 120~122, 124, 128, 134, 141~152
423	031967	J3019. ROSA423	11, 15, 18, 22~29, 32, 39, 82~85, 106~118 120~122, 134, 141~154
425	011922	J3019. ROSA425	11, 15~18, 26~29, 32, 33, 39, 84, 94, 106~117 120~122, 134, 137, 138, 141~144, 146~150, 152



Table 23 Elimination Channel Number for Output  
in the Test Data of UHI Assembly

RUN No.	SLTAPE		Elimination channel Number for Each Run
	Vol.	FNAME	
601	011919	J3019. ROSA601	11, 15~17, 26~29, 34(*), 40, 71, 84~90, 93~100, 103~108, 112~114
602	"	J3019. ROSA602	1, 8, 15, 16, 26~35, 40, 71, 74, 75, 86~101 103~114, 119
603	"	J3019. ROSA603	15~17, 20, 26~29, 32, 35, 40, 68, 71, 86~90, 93~101, 103~114, 119
604	"	J3019. ROSA604	15~17, 20, 26~29, 32, 35, 40, 63~66, 71, 77, 86~90, 93~101, 103~108, 112~114, 119
605	"	J3019. ROSA605	15, 16, 20, 26~29, 32, 35, 36, 40, 71, 86~90, 93~101, 103~107, 112~114, 119, 120
606	011918	J3019. ROSA606	15~17, 20, 26~34, 40, 71~75, 86~90, 93~100, 103~107, 112~114, 116
607	"	J3019. ROSA607	15~17, 26~29, 32, 40, 71, 85~90, 93~100, 103~108, 112~114
608	"	J3019. ROSA608	15~17, 26~29, 32, 40, 71, 86~90, 93~100, 103~108, 112~114
609	"	J3019. ROSA609	15~17, 26~29, 32, 40, 71, 86~90, 93~100, 103~108, 112~114
610	"	J3019. ROSA610	3, 4, 15~17, 22, 24, 26, 29, 32, 36, 40, 71, 74, 86~90, 93~100, 103~108, 112~116, 120

(\*) In this case, data of LPCI flow rate (Ch.34) was recorded in the place of Ch.32 by mistake on data acquisition system. Therefore there is no data in Ch.34.

Table 24 Input Data List for Data Processing (RSTEP-1)

Correspond. SLTAPE	Input Data (12I6)							Comment
	Run No.	Data/ sec	Total Ch.	Total Data Points	Reading Black No.	Sampling	NCHDT	
0001RD, 011876	202	50	86	1000	0	10	0	NCHDT=0 (RSTEP-2)
	203	100	86	"	0	23	0	
	303	50	86	"	0	14	0	
	304	50	86	"	0	15	0	
	306	50	86	"	0	15	3	
0002RD, 011875	307	50	86	1000	0	12	0	
	308	50	86	"	0	12	0	
	309	50	86	"	0	29	6	
0003RD, 021874	204	50	86	1000	0	15	5	NCHDT=0 (RSTEP-2)
	301	50	86	"	0	15	0	NCHDT=0 (RSTEP-2)
	302	50	86	"	0	29	3	
0004RD, 021863	401	50	86	1000	0	22	5	Original MT Run No.=400
	403	50	86	"	0	12	0	
	404	50	86	"	0	15	0	
0005RD, 021862	310	100	104	1000	0	17	3	NCHDT=0 (RSTEP-2)
	317	100	104	"	0	24	0	NCHDT=0 (RSTEP-2)
	312	100	104	"	0	12	3	
	313	100	104	"	0	14	2	"
	311	100	104	"	0	22	3	"
0006RD, 011836	411	100	104	1000	0	16	6	NCHDT=0 (RSTEP-2)
	314	100	104	"	0	31	3	
	316	100	104	"	0	31	6	
	315	100	104	"	0	31	0	
0007RD, 011766	318	100	104	1000	0	61	0	
	320	100	104	"	0	61	0	
	321	100	109	"	0	62	0	
	322	100	109	"	0	62	0	
	323	100	109	"	0	62	0	
0008RD, 011971	324	100	112	1000	500	60	0	
	325	100	112	"	0	55	0	
	326	100	112	"	0	62	0	

Table 24 (Cont'd)

Correspond. SLTAPE	Input Data (12I6)							Comment
	Run No.	Data/ sec	Total Ch.	Total Data Points	Reading Block No.	Sampling	NCHDT	
0009RD, 031967	418	50	112	1000	0	29	0	
	419	50	112	"	0	31	0	
	420	50	150	"	0	32	0	
	423	50	150	"	0	31	0	
0010RD, 031960	415	30	112	1000	0	27	6	
	417	30	112	"	0	25	6	
	421	50	150	"	0	30	6	
	422	50	150	"	0	34	6	
0011RD, 011937	327	50	150	1000	0	32	0	
	328	50	150	"	0	32	0	
	329	50	150	"	0	31	0	
	330	50	150	"	0	31	0	
0012RD, 011922	332	50	150	1000	0	33	0	
	413	100	112	"	0	62	0	
	425	50	150	"	0	31	0	
0013RD, 011921	506	50	150	1000	0	30	0	
	502	50	150	"	0	30	0	
	505	50	150	"	0	30	0	
	507	50	150	"	0	30	0	
0014RD, 011919	601	50	112	1000	0	18	0	
	605	50	112	1000	0	18	0	
0015RD, 011918	606	50	112	1000	0	18	0	
	609	50	112	1000	0	18	0	
	610	50	112	1000	0	31	0	

Table 25 An Input Manual of RESTEP-3 &amp; RESTEP3C for the Output of ROSA-II Open Tapes

No.1 Card (20A4) : Title card

The title may be written in the form such as,

ROSA DATA RUN NO. = xxx,

and xxx should be the numerical number of test run.

No.2 Card (12I6) : Required Number for change of axis.

NN2	.....	{	NN2 ≤ 0	No change in the range of axis.
				Then No.3 Cards should be skipped.
			NN2 > 0	Range of axis can be changed.

No.3 Cards (3I3, 3X, 4E12.5) : New set of axis

- |   |      |       |  |  |
|---|------|-------|--|--|
| 1 | NSEQ | ..... | Sequential number                            |  |
| 2 | IC1  | ..... | {  |  |
| 3 | IC2  | ..... |  | Data of channel number IC1~IC2 should be printed             |
|   |      |       |  | using the following new set of axis<br>(1 ≤ IC1 ≤ IC2 ≤ 150) |
| 4 | XR2  | ..... | maximum value of X-axis (Time)               |  |
| 5 | YR1  | ..... | minimum value of Y-axis                      |  |
| 6 | YR2  | ..... | maximum value of Y-axis                      |  |
| 7 | XR1  | ..... | minimum value of X-axis (XR1 should be zero) |  |

No.3 cards are required up to number of NN2.

In the case of NN2 ≤ 0 (on No.2 card) data are printed in the old form of combination of X-Y axis.

No.4 Cards (I3, 1X, 2I1, 2I3) : Output options

Using the following cards, list of digital numerical tables and plotted figures of data may be obtained.

- |   |      |          |  |
|---|------|----------|--|
| 1 | NSEQ | .....    | Sequential number.   |
| 2 | NPRT | .....    | Print option for digital table of data                             |
|   |      | NPRT=0   | ... data in the tape are printed                                   |
|   |      | NPRT≠0   | ... no data in the tape are printed                                |
| 3 | NPLT | .....    | Plot option (COM option) for figures.                              |
|   |      | NPLT(≥1) | sheets of figures are obtained for the following data combination. |

Table 25 (Cont'd)

4 (MCH(i), ISY(i),  $7 \leq i \leq 1$ ) ... data combinations.


"i" set of data which channel numbers are MCH(i) are plotted in the same figure with the different symbols (ISY(i)). Although X range (time) of the first data (i=1) takes precedence to the others, Y ranges may be chosen differently using No.3 cards.

Remarks: Data channel numbers which are possible for output should be referred to a) Standard set of output (Table 10<sup>15</sup>) and, b) Elimination channel number for output (Table 16<sup>23</sup>).

User may appoint any data combinations for output within the above restrictions and then No.4 cards are needed up to the number of data set.

Table 26 Control Cards for the Output of Plotter and Digital Tables

STATEMENT NUMBER	FORTRAN STATEMENT	DECK ID	LINE
5		73	78
6		76	80
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20	T. 4 C. 2 W. 1 P. 0, PLT/		
21			
22			
23	PROGNAME=RSTEP3, EFNAME=J3019.RSTEP3		
24	TAPE F70, J3019. ROSA eee, OLD, VOL = d d d d d d		
25	PLOT		
26	DISK F71		
27	DATA		
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			
51			
52			
53			
54			
55			
56			
57			
58			
59			
60			
61			
62			
63			
64			
65			
66			
67			
68			
69			
70			
71			
72			
73			
74			
75			
76			
77			
78			
79			
80			
81			
82			
83			
84			
85			
86			
87			
88			
89			
90			
91			
92			
93			
94			
95			
96			
97			
98			
99			
100			



\* In the case of many printed tables, W,1 may be exchanged by W.2

\*\* Volume number of opened tape "ddddd" should be the same with volume number on the apply card (Fig.1). Data "ROSAAA" should be contained in the opened tape.

\*\*\* Examples of input data are shown on Fig. 4.

Table 27 Control Cards for the Output of COM and Digital Tables

STATEMENT NUMBER	FORTRAN STATEMENT										DECK			LINE								
	7	10	20	30	40	50	60	70	73	76	78	80										
516	X	X	X	X																		
	N	0				T. 4	C. 2	W. 1	P. 0,	C 35 /												
	G	J	0	B																		
	H	R	U	N		P	R	O	G	R	A	M	E	=	R	S	T	E	P	3	C	
	T	A	P	E		F	7	0,	J	3	0	1	9.	R	O	S	A	e	e	e	*	*
	G	C	O	M	3	5																
	D	A	T	A																		

*** Input Data
-------------------

( \*, \*\*, \*\*\* the same as before)

Table 28 Sample Input Data for Run 419 (RSTEP-3)

	1		2		3		4		5		6		7		8		
	1	2	1	2	1	2	1	2	1	2	1	2	1	2	1	2	
NO	U113		T.4	C.2	W.1	P.0	PLT										
GJOB	411	3019	MI.	SUZUKI	1.931	1.11	RLP4JE								00331		
HRUN	PRGNAME=RSTEP3, EFNNAME=J3019.RSTEP3																
TAPE	F70, J3019.ROSA419, OLD, VOL=031967																
PLOT																	
DISK	F71																
DATA																	
ROSA	DATA RUN NO.=419																
3																	
1	13	13				5.0000E+02	0.0				1.0000E+02	0.0				NO. 1 CARD	
2	14	14				5.0000E+02	-1.0000E-01				9.0000E-01	0.0				NO. 2 CARD	
3	37	41				1.0000E+02	0.0				8.0000E+02	0.0				NO. 3 CARD	
1	12	1				2	2	12	3								NO. 4 CARD
2	01	13															
3	11	14															
4	11	37				38	2	39	3	40	4	41	5				
5	01	72				73	2	83	3								
JEND																	

\* 7.3-7.5: DATAID / 7.6-8.0: SEQUENTIAL NUMBER

共通E.173



Table 29 Program for the Duplication of Open SLTAPE to NLTAPE

STATEMENT NUMBER	FORTRAN STATEMENT										DECK	LINE
56	7	10	20	30	40	50	60	70	73	76	78	80
YNÖ	a	a	a									
XGJÖB			T 3	C 2	W 0	P 0						
YHFÖRT												
			DIMENSION M(20)									
	1		READ (1, 10, END=100) M									
	110		FORMAT (20A4)									
			WRITE (2, 10) M									
			GO TO 1									
	100		ENDFILE 2									
			IF ( N .GE. 2 ) GO TO 200									
			N = N + 1									
			GO TO 1									
	200		STOP									
			END									
XHLIEDRUN												
XSLTAPE	F01. 001, J3019.	RÖSAbbb, ÖLD, VÖL=CCCCC, BSIZE=3200, RSIZE=80, TMÖD=9										
XSLTAPE	F01. 002, J3019.	RÖSAddd, ÖLD, VÖL=CCCCC, BSIZE=3200, RSIZE=80, TMÖD=9,										
			*SPEC= SAME									

共通E174

1										2										3										4										5										6										7										8																																							
*SLTAPE F01.00X,J3019.ROSAIII,OLD,VOL=CCCCC,BSIZE=3200,RSIZE=80,TIMOD=9,																																																																																																													
*SPEC= SAME																																																																																																													
*NLTAPE F02.001,VOL=000YRD,BSIZE=3200,RSIZE=80																																																																																																													
*NLTAPE F02.002,VOL=000YRD,BSIZE=3200,RSIZE=80																																																																																																													
*NLTAPE F02.00X,VOL=000YRD,BSIZE=3200,RSIZE=80																																																																																																													
*JEND																																																																																																													
x : number of test runs (from bbb to 111) recorded in the SLTAPE (VOL NO=cccccc) kept in the calculation center of JAERI.																																																																																																													
y : Sequential number of NLTAPE brought into the calculation center to duplicate SLTAPE.																																																																																																													
1 2 3 4 5 6 7 8 9 0										1 2 3 4 5 6 7 8 9 0										1 2 3 4 5 6 7 8 9 0										1 2 3 4 5 6 7 8 9 0										1 2 3 4 5 6 7 8 9 0										1 2 3 4 5 6 7 8 9 0										1 2 3 4 5 6 7 8 9 0										1 2 3 4 5 6 7 8 9 0																																							

\* 73-75 : DATAID / 76-80 : SEQUENTIAL NUMBER

共通E173

Table 30 List of ROSA-II Test Runs

Run No.	Break Condition		Assem- bly No.	Core Power Control		Temperature of Op. Loop		Pump Duration(s)		Injection Location			Sec. Sys. Blow No.	Data Rep. No.			
	Position	Type		Initial L.P.D. H.F.R./L.F.R.(%)	Variat. H./L.	H.Leg	C. Leg	HPCI	LPCI	ACC							
Facility Performance Test																	
202	C	D.E	30.5/30.5	1	13.8/1.69	d/c	327	324	-	-	-	-	-	X	1		
203	C	D.E	30.5/30.5	1	13.8/1.69	d/c	327	324	-	HC	-	H	-	C	X	1	
204	C	S.E	0/30.5	1	13.8/1.73	d/c	295	292	-	H	-	H	-	H	X	3	
Parametric Test																	
301	C	S.E	30.5/0	1	13.8/1.36	d/c	310	307	-	-	-	-	-	-	X	3	
302	C	S.E	30.5/0	1	13.1/1.72	d/c	312	309	-	L	L	L	-	L	X	3	
303	C	D.E	30.5/30.5	1	13.8/2.08	d/c	325	322	-	HC	-	H	-	C	O	1	
304	C	D.E	30.5/30.5	1	13.8/2.03	d/c	310	307	-	-	HC	-	H	-	C	X	1
306	C	D.E	30.5/30.5	2	38.9/4.44	c/c	312	306	-	-	HC	-	H	-	C	O	1
307	C	D.E	37.5/37.5	1	29.1/7.41	d/c	318	309	-	-	-	H	H	C	C	X	2
308	C	D.E	37.5/37.5	1	29.1/7.70	d/c	313	304	-	-	-	-	-	C	C	X	2
309	C	D.E	37.5/37.5	1	29.1/7.63	d/c	313	304	-	-	-	H	H	-	-	X	2
310	C	D.E	37.5/37.5	3	15.5/15.5	n/n	321	310	-	-	-	C	C	C	C	X	5
311	C	D.E	37.5/37.5	3	15.5/15.5	n/n	319	307	-	-	-	C	C	-	-	X	5

Abbreviations; LPD-Linear Power Density at peak point, H.F.R.-High Flux Rod, L.F.R.-Low Flux Rod  
 D.E - Double Ended, S.E - Single Ended, Sp. - Split, Dis. - Distributed  
 H - Hot leg, C - Cold leg, U - Upper plenum, L - Lower plenum  
 d - decay heat, n - d + delayed neutron, S - n + stored heat release, C - constant

Table 30 List of ROSA-II Test Runs (cont'd)

Run No.	Break Condition		Assem- bly No.	Core Power Control		Temperature of Op. Loop		Pump Dura- tion(s)	Injection Location			Sec. Data Sys. Rep. Blow No.			
	Posi- tion	Type		Initial H.F.R./ L.F.R.	L.P.D Variat. H./L.	H.Leg	C.Leg		HPCI	LPCI	ACC				
312	C	D.E	3	15.5/15.5	n/n	318	306	-	-	C	C	C	X	5	
313	C	Dis.	3	15.5/15.4	n/n	314	302	-	-	C	C	C	X	5	
314	C	D.E	3	15.5/15.4	n/n	313	302	-	-	C	L	C	L	X	6
315	C	Dis.	3	22.6/0	n/n	302	298	-	-	C	L	C	L	X	6
316	C	D.E	4	25.5/20.4	n/n	316	298	-	-	H	H	-	U	X	6
317	C	D.E	4	15.5/15.5	n/n	312	300	-	-	H	H	C	C	X	5
318	C	Dis.	4	3.69/3.80	o/o	302	299	-	HC	HC	H	H	C	C	7
320	C	Dis.	4	15.4/15.5	n/n	315	304	-	HC	HC	H	H	C	C	7
321	C	Sp.	4	15.0/15.3	n/n	313	301	-	HC	HC	H	H	C	C	7
322	C	Sp.	4	15.4/15.5	n/n	319	307	15	HC	HC	H	H	C	C	7
323	C	Dis.	4	15.3/15.3	n/n	314	302	15	HC	HC	H	H	C	C	7
324	C	D.E	3A	24.9/20.9	n/n	308	298	-	-	C	C	C	C	X	8
325	C	D.E	3A	24.6/21.0	n/n	310	300	-	-	C <sup>t</sup>	C <sup>t</sup>	C <sup>t</sup>	C <sup>t</sup>	C <sup>t</sup>	8
326	C	D.E	3A	24.4/21.1	n/n	306	296	-	-	C	C	C	C	X	8
327	H	Dis.	5	17.9/18.0	n/n	324	296	-	-	H	H	C	C	X	11
328	H	Dis.	5	17.7/17.1	n/n	324	296	-	-	H	H	C	C	X	11
329	H	Dis.	5	17.9/17.6	n/n	323	300	15	-	H	H	C	C	X	11
330	H	Dis.	5	17.8/17.4	n/n	312	292	15	-	H	H	C	C	X	11
332	C	D.E	4	26.3/19.9	n/o	325	295	-	-	-	-	-	-	X	12

Table 30 List of ROSA-II Test Runs (cont'd)

Run No.	Break Condition		Assembly No.	Core Power Control		Temperature of Op. Loop		Pump Duration	Injection Location					Sec. Sys. Blow No.			
	Position	Diameter (mm)		Initial H.F.R./L.F.R. (kW)	L.P.D. Variat. H/L	H-Leg	C-Leg		HPCI	LPCI	ACC						
											1	2	1		2		
Actual Reactor Simulation Test																	
401	C	D.E	30.5/30.5	1	13.8/2.07	d/c	311	308	-	HC	HC	H	H	C	C	X	4
403	C	D.E	37.5/37.5	1	29.1/7.74	d/c	317	308	-	-	-	-	-	-	-	X	4
404	C	D.E	37.5/37.5	1	29.1/7.67	d/c	315	306	-	HC	HC	H	H	C	C	X	4
411	C	D.E	37.5/37.5	3	15.5/16.4	n/n	332	319	-	-	-	H	H	C	C	X	6
413	C	D.E	37.5/37.5	4	25.0/20.2	n/n	328	293	-	-	-	H	H	C	C	X	12
415	C	Sp.	- /16.5	4	24.5/20.3	n/n	324	300	-	-	-	H	H	C	C	X	10
417	C	Sp.	- /16.5	4	24.4/20.1	n/n	323	302	-	HC	HC	H	H	C	C	X	10
418	H	D.E	37.5/37.5	4	24.8/20.2	n/n	324	300	-	-	-	-	-	-	-	X	9
419	H	D.E	37.5/37.5	4	24.9/20.3	n/n	318	295	-	-	-	H	H	C	C	X	9
420	H	D.E	37.5/37.5	5	17.9/17.3	n/n	320	302	-	-	-	C	C	C	C	X	9
421	H	Sp.	- /16.5	5	17.8/17.6	n/n	318	303	-	HC	HC	H	H	C	C	X	10
422	H	Sp.	- /16.5	5	17.8/17.6	n/n	315	295	-	HC	HC	H	H	C	C	O	10
423	H	D.E	37.5/37.5	5	17.7/17.8	n/n	312	294	15	-	-	H	H	C	C	X	9
425	C	D.E	37.5/37.5	5	16.9/17.5	n/n	313	297	15	-	-	H	H	C	C	X	12

Table 30 List of ROSA-II Test Runs (cont'd)

Run No.	Break Condition		Assem- bly No.	Core Power Control		Temperature of Op. Loop		Pump Dura- tion(s)	Injection Location			Sec. Sys. Rep. Blow No.	Data		
	Posi- tion	Diameter (mm)		Initial H.F.R./L.F.R. (W)	Varia- tion H/L	H-Leg	C-Leg		HPCI	LPCI	ACC				
Alternative ECCS Test															
502	C	D.E	37.5/37.5	4	24.7/18.6	n/n	312	289	-	-	-	L	H	X	13
505	C	D.E	37.5/37.5	4	24.8/19.8	n/n	311	287	-	-	-	H	U*	X	13
506	C	D.E	37.5/37.5	4	25.1/19.8	n/n	315	288	-	-	-	C	C	X	13
507	C	D.E	37.5/37.5	4	24.8/19.8	n/n	314	291	-	-	-	H	U <sup>†</sup>	X	13
U. H. I System Performance Test															
601	C	D.E	37.5/37.5	UHI	15.4/16.4	n/n	327	302	-	-	-	C	C	X	
602*	C	D.E	37.5/37.5	UHI	16.3/16.2	s/s	324	300	-	-	-	-	-	X	
603*	C	D.E	37.5/37.5	UHI	9.04/9.04	s/s	323	305	-	-	-	C	C	X	6707
604	C	D.E	37.5/37.5	UHI	9.04/9.04	s/s	325	307	-	-	-	C	C	X	6707
607	C	D.E	37.5/37.5	UHI	0/0	o/o	304	304	-	-	-	C	C	X	
606	C	D.E	37.5/37.5	UHI	15.8/15.5	s/s	325	301	-	-	-	C	C	X	
607	C	D.E	37.5/37.5	UHI	16.6/15.4	s/s	322	298	-	-	-	C	C	X	6707
608	C	D.E	37.5/37.5	UHI	15.6/15.2	s/s	319	295	-	-	-	C	C	X	6707
609	C	D.E	37.5/37.5	UHI	15.6/15.4	s/s	322	298	-	-	-	C	C	X	6707
610	C	Sp.	- /16.5	UHI	15.6/15.4	s/s	321	297	-	-	C	C	C	X	6707

Note 1) Pump nozzle in the blowdown loop was remodeled after RUN 324 and RUN 411.

2) Venturi throat in the blowdown loop was removed after RUN 502.

\* Newly made accumulator was attached to the upper plenum.

† Enlarged injection flow rate was employed. \* without UHI injection.

Table 31 Program List of RSTEP-3

ISN	ST-NO	SOURCE PROGRAM
1		DEFINEFILE 71(260,1100,U,19ZZ)
2		COMMON/DFILE/ 19ZZ
3		COMMON/PLOT/COMENT(6),NRUN,XRANG1,XRANG2,YRANG1,YRANG2, * BREAK(2),BRKD1,BRKD2,NANO,HP1(2),HP2(2),AC1(2),AC2(2), * LP1(2),LP2(2),NEJCT,ISCAL,NSYMB,SYMB,GAGE(5),JCH
C		COMMON/ROSA/NOTEST,DT,MAXCH,MAXTIM,ICH,TIM(1024),DAT(1024)
C		COMMON/TEST/SYB(260),COF1(260),COF2(260),GAG(5,260),COMT(6,260)
C		* ,XXR2(260),YYR1(260),YYR2(260)
C		DIMENSION MCH(7),ISC(7),ISY(7),NTB(7)
4		COMMON/ROSA/NOTEST,DT,MAXCH,MAXTIM,ICH ,TIM (1024),DAT (1024), * NCT(8),TCW,IZ,WD1(1000),WD2(1000),X1(1000),X2(1000), * DATA(8,1024),TL1,TL2,TS1,TS2
C		* DATA(8,1024),TL1,TL2
5		COMMON/TEST/SYB(260),COF1(260),COF2(260),GAG(5,260),COMT(6,260)
		* ,XXR2(260),YYR1(260),YYR2(260),NTB(6,20),CONT1,CONT2
		* ,XXR1(260)
6		DIMENSION MCH(7),ISC(7),ISY(7)
7		DIMENSION ECC(2)
C		COMMON/CONT/CONT1,CONT2
8		COMMON/MTOUT/NN3,NZRC,NDUM,ECC,TITLE(20)
9		READ (5,8200) TITLE
10	8200	FORMAT(20A4)
11		WRITE (6,9200) TITLE
12	9200	FORMAT(1H1,'ROSA PLOT ROUTINE',10X,'TITLE --- (1,20A4,1)')
13		CALL MTDUMP
14		READ (5,8000) NN2
15		IF(NN2.LE.0) GO TO 2015
16		DO 2010 I=1,NN2
17		READ (5,8060) NDZM,IC1,IC2,XR2,YR1,YR2,XR1
18	8060	FORMAT(3I3,3X,4E12,5)
19		DO 2005 J=IC1,IC2
20		XXR1(J) = XR1
21		XXR2(J) = XR2
22		YYR1(J) = YR1
23		YYR2(J) = YR2
24	2005	CONTINUE
25	2010	CONTINUE
26		*WRITE (6,9210)
27	9210	FORMAT(1H1,'HENKAN SARETA TABLE')
28		MAXXX = MAXCH+NN3
29		DO 2006 J=1,MAXXX
30	2006	WRITE (6,9220) J,XXR1(J),XXR2(J),YYR1(J),YYR2(J)
31	9220	FORMAT(1X,15,5X,1P+E10,3)
32	2015	KCZ=NDUM
33	8050	FORMAT(13,1X,A4,2E10,3,5A4,6A4)
C		TIMES SET
34		DO 1010 I=1,MAXTIM
35		TIM(I)=DT* FLOAT(I-KCZ)
36	1010	CONTINUE
37		*WRITE (6,8040) TIM
38		NNMM = 0
39		WRITE (6,9240) TITLE
40	9240	FORMAT(1H1,'DATA PLOT START',10X,20A4)
41	1005	READ (5,8070,END=4500) NSQ1,NPRT,NPLT,(MCH(I),ISY(I),I=1,7)
42		NNMM = NNMM+1
43		*WRITE (6,9230) NNMM
44	9230	FORMAT(//1X,'PLOT NUMBER ----- ',15)

```

ISN   ST-NO          SOURCE PROGRAM      ( FTMAIN )
45     DO 3100  I=1,7
46     ISC(I)= 1
47     3100 CONTINUE
48     ISC(1)= 1
49     LLL = 1
50     DO 3110  I=2,7
51     MCHI = MCH(I)
52     IF(MCHI.EQ.0) GO TO 3110
53     DO 3111  J=1,I-1
54     MCHJ = MCH(J)
55     DO 3115  M=1,5
56     IF(GAG(M,MCHI).NE.GAG(M,MCHJ)) GO TO 3111
57     3115 CONTINUE
58     IF(YR1(MCHI).NE.YR1(MCHJ) ) GO TO 3111
59     IF(YR2(MCHI).NE.YR2(MCHJ) ) GO TO 3111
60     ISC(I)=ISC(J)
61     GO TO 3110
62     3111 CONTINUE
63     LLL = LLL+1
64     ISC(I) = LLL
65     3110 CONTINUE
66     DO 3113  I=2,7
67     IF(ISC(I).NE.1) GO TO 3114
68     3113 CONTINUE
69     ISC(1)=2
70     3114 CONTINUE
71     DO 3003  KK=1,NPLT
72     WRITE (5,9250)      (MCH(K),K=1,7),(ISY(K),K=1,7)
73     9250 FORMAT(1X,'PLOT CHANNEL --- ',7I6/
*          1X,'PLOT SYMBOL --- ',7I6)
74     NEJCT = 1
75     DO 3000  K=1,7
76     JCH = MCH(K)
77     IF(JCH.EQ.0) GO TO 3000
78     DO 3001  L=1,6
79     3001 COMENT(L)=COMT(L,JCH)
80     DO 3002  L=1,5
81     3002 GAGE(L)=GAG(L,JCH)
C      XRANG1 = 0.
C      XRANG2 = XXR2(JCH)
82     IF(K.EQ.1)          XR1JCH=XXR1(JCH)
83     IF(K.EQ.1)          XR2JCH=XXR2(JCH)
84     XRANG1 = XR1JCH
85     XRANG2 = XR2JCH
86     YRANG1 = YR1(JCH)
87     YRANG2 = YR2(JCH)
88     SYMB = SYB(JCH)
89     NSYMB = ISY(K)
90     ISCAL = ISC(K)
91     DO 1020  I=1,MAXTIM
92     NA = I-1
93     IF(TIM(I).GE.XRANG2) GO TO 1030
94     NA = I
95     1020 CONTINUE
96     1030 CONTINUE
97     NB = KCZ-30
98     IF(NB.LE.0) NB=1

```



ISN	ST-NO	SOURCE PROGRAM	( FTMAIN )
99		NDMAX=NA-NB+1	
100		WRITE (6,8090)	NDMAX
101		19ZZ=JCH	
102		FIND (71'19ZZ)	
103		READ (71'19ZZ)	(DAT(J),J=1,MAXTIM)
104		IF(NPRT.NE.0)	WRITE(6,9000) JCH,(DAT(J),J=1,MAXTIM)
105		CALL	GRAF(TIM(NB),DAT(NB),NDMAX)
106		NEJCT	= 0
107	3000	CONTINUE	
108	3003	CONTINUE	
109		GO TO	1005
110	4500	CALL PLOT(0.,0.,999)	
111	8000	FORMAT(12I6)	
112	8010	FORMAT(6E12.5)	
113	8020	FORMAT(20A4)	
114	8030	FORMAT(I3,3I1,3E10.3,5A4,6A4)	
115	8040	FORMAT(1H1,'SET OF TIME'/(1X,1P10E13.5))	
116	8070	FORMAT(I3,1X,2I1,22I3)	
117	8080	FORMAT(10I12)	
118	9000	FORMAT(//1X,'CHANNEL = ',I4/(1X,1P10E13.5))	
119	5000	STOP	
120		END	

```

ISN  ST-NO      SOURCE PROGRAM
1      SUBROUTINE GRAF (XA,YA,NDMAX)
2      COMMON/PLOT/COMENT(6),NRUN,XRANG1,XRANG2,YRAN 1,YRAN 2,
*      BREAK(2),BRKD1,BRKD2,NANO,HP1(2),HP2(2),AC1(2),AC2(2),
*      LP1(2),LP2(2),NEJCT,ISCAL,NSYMB,SYMB,GAGE(5),JCH
3      DATA      XLO /100./,YLO / 15./,XL1 /250./,YL1 /180./,
*      XL2 / 40./,YL2 / 35./,XL3 /160./,YL3 /100./,
*      XL4 / 10./,YL4 / 20./
4      DIMENSION  XA(NDMAX),YA(NDMAX)
5      DIMENSION  BUF(1024)
6      DATA      NPAGE/0/,NLQC/1024/,NMOJI/20/
C      PLOTTER INITIALIZE
7      YRANG1 = YRAN1
8      YRANG2 = YRAN2
9      NJYO = 0
10     IF (NEJCT.EQ.0) GO TO 2000
11     NTIMES = 0
12     NPAGE = NPAGE+1
13     XL = XLO+XL1
14     IF (NPAGE.NE.1) GO TO 1000
15     CALL      PASS(1)
16     CALL      PLOT      (BUF      ,NLQC      )
17     CALL      PLOT      (0.      ,YLO      , -3      )
18     XL = XLO
19     1000 CALL      PLOT      (XL      ,0.      , -3      )
C      FLAME
20     CALL      PLOT      (XL1      ,0.      , 2      )
21     CALL      PLOT      (XL1      ,YL1      , 2      )
22     CALL      PLOT      (0.      ,YL1      , 2      )
23     CALL      PLOT      (0.      ,0.      , 2      )
C      VERTICAL LINE.
24     YP1 = YL2
25     YP2 = YL2+YL3
26     XD = XL3/8.
27     XP = XL2+XL4
28     DO 1010 I=1,8
29     CALL      PLOT      (XP      ,YP1      , 3      )
30     CALL      PLOT      (XP      ,YP2      , 2      )
31     XP = XP+XD
32     1010 CONTINUE
C      HORIZONTAL LINE.
33     XP1 = XL2
34     XP2 = XL2+XL3
35     YD = YL3/5.
36     YP = YL2
37     DO 1020 I=1,5
38     CALL      PLOT      (XP1      ,YP      , 3      )
39     CALL      PLOT      (XP2      ,YP      , 2      )
40     YP = YP+YD
41     1020 CONTINUE
C      TITLE 1.
42     HP = 3.
43     YP = 170.
44     CALL      SYMBOL      ( 25.,YP      ,HP,4HRUN      ,0., 4)
45     FLOAT = NRUN
46     CALL      NUMBER      (999.,999.,HP,FLOAT      ,0., -1)
47     CALL      SYMBOL      ( 58.,YP      ,HP,BREAK      ,0., 8)
48     CALL      SYMBOL      (999.,999.,HP,6H BREAK      ,0., 6)

```

```

ISN  ST-NO          SOURCE PROGRAM      ( GRAF  )
49      CALL      SYMBOL      (109.,YP,HP,15HBREAK DIAMETER ,0.,15)
50      CALL      NUMBER      (999.,999.,HP,BRKD1      ,0., 1)
51      CALL      SYMBOL      (999.,999.,HP,1H/      ,0., 1)
52      CALL      NUMBER      (999.,999.,HP,BRKD2      ,0., 1)
53      CALL      SYMBOL      (999.,999.,HP,3H MM      ,0., 3)
54      CALL      SYMBOL      (193.,YP ,HP,3HNO      ,0., 3)
55      FLOAT    = NANO
56      CALL      NUMBER      (999.,999.,HP,FLOAT      ,0.,-1)
57      CALL      SYMBOL      (999.,999.,HP,9H ASSEMBLY,0., 9)
C      TITLE 2.
58      HP      = 2.
59      YP      = 163.
60      CALL      SYMBOL      ( 25.,YP ,HP,8HECCS ---,0., 8)
61      CALL      SYMBOL      ( 55.,YP ,HP,4HHP1-      ,0., 4)
62      CALL      SYMBOL      (999.,999.,HP,HP1(1)      ,0., 8)
63      CALL      SYMBOL      ( 85.,YP ,HP,4HHP2-      ,0., 4)
64      CALL      SYMBOL      (999.,999.,HP,HP2(1)      ,0., 8)
65      CALL      SYMBOL      (115.,YP ,HP,4HAC1-      ,0., 4)
66      CALL      SYMBOL      (999.,999.,HP,AC1(1)      ,0., 8)
67      CALL      SYMBOL      (150.,YP ,HP,4HAC2-      ,0., 4)
68      CALL      SYMBOL      (999.,999.,HP,AC2      ,0., 8)
69      CALL      SYMBOL      (175.,YP ,HP,4HLP1-      ,0., 4)
70      CALL      SYMBOL      (999.,999.,HP,LP1(1)      ,0., 8)
71      CALL      SYMBOL      (205.,YP ,HP,4HLP2-      ,0., 4)
72      CALL      SYMBOL      (999.,999.,HP,LP2(1)      ,0., 8)
C      X-SCALE
73      CALL      PASS(8)
74      YP1     = YL2+0.5
75      YP2     = YL2-0.5
76      XD      = XL3/16.
77      XP      = XL2
78      XRD     = (XRANG2-XRANG1)/15.
79      XRG     = XRANG1-XRD
80      DO 1030 I=1,17
81      CALL      PLOT      (XP ,YP1 ,3      )
82      CALL      PLOT      (XP ,YP2 ,2      )
83      IF(MOD(I,2).EQ.0) CALL NUMBER(XP,YL2-3.,2.,XRG,0.,-1)
84      XRG     = ARG+XRD
85      XP      = XP+XD
86      1030 CONTINUE
87      XP      = XL2
88      YP3     = YL2+YL3+0.5
89      YP4     = YL2+YL3-0.5
90      DO 1040 I=1,17
91      CALL      PLOT      (XP ,YP3 ,3      )
92      CALL      PLOT      (XP ,YP4 ,2      )
93      XP      = XP+XD
94      1040 CONTINUE
C      X=TITLE.
95      CALL      PASS(9)
96      XP      = XL2+65.
97      YP      = YL2-8.
98      HP      = 3.
99      CALL      SYMBOL      (XP,YP,HP,12HTIME      (SEC),0.,12)
C      Y-SCALE
100     HHP1    = 2.
101     HHP2    = 3.

```

```

ISN      ST-NO      SOURCE PROGRAM      ( GRAF )
102      XXPR      = XL2+XL3
103      XXPL      = XL2
104      YYP1      = YL2
105      YYP2      = YL2+YL3
106      WID1      = 1.
107      WID2      = 1.
108      WID3      = 1.
109      WID4      = 1.
110      WIDE      = 25.
111      NYSCAL    = 0
112      NNSCAL    = 0
113      2000      IF(ISCAL.LT.NNSCAL+1) GO TO 2200
114      NNSCAL    = NNSCAL+1
115      2005      NYSCAL    = NYSCAL+1
116      IF(YRANG2.LT.0.9995E4) GO TO 2007
117      2006      NJYO     = NJYO+1
118      YRANG1    = YRANG1/10.
119      YRANG2    = YRANG2/10.
120      IF(YRANG2.GT.9.995) GO TO 2006
121      2007      CONTINUE
122      YRD       = (YRANG2-YRANG1)/10.
123      NRL       = MOD (NYSCAL,2)
124      KETA      = 1
125      IF(YRD.GE.0.995) KETA = -1
126      MOJI      = ALOG10(YRANG2+0.005)+1.005
127      IF(KETA.EQ.1) MOJI = MOJI+2
128      IF(YRANG1.LT.0.) MOJI = MOJI+2
129      YRNG      = YRANG1
C
130      IF(NRL.EQ.0) GO TO 2100
131      CALL      PLOT      (XXPR,YYP1,3)
132      CALL      PLOT      (XXPR,YYP2,2)
133      XP1       = XXPR+0.5
134      XP2       = XXPR-0.5
135      YD        = YL3/10.
136      YP        = YL2
137      CALL      PASS(7)
138      DO 2010 I=1,11
139      CALL      PLOT      (XP1,YP,3)
140      CALL      PLOT      (XP2,YP,2)
141      XP3       = XP1+WID1
142      YP3       = YP-HHP1/2.
143      CALL      NUMBER    (XP3,YP3,HHP1,YRNG,0.,KETA)
144      YRNG      = YRNG+YRD
145      YP        = YP+YD
146      2010      CONTINUE
147      XP4       = XXPR+WID1+MOJI*HHP1+WID2+HHP2
148      IF(NJYO.EQ.0) GO TO 2011
149      YP4       = WIDE+YYP1+13.*HHP2*6./7.
150      FLN       = NJYO
151      CALL      SYMBOL    (XP4,YP4,HHP2,4HX 10,90.,4)
152      CALL      NUMBER    (XP4-HHP2*0.5,YP4+4.*HHP2*6./7.,HHP2*0.5,FLN,
*          90.,-1)
153      XP4       = XP4+WID4+HHP2
154      2011      CONTINUE
155      YP4       = WIDE+YYP1
156      CALL      SYMBOL    (XP4 ,YP4 ,HHP2,GAGE(1),90.,12)

```

```

ISN   ST-NO          SOURCE PROGRAM      ( GRAF )
157   CALL          SYMBOL      (999.,999.,HHP2,1H      ,90., 1)
158   CALL          SYMBOL      (999.,999.,HHP2,GAGE(4),90., 8)
159   CALL          SYMBOL      (999.,999.,HHP2,1H      ,90., 1)
160   FLN           =  NNSCAL
161   HHP3          =  2.
162   CALL          NUMBER      (999.,999.,HHP3,FLN      ,90.,-1)
163   XXPR          =  XP4+WID3
164   IF(CISCAL.EQ.2.AND.NEJCT.NE.0) GO TO 2005
165   GO TO 2200
C
166   2100 CALL      PLOT        (XXPL,YYP1,3)
167   CALL          PLOT        (XXPL,YYP2,2)
168   XP1           =  XXPL+0.5
169   XP2           =  XXPL-0.5
170   YD            =  YL3/10.
171   YP            =  YL2
172   CALL          PASS(5)
173   DO 2110 I=1,11
174   CALL          PLOT        (XP1,YP,3)
175   CALL          PLOT        (XP2,YP,2)
176   XP3           =  XP1/WID1=MOJ1*HHP1
177   YP3           =  YP-HHP1/2.
178   CALL          NUMBER      (XP3,YP3,HHP1,YRNG,0.,KETA)
179   YRNG          =  YRNG+YRD
180   YP            =  YP+YD
181   2110 CONTINUE
182   CALL          PASS(5)
183   XP4           =  XXPL-WID1=MOJ1*HHP1-WID2
184   IF(NJYO.EQ.0) GO TO 2111
185   YP4           =  WIDE+YYP1+13.*HHP2*6./7.
186   FLN           =  NJYO
187   CALL          SYMBOL      (XP4,YP4,HHP2,4HX 10,90., 4)
188   CALL          NUMBER      (XP4-HHP2*0.5,YP4+4.*HHP2*6./7.,HHP2*0.5,FLN,
*          90.,-1)
189   XP4           =  XP4-WID4-HHP2
190   2111 CONTINUE
191   YP4           =  WIDE+YYP1
192   CALL          SYMBOL      (XP4 ,YP4 ,HHP2,GAGE(1),90.,12)
193   CALL          SYMBOL      (999.,999.,HHP2,1H      ,90., 1)
194   CALL          SYMBOL      (999.,999.,HHP2,GAGE(4),90., 8)
195   CALL          SYMBOL      (999.,999.,HHP2,1H      ,90., 1)
196   FLN           =  NNSCAL
197   HHP3          =  2.
198   CALL          NUMBER      (999.,999.,HHP3,FLN      ,90.,-1)
199   XXPL          =  XP4-HHP2-WID3
C
200   2200 COMMENT PLOT
201   NTIMES        =  NTIMES+1
202   YRANG1        =  YRAN1
203   YRANG2        =  YRAN2
204   CALL          PASS(4)
205   XPX           =  25.
206   PHP           =  2.
207   MODET         =  MOD(NTIMES,2)
208   IF(MODET.EQ.1) XPY=157.-3.*(NTIMES/2)
209   IF(MODET.EQ.0) XPX = 125.
210   YDW           =  5.
211   CALL          SYMBOL      (XPX ,XPY ,PHP,3HCH= ,0., 3)

```

```

ISN   ST-NO          SOURCE PROGRAM      ( GRAF )
211   FLN           = JCH
212   IF(JCH,LE,99) CALL SYMBOL(999.,999.,PHP,1H ,0.,1)
213   IF(JCH,LE,9)  CALL SYMBOL(999.,999.,PHP,1H ,0.,1)
214   CALL          NUMBER (999.,999.,PHP,FLN ,0.,-1)
215   CALL          SYMBOL (999.,999.,PHP,2H ,0.,2)
216   XXX          = XPX+8.,*PHP*6./7.
217   CALL          SYMBOL (XXX+0.43*PHP,XPY+0.5*PHP,PHP,NSYMB,0.,-1)
218   XXX          = XXX +0.90*PHP
219   FLN          = ISCAL
220   IF(ISCAL.E0.2.AND.MNSCAL.E0.1) FLN=1,
221   CALL          NUMBER (XXX ,XPY ,PHP ,FLN ,0.,-1)
222   CALL          SYMBOL (999.,999.,PHP ,2H ,0.,2)
223   CALL          SYMBOL (999.,999.,PHP ,SYMB ,0.,4)
224   CALL          SYMBOL (999.,999.,PHP ,3H ( ,0.,3)
225   CALL          SYMBOL (999.,999.,PHP ,COMENT ,0.,24)
226   CALL          SYMBOL (999.,999.,PHP ,1H) ,0.,1)
C     DATA PLOT AND CENTERED SYMBOL
227   YLENG        = YRANG2-YRANG1
228   XLENG        = XRANG2-XRANG1
229   NPEN         = 3
230   XD           = XL3/8,
231   HP           = 2,
232   YP           = XL2+XL4+HP*(NTIMES-1)
233   CALL          PASS(3)
234   DO 2300 I=1,NDMAX
235   XX=(XA(I)-XRANG1)/XLENG*(XL3-XL4)+XL2+XL4
236   YY=(YA(I)-YRANG1)/YLENG*YL3+YL2
237   IF(XX,LT,XL2 ) GO TO 2300
238   IF(XX,GT,XL2+XL3) GO TO 2300
239   IF(YY,GT,YL2+YL3) YY=YL2+YL3
240   IF(YY,LT,YL2 ) YY=YL2
241   CALL          PLOT (XX ,YY ,NPEN )
242   NPEN         = 2
243   IF(YP,GT,XX) GO TO 2300
244   CALL          SYMBOL (XX ,YY ,HP ,NSYMB,0.,-1)
245   CALL          PLOT (XX ,YY ,3 )
246   YP          = YP+XD
247   2300 CONTINUE
C     PLOT TERMINATED
248   RETURN
249   END

```

```

ISN  ST-NO      SOURCE PROGRAM
1      SUBROUTINE MTDUMP
2      COMMON/DFILE/ 19ZZ
3      COMMON/MTOUT/ NN3,N9RC,NDUM,EEC(2),TITLE(20)
4      COMMON/PLOT/COMENT(6),NRUN,XRANG1,XRANG2,YRANG1,YRANG2,
*      BREAK(2),BRKD1,BRKD2,NAND,HP1(2),HP2(2),AC1(2),AC2(2),
*      LP1(2),LP2(2),NEJCT,ISCAL,NSYMB,SYMB,GAGE(5),JCH
5      COMMON/ROSA/NOTEST,DT,MAXCH,MAXTIM,JCH ,TIM(1024),DAT(1024),
*      NCT(8),TCW,IZ,WD1(1000),WD2(1000),X1(1000),X2(1000),
*      DATA(8,1024),TL1,TL2,TS1,TS2
6      C
*      COMMON/TEST/SYB(260),COF1(260),COF2(260),GAG(5,260),COMT(6,260),
*      XAR2(260),YYR1(260),YYR2(260),NTB(6,20),CONT1,CONT2,
*      AA(260)
7      DATA N1,N2,N3/12,10,16/
8      WRITE (6,59)
9      59 FORMAT(//1X,'INPUT TABLE LIST')
10     READ (70,10)      TITLE
11     10 FORMAT(20A4)
12     WRITE (6,60)      TITLE
13     60 FORMAT(1X,20A4)
14     READ (70,11) NOTEST,N1,N2,N3,MAXCH,NN3,MAXTIM
15     11 FORMAT(16I5)
16     WRITE (6,61) NOTEST,N1,N2,N3,MAXCH,NN3,MAXTIM
17     61 FORMAT(1X,16I5)
18     READ (70,11)  NRUN,NAND,N9RC,NDUM,NCT
19     WRITE (6,61)  NRUN,NAND,N9RC,NDUM,NCT
20     READ (70,13) BRKD1,BRKD2,DT,CONT1,CONT2,TCW,TL1,TL2,TS1,TS2
21     13 FORMAT(1P8E10,3)
22     WRITE (6,63) BRKD1,BRKD2,DT,CONT1,CONT2,TCW,TL1,TL2,TS1,TS2
23     63 FORMAT(1X,1P8E10,3)
24     READ (70,15) EEC,BREAK,HP1,HP2,AC1,AC2,LP1,LP2
25     15 FORMAT(8(2X,2A4))
26     WRITE (6,65) EEC,BREAK,HP1,HP2,AC1,AC2,LP1,LP2
27     65 FORMAT(1X,8(2X,2A4))
28     DO 21 I=1,MAXCH
29     JCH=I
30     READ (70,17) JCH,SYB(JCH),COF1(JCH),COF2(JCH),(GAG(J,JCH),J=1,5),
*      (COMT(J,JCH),J=1,6),NROSA,NUMB
31     21 WRITE (6,67) JCH,SYB(JCH),COF1(JCH),COF2(JCH),(GAG(J,JCH),J=1,5),
*      (COMT(J,JCH),J=1,6),NROSA,NUMB
32     17 FORMAT(13,1X,A4,1P2E10,3,5A4,6A4, A4,I4)
33     67 FORMAT(1X,13,1X,A4,1P2E10,3,5A4,6A4, A4,I4)
34     DO 23 I=1,NN3
35     JCH=1+MAXCH
36     READ (70,19) JCH,SYB(JCH),(NTB(J,I),J=1,6),(GAG(J,JCH),J=1,5),
*      (COMT(J,JCH),J=1,6),NROSA,NUMB
37     23 WRITE (6,69) JCH,SYB(JCH),(NTB(J,I),J=1,6),(GAG(J,JCH),J=1,5),
*      (COMT(J,JCH),J=1,6),NROSA,NUMB
38     19 FORMAT(13,1X,A4,1X,6I3,1X,5A4,6A4, A4,I4)
39     69 FORMAT(1X,13,1X,A4,1X,6I3,1X,5A4,6A4, A4,I4)
40     J1=MAXCH+NN3
41     DO 25 I=1,J1
42     JCH = I
43     READ(70,31) JCH,AA(JCH),XXR2(JCH),YYR1(JCH),YYR2(JCH),NROSA,NUMB
44     25 WRITE(6,81) JCH,AA(JCH),XXR2(JCH),YYR1(JCH),YYR2(JCH),NROSA,NUMB
45     31 FORMAT(15,5X,1P4E10,3,22X,A4,I4)
46     81 FORMAT(1X,15,5X,1P4E10,3,22X,A4,I4)

```

```

ISN   ST-NO           SOURCE PROGRAM   ( MTDUMP )
47     DO 27 I=1,J1
48     JCH = 1
49     READ (70,33) JCH,(DAT(J),J=1,MAXTIM)
50     I9ZZ=JCH
51     27 WRITE(71,I9ZZ) (DAT(J),J=1,MAXTIM)
52     33 FORMAT(15.5X,1P7E10.3/(8E10.3))
53     RETURN
54     END
    
```

```

ISN   ST-NO           SOURCE PROGRAM
1     SUBROUTINE PASS (NFASS )
2     RETURN
3     END
    
```

```

NAME RSTEP3,ENTRY=ELM(FTMAIN),OVLY
DOMAIN HCM,R*X,OVLY
INPUT RELBIN
CALL JSSL,SSL,SSL2
CALL GGS
* PGSLIB
* PTSLIB
* COMLIB
CALL PLTLIB
SELECT RELBIN
FIN
    
```



F 230-75 ジョブ申込票 ①									
申込月日		2月26日		10:05時					
〒 No.	U 113		課室番号		a a a				
職員番号	b b b b		課室名		X X X X				
氏名	Y Y Y Y Y		電話		c c c c				
CPU 使用時間		メモリ量		出力ページ		出力カード			
PRTY	T. 4	C. 2		W. 0		P. 0			
実際量	分 秒		K 語		頁		枚		
VOL 通番		書き込み		BPI		NL		持ち込み	
d d d d d d		○ 印				○ 印		○ 印	
使用機器		[COM ハード有], [COM ハードなし], (PLOT)							
特別の指示									
計せ室長									

(aaa, bbbb, cccc, dddddd : Numerals)  
 (XXXX, YYYY : Name)

Fig. 1 Apply Card for Use of Computer in the Calculation  
 Center of JAERI (System B)