公開資料

ATR 「Fugen」 Data Base Design/R&D/ Plant Performance [Pressure Tube Assembly]

	Ny Service State	技	術	資	料	<u>are tapo de la c</u>	Sec. 30 (2)	ada Neolane	
開示区分		レポ	-	No.		受	領	В	
	J	1409	97	-02	3	9.	6.	19	ن
	閲覧	資料は打 には技術 ・核燃料開	资料	閲覧票	が必	要で	す		

March, 1997

PESCO Co., Ltd.

Inquiries about copyright and reproduction should be addressed to: Technical Evaluation and Patent Office. Technology Management Division. Power Reactor and Nuclear Fuel Development Corporation 9-13, 1-chome, Akasaka, Minato-ku, Tokyo 107, Japan

(C) Power Reactor and Nuclear Fuel Development Corporation 1997

ATR 「Fugen」 Data Base Design/R&D/Plant Performance [Pressure Tube Assembly]

Hiroshi Takeda* Sadamu Sawai* Hitoshi Ishigami*

Abstract

- Reflection of R&D Results, Design and Operation Experiences
 All knowledge obtained in the project, such as R&D results, design,
 operation experiences and so on, are to be reflected to following items.
 - ① Improvement of safety and reliability in plant operation
 - ② Design modification of the plant
 - 3 Design of the next plant
- Basic Standpoint for Data Base Composition
 "Design/R&D/Plant Performance Data Base" will be composed as shown in
 the following, so that the Data Base could be utilized for reflecting them to
 the above items and for improving the above items, effectively and efficiently.
 - "Design/R&D/Plant Performance Data Base" will be composed by uniting design data base and R&D data base, considering that the R&D of the project is mainly made in order to establish the design engineering and technical basis, such as design policy, design criteria, design conditions, alloable design limits, design verification, etc.
 - (2) Addition of Initial Plant Performance Data

 Design is made with safety factors, however, plants perform with its own characteristics, namely without safety factors.

 Therefore, plant performance data, especially initial plant performance data, are to be added in "Design/R&D/Plant Performance Data Base", so as to make following engineering works, effectively, and efficiently.

Work performed by PESCO Co., Ltd. under contract with Power Reactor and Nuclear Fuel Development Corporation PNC Liaison: Senior Engineer of ATR R&D Group, Reacter Development Project, Kazuteru Naruo *: PESCO Co., Ltd.

- Setting-up of appropriate safety factors, by comparing and evaluating the design and actual plant performance
- ② Ageing evaluation of components and equipment, coupled with annual inspection data
- 3 Clarification of reactor characteristics change according to fuel burnup and fuel composition change
- Upgrading technologies and design, based on the actual plant performance data
- 3 Composition of "Design/R&D/Plant Performance Data Base"
 Based on the above consideration, "Design/R&D/Plant Performance
 Data Base" is composed of following items.
 - ① Design Basic Items

(Table-1)

- ② Engineering data on design (Design technology basis) (Table-2)
- ③ Plant Performance

(Table-3)

- 4 "Design/R&D/Plant Performance Data Base" of [Pressure Tube]
 - (1) Important Information of Pressure Tube after the Design Approval Important information for hardware, such as components and systems, after the Design Approval, resistance characteristics against their ageing.

In case of the pressure tube, such techical information are obtained in commissioning, operation annual inspection, etc.

Main information is shown as follows:

- Mechanical strength change
- ② Dimension change, especially inner diameter change
- 3 Corrosion characteritics
- 4 Crack initiation and crack growth
- ⑤ Surveillance test
- 6 Effects of irradiation
- (2) "Design/R&D/Plant performance Data Base" of [Pressure Tube] It would be considered reasonable that the above informations be collected in "Plant Operation/R&D Data Base". Therfore, Table 3 will be omitted in "Design/R&D/Plant Performance Data Base" of [Pressure Tube].

Contents

Table 1	Design Basic Items · · · · · · · · · · · · · · · · · · ·	1-1
	1. Design policies/criteria/guides etc. · · · · · · · · · · · · · · · · · · ·	
	2. Design conditions · · · · · · · · · · · · · · · · · · ·	
	3. Design (specification) / safety margin · · · · · · · · · · · · · · · · · · ·	1-8
Table 2	Engineering Data on Pressure Tube Assembly Design · · · · · · · · · · · · · · · · · · ·	2-1
	1. Characteristics of pressure tube material · · · · · · · · · · · · · · · · · · ·	2-1
	2. Material characteristics of pressure tube extension · · · · · · · · · · · · · · · · · · ·	2-6
	3. Load conditions for stress calculation for pressure tube · · · · · · · · · · · · · · · · · · ·	
	4. Rolled joint tests·····	
	5. Pressure tube monitoring · · · · · · · · · · · · · · · · · · ·	2-8
Reference	ces ······	R-1

Table 1 ATR 「Fugen」 Data Base Design/R&D/Plant Performance [Pressure Tube Assembly] Basic Design Items

Item	Design Policy, Design Condition, Design etc.	(R) (T) etc.
1. Design policies/	1. Design policies/criteria/guides etc.	
criteria/guides		
(1) Policies on design	(1) Policies on design as a whole	
as a whole		
(i) Pressure tube	(i) Pressure tube	
	Design the pressure tube based on the	
	characteristics of the Zr-2.5 wt%Nb alloy in	
	accordance with the design criteria for the pressure	
	vessel (class I vessel) of a light water reactor shown	·
	in the Notification No.501 of the MITI.	
(ii) Pressure tube	(ii) Pressure tube rolled joint	
rolled joint	In the pressure tube rolled joint, the pressure tube	
	made of the Zr-2.5wt%Nb alloy is sandwiched by	
	high-rigidity Inconel-718 or SUS-50Mod, and the	
	stress and strain of the Zr-2.5wt%Nb alloy are	
	completely dominated by the high-rigidity rolled joint	
	materials; accordingly, confirm the strength	
	(mechanical properties and durability) of the rolled	
	joint by tests.	
	Remarks:	
·	The special structure of the rolled joint makes	
	theoretical stress analysis impossible. Therefore,	
	confirm the strength by tests.	
(2) Design policies for each item/	(2) Design policies for each item/allowable value	
allowable values	(1) 377 13 (2 1 1 1 2 1 1 2 1 2 1 2 1 2 1 2 1 2 1	
(i) Wall thickness of	(i) Wall thickness of pressure tube (nominalvalue)	
pressure tube	/	
	(effective wall thickness after 30 yrs+(corrosion allowance)	
	(nominal value)= 1- tolerance of wall thickness	

	· · · · · ·		·
(ii) Design allowable	(ii)	Design allowable stress	
stress		The design allowable stress should be the min. value	
		of the following three;	
		2/3 of yield strength (at room and hign temperatures)	
:		1/3 of tensile strength (at room and hightemperatures)	
		The smaller value of either 80% of minimum creep	
		strength for load acting time or 2/3 of the mean value	
		of the creep rupture strength	
(iii) Allowable creep	(iii)	Allowable creep strain	
strain		Allowable value of membrane strain due to internal	
		pressure strain: 2.5%	
		Remarks:	
		The membrane strain of 2.5% was judged to be equal	
		to or less than the strain that causes the tertiary]
		creep. Evaluate and confirm this by monitoring actual	
		pressure tubes.	
(iv) Corrosion	(iv)	Corrosion allowance	İ
allowance		Corrosion allowance is the sum of the following:	
		· Corrosion by water	
		• Fretting corrosion	
		• Corrosion by carbon dioxide gas	
(v) Hydrogen	(y)	Hydrogen absorption	
absorption		Adopt the design value for CANDUBLW-250.	
(vi) Brittleness	(vi)	Brittleness	
<i>(</i>		Design brittleness is as follows:	
		(Maximum defect length) has adequate safety factor	
		for (limit defect length for maximum defect depth) at	
		the working and room temperatures.	
		(The penetrated defect length of the maximum defect	
		depth) has adequate safety factor for (limit defect	
		depth for the penetrated defect length) at the working	
		temperature.	
		Evaluate in accordance with the ASME Code Sec. III	
		Appendix-G, and confirm	
		(stress intensity factor during operation):	
		$\times 2$ < (limit stres intensity factor)	

	<u> </u>	T
	(stress intensity factor during hydraulic test)	
	$\times 1.5 <$ (limit stress in tensity factor)	
(vii) Fatigue analysis	(vii) Fatigue analysis Show the fact that the conditions which do not require fatigue analysis specified in Sub-Section 3 of Section 13 of Notification No.501 of the MITI are met, and that the parts required to make fatigue analysis is provided with sufficient fatigue strength.	
6.50 AT 11	(
(viii) Allowable criteria for rolled joint	Allowable criteria for rolled joint License application for specially designed facility p3-(4), Table 4 Test and inspection items Allowable criteria	
2. Design conditions	2. Design conditions	
(1) Operating conditions	(1) Operating conditions of pressure tube	
of pressure tube (i) Maximum working pressure, etc.	(i) Maximum working pressure, etc. Max. working pressure: 82kg/cm ² G Max. working temp.: 296 °C	(R)PD
(ii) Pressure tube pressure, etc.	(ii) Pressure tube pressure, etc. Lower end pressure of pressure tube: 73.6kg/cm² G Lower end temperature of pressure tube: ~280 ℃ Upper end pressure of pressure tube:~71.0kg/cm² G Upper end temperature of pressure tube: ~286℃	(R)THD
(iii) Inside diameter of pressure tube	(iii) Inside diameter of pressure tube (nominal value): 117.8mm	(R)OP
(iv) Fast neutron flux	(iv) Fast newtron flux (max. in core) : 3.4×10^{13} n/cm ² · s	(R)RPD
		j

- (2) Load condition
- (2) Load condition
- (i) Combination of loads and allowable stress intensity
- (i) Combination of loads and allowable stress intensity

 allowable stress intensity

 1st General 1st 1st+2nd peak

	18t General	ISt	1st T Zno	реак
D _{C1}	Sm	1.5 S _m		_
$D_{C1}+S_1$	_	-	3S _m	Cumulative
				r < 7

Dc1: max. working load=D+ OD + PRO

Oc1: working load=D+ OP + PRO

S1: design seismic load=SH + PRS

S_m: design allowable stress

D: dead load

On: pressure and temperatur at max, working condition

Op: pressure/temperature during operation

Pro: reation force from piping due to selfweight and heat

Prs: reation force from piping due to design earthquake

SH: load applied by design earthquake

- (ii) Load conditions
- (ii) Load conditions

License application special design facility p2-4-(3) to (4), left lower Table

p2-4-(3) to (4), right Figure of the above Table

- (3) Creep strain
- (3) Creep strain (ε)

$$\epsilon = 3.12 \times 10^{-24} \cdot \phi \cdot \frac{\text{P} \cdot \text{D}}{2 \cdot \text{t}} \cdot \text{(T-160)} \cdot \text{Tm}$$

 ϕ : fast neutron flux, 90% average power operation (2.5×10¹³ n/cm² · S)

p: internal pressure, 0.715 kg/mm^2

D: inside dia. of pressure tube, 117.8mm

t: wall thickness of pressure tube, 3.98mm

Tm: operation time, 85% of 30yr ($2.24 \times 10^5 \, hr$)

- (4) Hydrogen absorption
- (4) Hydrogen absorption

Initial stage:25ppm

(5)	Brittleness
-----	-------------

(5) Btittleness

- (i) Initial defects
- (i) Initial defects

(Allowable defects at receiving inspection) ×1.1

Defective length: 3.3mm Defective depth: 0.15mm

(Detectable minimum defects in in-servic

inspection)

Defective length: 5.0mm Defective depth: 0.4mm

Remarks:

Because defects due to pressure tube assembly production, refeuling and fretting are considered to be sufficiently smaller than the one initially postulated, it would not necessary to evaluate these defects.

- (ii) Stress intensity factor
- (ii) Stress intensity factor (K)

K=M
$$\cdot \sigma \cdot \sqrt{\pi \cdot F \cdot a}$$

M: 1.12

F: 1.0

 σ : (design allowable stress) + (wedge effect)

a: defective length

- (iii) Fatigue crack
- (iii) Fatigue crack propagation rate (dc/dN,d a/dN)

$$\frac{dc}{dN} \left[\text{or } \frac{da}{dN} \right] = 1.7 \times 10^{-5} (\Delta \text{K})^{2.5}$$

K: stress intensity factor, kg/mm^{3/2}

 $\triangle \sigma$: 18.3kg/mm² +0.82kg/mm²

N: number of normal running stops, 360times

a: defective length

c: defective depth

(iv) Calculation of stress intensity fact or in accordance with

the ASME Code

(iv) Calculation of stress intensity factor in accordance with the Appendix-G of ASME Code Sec. II

$$K=M \cdot \sigma \cdot \sqrt{\pi \cdot F \cdot a}$$

M: 1.12

F:1.0

 σ : (membrane stress) + (wedge effect)

	a : Defective length	
	Calculation conditions for σ	
	Inside dia. of pressure tube	
	= (nominal value) + (max. tolerance)	
	= (117.8 + 0.762) mm	
	Wall thickness of pressure tube	
	= (nominal value) - (max. tolerance)	
	- (corrosion allowance)	
	$= \{4.3 (1-0.075)-0.62\} \text{ mm}$	
	Internal pressure = 0.715 kg/mm ² (during operation)	
	0.82 kg/mm² (during testing)	
(6) Testing conditions for rolled joint	(6) Testing conditions for rolled joint	
(i) Air tightness test	(i) Air tightness test	
., 0	(Air leak test)	
:	Testing pressure 5kg/cm ² G	
	Shelt time 0.5hr	
	Testing temperature Room temperature	
	(Helium leak test)	
	Testing pressure 5kg/cm ² G	
	(After air leak test)	
	Testing pressure 89kg/cm ² G	
	Testing temperature Room temperature	
(ii) Pressure test	(ii) Pressure test	
()	Hydraculic test Perform after air tightness test	
	Testing pressure 160kg/cm ² G	
	Shelf time 0.5hr	
	Testing temperature Room temperature	
(iii) Thermal cycle test	(iii) Thermal cycle test (after air tightness / pressure tests)	
(m) incimal cycle test	the state (many same segments and segments)	
	(Thermal soak test) Fluid temperature $300\%\pm5\%$	
	V-mg, V-m	
	Circulating flow rate 175l/hr Time 144hr	
	Torsional moment 100kg-m	
	l l	

	(Thermal cycle test)	
	Temperature range for thermal cycle 100°C-300°C	
	Temperature-rising rate 7℃ / min	
	Temperature-falling rate 7℃ / min	
	Number of thermal cycles 600times	
	Pressure 92kg/cm ²	
	Circulating flow rate 175l/hr	
	Torsional moment 100kg-m	
	(Thermal shock test)	
	Temperature range for thermal shock 100℃-300℃	
	Temperature-rising rate 20°C / min	
	Temperature-falling rate 7℃ / min	
·	Number of thermal shocks 60times	
	Pressure 92kg/cm ²	
	Circulating flow rate 1751/hr	
	Torsional moment 100kg-m	
(iv) Tension test	(iv) Tension test (after air tightness / pressure tests)	
	Testing temperature design temperature (300℃)	
(v) Bending test	(v) Bending test (after air tightness/pressure tests)	
	Testing temperature design temperature	
	Testing load design bending m	
	2 x (design bending	
	moment rupture	
	strength)	
(vii) Torsional test	(vii) Torsional test	
	Testing temperature design temperature	
	Load conditions design torsional moment	
	2 x (design torsional	
	moment rupture	
	strength)	
(Ⅷ) Repetitive	(vii) Repetitive internal pressure test	
internal	Testing temperature room temperature	
pressure test	Testing pressure 100-180kg/cm ²	
_	Number of cycles 5,000-100,000	
	Frequency 8~30 cpm	

3. Design	3. Design (specification) / safety margin	
(specification)/		
safety margin		
(1) Main specification	(1) Main specification of pressure tube max.	
of pressure tube	Max. working pressure 82kg/cm ² G]
	Max. working temperature 296℃	
	Inside dia.of pressure tube 117.8mm±0.762mm	(T)THD
	-0mm	(T)RPD
		(T)FD
	Wall thickness of pressure tube 4.3mm± 0.32mm	(T)FD
	Length of pressure tube about 4.7m	(T)FD
	Pressure tube material Zr-2.5Wt% Nb alloy	(T)RPD
(2) Main dimensions/	(2) Main dimensions/material of pressure tube assembly	(T)RPD
material of	License application for special design facility	(T) THD
pressure	Figure for the range of license application of	(T) FD
tube assembly	special design facility	
	(3) Design allowable stress (18.3kg/mm²)	
(3) Design allowable	2/3 of yield strength 26.7kg/mm ²	
stress	1/3 of tensile strength 18.3kg/mm ²	
	Smaller value of either 80% of creep rupture strength or	
	$2/3$ of the average 30 kg/mm^2	
(4) Creep strain	(4) Creep strain 2.3%/30yr	(T) THD
(5) Corrosion	(5) Corrosion allowance (0.62mm)	
allowance	Corrosion by water 0.31mm	
	Fretting corrosion 0.23mm	
	Corrosion by carbon dioxide gas 0.08mm	
(6) Hydrogen	(6) Hydrogen adsorption	
absorption	Initial stage 2.5ppm	
	After 15yr 118ppm	
	After 30yr 211ppm	
(7) Brittleness	(7) Brittleness	
	License application for special design facility	
	p2-3-(51), Table	
	p2-2-(28), Table2	

(8) Stress calculation (8) Stress calculation Stress calculation for the vicinity of rolled joint imes Lisense application for special design facility imesp2-4-(16), Table 7 p2-4-(17), Table 8 transient conditions for analysis states 1-4 (p2-4-(15)) p2-4-(18), Table 9 p2-4-(1), left lower Table (9) Fatigue analysis (9) Fatigue analysis (i) Fatigue diagram (i) Fatigue diagram License application for special design facility L p2-2-(48), Fig.17 (ii) Number of cycles (i i) Number of cycles of atmospheric pressureof atmospheric operating pressure Allowable number of cycles with the repeated peak pressure pressure of 3Sm =700times operating Number of cycles of pressure (start-up/shutdown) + (pressure/leak test) =415times (iii) Allowable double (iii) Allowable double amplitude of pressure fluctuation during load operation amplitude of Repeated peak stress for 106 cycles: 7.1kg/mm² pressure Pressure fluctuation exceeding the above = fluctuation during load (loss of station power) + (turbine trip) operaztion Number of the above pressure fluctuation: 320 times Max. pressure fluctuation for the above: 35.6kg/cm² Allowable double amplitude of pressure fluctuation for the above:113kg/cm² (iv) Max. allowable (iv) Max. allowable temperature difference between temperature 2 points difference Max. allowable temperature difference between :604 ℃ between 2points 2 points Max. allowable temperature difference between

2 points during load running :61.0°C

- (v) Allowable double amplitude of stress due to mechanical load
- (v) Allowable double amplitude of stress due to mechanical load

Repeated stress for 106 cycles

 $: 7.1 \text{kg/mm}^2$

Event exceeding the above: design earthquake

number of the above

:50times

Repeated peak stress for the above number

 $: 183 \text{kg/mm}^2$

- (10) Results of tests for rolled joint
- (10) Results of tests for rolled joint

 License application for special design facility
 p3-(4), Table4
- (11) Safety margin
- (11) Safety margin
- (i) Safety margin for brittleness evaluation
- (i) Safety margin for brittleness evaluation
 Do not take into consideration the number of cycles
 (in the order of 10³ 10⁵) of stress change in which an initial notch defect grows into an initial fatigue crack.

As to fatigue crack propagation rate, adopt the best fit data in the working range of pressure tubes, whereas analyze and calculate fatigue propagation by using a safety factor which is 20times as high as that for the stress cycle.

Calculate stress intensity factor by taking into account the infinite length of surface defect and "wedge effect" due to internal pressure.

The stress intensity factors in the longitudinal direction of the defect are smaller than that in the longitudinal end of the defect. However, consider that the longitudinal crack propagation rate is equal to the crack propagation rate toward depth.

Table 2

ATR 「Fugen」 Data Base

Design /R&D/Plant Performance [Pressure Tube Assembly]

Engineering Data on Pressure Tube Assembly Design

Item	Design Engineering and Technical Basis, etc.	(R) (T) etc.
1. Characteristics of	1. Characteristics of pressure tube material	
pressure tube material		
(1) Composition of	(1) Composition of Zr-2.5Wt% Nb alloy	(T)RPD
Zr-2.5wt% Nb alloy	License application for special design facility p2-2-(3), Table 1	
(2) Mechanical properties of Zr-2.5wt%N b alloy	(2) Mechanical properties of Zr-2.5wt% Nn al loy	(T)FD
(i) Yield strength	(i) Yield strength	
	License application for special design facility	
,	p2-2-(12), Fig.1	
	Remarks:	
	BLW-250-TECH NOTE 61, (1964)	
(ii) Tensile strength	(ii) Tensile strength	
()	License application for special design facility	
	p2-2-(18), Fig.4	
	Remarks:	
; 	BLW-250-TECH NOTE 61, (1961)	
(iii) Creep rupture	(iii) Creep rupture strength	
strength	License application for special design facility	
40-3-80-	p2-2-(18), Fig.14	
	Remarks:	
	AECL MET-1-58 (1965)	
Gard Chronic control	(iv) Creep rate	
(iv) Creep rate	Design equation	
	$\varepsilon = 3.12 \times 10^{-24} \cdot \phi \cdot \sigma \cdot (\text{T-160})$	
	E -0.12 1.10 \$ 0 (1-100)	

```
License application for special design facility
  p2-2-(22), Table 9
  p2-2-(23), Table 10
  p2-2-(27), Fig.8
  p2-2-(28), Fig.9
  CRNL-67, (1967); J. of Nuclear Materials,
  26, (1968) p2-111;
  AECL-3365; CNA (1965), P537;
  CRNL-139, (1968); AECL MET-1-58;
  Emprical formula
   \dot{\varepsilon} = \dot{\varepsilon}_{o} \cdot f(\phi t) + B \cdot f(A) \cdot \sigma^{n}
                     \cdot \phi p \cdot t^{m-1} \cdot f(T) + f(G)
  1st term:time-dependent creep behavior
  2nd term:effect of irradiation on creep
  3rd term:irradiation growth (no load)
 : Out-of-core creep rate
  \phi: Fast neutron flux
  t:Time
 B : Constant
f(A): Function regarding amisotropy
 \sigma: Stress
 n, p, (m-1): Indexes, (1,1,0)
 T: Temperature
f (G): Function regarding irradiation gronth, etc.
  Remarks:
  J. of Nuclear Materials, 45, (1973) p335-338 and
  46, (1973), p281-292;
  Ross-Ross, JOICE Meeting (1973);
  p2-2-(29), Eq.(2)
  in license application for special design facility
Empirical formula
  The 1st term the empirical formula (Ref.1) can
  be ignored for long-term cerrp, and the 3rd term
  can be included in the 2nd term. As a result,
  the following formula can be proposed.
  _{\mathcal{E}} =K · \sigma · \phi · exp (-5500/RT)
 License application for special design facility
```

p2-2-(33), Fig.11

o
'
.

	Ref.: HW-60903, (1959)	
(iii) Specific heat	(iii) Specific heat License application for specfic design facility p2-2-(76), Fig.29 p2-2-(76), Table32 Ref.: BMI-1644, (1963); J. of Nuclear Materials, 18, (1966), p233	
(iv) Density	(iv) Density 0.238lb/in³=6.6g/cm³ License application for specific design facility p2-2-(74)	
(4) Fatigue characteristics	(4) Fatigue characteristics (design fatigue diagram) License application for special design facility p2-2-(54), Fig.22 Ref.: TRG/AECL NEWSLETTER-14, (1965) JAERI-memo 4604, (1971)	
(5) Corrosion characteristics	(5) Corrosion characteristics Design corrosion allowance for neutral water design fretting corrosion allowance design corrosion allowance for carbon for carbon dioxide gas License application for special design facility p2-2-(63), Table 1 (except central portion) Ref.: BLW-250-NOTE- MET.5 (1966)	(T)FD
(6) hydrogen absorption characteristics	(6) Hydrogen absorption characteristics License application for special design facility p2-2-(70), Table27 p2-2-(70), Table26 Ref.:BLW-250-TBCH NOTE 61, (1966); AECL MET-1-58, (1965) Basis for evaluating the hydrogen absorption amount to be 211ppm after 30yr: Design hydrogen absorption of a pressure tube given by BLW-250=110ppm for 10yr, wall thickness0.095" p2-2-(70), Table27	(T)FD

	D 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
	Design hydrogen absorption of the pressure tube of	
·	0.095 30yr	
	"Fugen"= (110ppm) · =186ppm	
	(4.3/25.4)" 10yr	
	Initial hydrogen content 25ppm	
	Hydrogen content after 30yr	
	25ppm+186ppm=211ppm	
(7) Prittleman	(7) Brittleness	
(7) Brittleness	(7) Brittleness	
(i) Crack propagation	(i) Crack propagation characteristics	
characteristics	License application for special design facility	
	l l	
	p2-3-(29), Fig.15 (at room tempera ture) p2-3-(30), Fig.16 (at 300°C)	
(ii) Fatigue crack	(ii) Fatigue crack initiation characteristics	
initiation	License application for special design facility	1
characteristics	p2-3-(28), Fig.14	
(iii) Fracture	(iii) Fracture toughness	
toughness	License application for special design facility	
	p2-3-(31), Fig.17 (effects of hydrogen content)	
	p2-3-(32), Fig.18 (effects of temp rature	
/ \ T \ \ \ 1 \ 6 \ \	(a) Timit 3.C. t	
(v) Limit defect	(v) Limit defect	
	License application for special design facility p2-3-(34), Fig.20 (at room temperature)	
	p2-3-(35), Fig.21 (at 300 °C) p2-3-(37), Fig.23 (250ppm H ₂)	
	p2-5-(57), Fig.25 (250ppm 112)	
(e) LBB test	(vi) LBB test	
(0) 222 0000	License application for special design facility	
	p2-1-(32), Table1	
	F= - (-, /,	

2. Material	2. Material characteristics of pressure tube extension
characteristics	
of pressure tube	
extension	
(1) Composition of	(1) Composition of SUS50Mod.
SUS50Mod.	Results of development of "Fugen" p79, Table2, 3 and 11
	p79, Table2, 3 and 11
(2) Mechanical	(2) Mechanical properties of SUS50Mod.
properties	Results of development of "Fugen" p79, Table2, 3 and 11
of SUS50Mod.	p79, Table2, 3 and 11
(3) Impact transition	(3) Impact transition characteristics of SUS 50Mod
characteristics of	
SUS50Mod.	Results of development of "Fugen" p80, Fig.s 2, 3 and 24
SOSSOMICA.	poo, rig.s 2, 5 and 24
3. Load conditions for	3. Load conditions for stress calculation for pressure
stress calculation	tube
for pressure tube	
(1) Stress calculati on	(1) Stress calculation point (near lower rolled joint)
point	License application for special design facility p2-4-(1), Fig.1
·	p2-4-(1), Fig.1
(0.7)	
(2) Design load	(2) Design load conditions
conditions	
(i) Dead load	(i) Dead load (D)
	Upper extended tube 101kg
	Pressure tube 56kg
	Total 157kg
(ii) Pressure /	(ii) Pressure/temperature under max. working
temperature	conditions (O _D)
under max.	Max. working pressure 82.0kg/cm ² G
working	Max. working temperature 296°C
conditions	
(iii) Pressure/tempera	(iii) Pressure/temperature under plant operation (O _P)
ture under plant	License application for special design facility
operation	p2-4-(3) to (4), Fig.2

(: A T 1 1: 7 1: 2	(iv) I and applied at the time of design and because (C)	
(iv) Load applied at the	(iv) Load applied at the time of design earthquake (S _H) Horizontal seismic force	į
time of design		
earthquake	Bending moment 1.55×10 ⁵ kg • mm	
	Shear force 148kg	
	Vertical seismic force 45kg	
(v) Stress from piping due to its self-	(v) Stress from piping due to its self-weight and heat (Pro)	
weight	Bending moment 1.0×103kg · mm	
	Axial force 31kg	
	Forsional moment 1.3×10 ⁴ kg · mm	•
	License application for special design facility p2-4-(6), Table 1	
(vi) Reaction from	(vi) Reaction from piping due to design earthquake (Prs)	
piping due to	Moment 3.0×10 ³ kg · mm	
design	Axial force 73kg	
earthquake	Forsional moment $6.6 \times 10^4 \text{kg} \cdot \text{mm}$,
out inquite	License application for special design facility	
	p2-4-(8), Table2	
(3) Temperature distribution	(3) Temperature distribution	-
(i) Evaluation point	(i) Evaluation point for temperature distribution	
for temperature	License application for special design facility	
distribution	p2-4-(11), Fig.3	
(ii) Change in	(ii) Change in temperature distribution	
temperature	License application for special design facility	
distribution	p2-4-(12), Fig.4-1	;
	p2-4-(13), Fig.4-2 p2-4-(14), Fig.4-3	
4. Rolled joint tests	4. Rolled joint tests	
(1) Summary of	(1) Summary of rolled joint tests	
rolled joint tests	(1) Summary of rotten Joint resus	
(i) Upper rolled joint	(i) Upper rolled joint test for short pressure tube	
test for short	License application for special design facility	
pressure tube	p3-(2), Table1	

		7
(ii) Lower rolled joint test for short pressure tube	(ii) Lower rolled joint test for short pressure tube License application for special design facility p3-(2), Table2	
(iii) Test for full-scale pressure tube assembly	(iii) Test for full-scale pressure tube assembly License application for special design facility p3-(3), Table3	
(2) Summary of results of rolled joint tests	(2) Summary of results of rolled joint tests License application for special design facility p3-(4), Table4	
(3) Results of upper rolled joint tests fors hort pressure tube	(3) Results of upper rolled joint tests for short pressure tube License application for special design facility p3-(25), Table 5 p3-(27), Table 6 p3-(29), Table 7	
(4) Results of lower rolled joint tests fors hort pressure tube	(4) Results of lower rolled joint tests for short pressure tube License application for special design facility p3-(31), Table 8 p3-(33), Table 9 p3-(35), Table 10	
(5) Results of full-scale pressure tube assembly	(5) Results of full-scale pressure tube assembly License application for special design facility p3-(45), Table 11	
5. Pressure tube mon itoring (1) Pressure tube monitoring plan	 5. Pressure tube monitoring (1) Pressure tube monitoring plan Application for construction modification permit of 	(T)PD
	ATR prototype reactor, attached documents, (final documents) Attached document8, supplement6, p109 Attached papers 2, p2-1-(10) to (10)	

<u> </u>	<u> </u>	
	Follow-up pressure tube inspection	
	Inspection item : creep strain	
	Number of pressure tubes for inspection : 4 tubes	
	In-service inspection	
1	Inspection item: defect inspection using ultrasonic	
	wave observation of inside surface	
	with ITV	
	Number of pressure tubes for inspection:	
.	10% pressure tubes for 10yr	
(2) Monitoring using monitoring test	(2) Monitoring using monitoring test pieces	(T)PD
pieces (i) Kind of monitoring	(i) Kind of monitoring test pieces	
''	Application for construction modification permit of	
test pieces	ATR prototype reactor, Attached documents	
	(final documents),	
	Attached documents8, supplement 2, p.93	
	ditto, Fig. 3.3-3, p11	
	Tension test piece	
	Bending test piece	
	Corrosion test piece	
	Corrosion test piece	
(ii) Monitoring test	(ii) Monitoring test piece withdrawal plan	
piece withdrawal	Application for construction modification permit of	
1 -	ATR prototype reactor, (final documents)	
plan	Attached documents8, supplements 5, p103, Table	
	(1100dollott documents), 5 tipp-1 = 5 tipp-1	
(iii) Monitoring using	(iii) Monitoring using CO ₂ gas system	(T)PD
CO ₂ gas system	Monitor by detecting the moisture content at the	
CO2 gas system	outlet of the CO ₂ gas system.	
•	outles of the coa gue of bloom.	

References

- (1) Application for construction modification permit of ATR prototype reactor, Attached document 8 (June, 1976)
- (2) Application for construction modification permit of ATR prototype reactor, Committee 63, Reference paper, (November, 1970)
- (3) Application for construction modification permit of ATR prototype reactor, Committee 82, Reference paper, (January, 1972)
- (4) Application for construction modification permit of ATR prototype reactor, Committee 105, Reference paper, (September, 1974)
- (5) Application for fuel assembly design approval for initial core loading of ATR protptype reactor, Tsuruga works, (November, 1974)
- (6) Application for specially designed facility approval based upon nuclea power station engineering standards, (February, 1974)
- (7) "Fugen", reseach and development, PNC, (June, 1991)
- (8) "Fugen" Commissioning Tests, PNC SN 79-11, (September, 1979)